


Columbia River Treaty

2014/2024 Review • Phase 1 Report

July 2010



Canadian and United States Entities

This page intentionally left blank

Executive Summary

Columbia River Treaty
2014/2024 Review
Phase 1 Report

The Columbia River Treaty

Under the Columbia River Treaty (Treaty or CRT) of 1964, Canada and the United States (U.S.) jointly regulate and manage the Columbia River as it flows from British Columbia into the U.S. The Treaty has provided substantial flood control and power generation benefits to both nations.

The Treaty established Canadian and U.S. Entities as implementing agents for each government. British Columbia Hydro and Power Authority (BC Hydro) was designated as the Canadian Entity. The Bonneville Power Administration (BPA) Administrator and the U.S. Army Corps of Engineers (Corps) Division Engineer, Northwestern Division, were designated as the U.S. Entity.

The Canadian and U.S. Entities are empowered by their respective governments with broad discretion to implement the existing Columbia River Treaty. They are not, however, authorized to terminate, renegotiate, or otherwise modify the Treaty. In the U.S., authority over international treaties rests with the President, assisted in foreign relations and international negotiations by the Department of State and subject in certain cases to the advice and consent of the U.S. Senate. In Canada, international treaties are within the prerogative of the executive branch of the federal government. Under current policy, treaties are tabled in the House of Commons, and are subject to a waiting period before the executive branch brings the treaty into effect. In the case of the Columbia River Treaty, Canada has assigned certain rights and obligations relating to the Treaty to British Columbia pursuant to the Canada-B.C. Agreement. The Phase 1 report is provided to those respective governmental bodies to support possible independent and/or joint decisions that may be made with respect to the future of the Treaty.

The Treaty contains two important provisions that take effect on and after September 16, 2024, that could impact the current power and flood control benefits:

1. Canadian flood control obligations automatically change from a pre-determined annual operation to a “Called Upon” operation.
2. The year 2024 is the earliest date that either Canada or the U.S. can terminate most of the provisions of the Treaty, with a minimum 10-years advance written notice.

Hence, September 16, 2014, is the latest date that either nation could provide notice of intent to terminate and still have the termination effective at its earliest possible date in 2024. While termination would end most Treaty obligations, Called Upon flood control and Libby coordination provisions will continue regardless of termination. However, it is important to note that the Treaty has no end date and absent either country using the termination option will continue indefinitely.

Given the significance of the provisions that will take effect in 2024, it is important that the Canadian and U.S. Entities work toward an understanding of the implications for post-2024 Treaty planning and Columbia River operations. The joint effort by the Entities to conduct initial post-2024 modeling and analysis is referred to as Phase 1 of the 2014/2024 Columbia River Treaty Review.

Phase 1 Study Overview

This Phase 1 report of the 2014/2024 Columbia River Treaty Review describes the results of the three Phase 1 studies. The purpose of the Phase 1 studies was to provide information about post-2024 conditions both with and without the current Treaty from the perspective of the two purposes of the Treaty, power and flood control. The three studies were:

Treaty Continues: The Treaty was assumed to continue post-2024 with its current provisions. Canadian flood control obligations would change from the current prescribed annual operation of a dedicated amount of storage to an assumed Called Upon operation. Assured Operating Plans (AOPs) for power benefits and Canadian Entitlement provisions would continue, but modifications to current procedures would be required to reflect the revised Canadian flood control obligations.

Treaty is Terminated: The Treaty was assumed to be terminated in 2024 with no replacement agreement. The U.S. payment of the Canadian Entitlement would end, as would the requirement for Canada to regulate flows for U.S. power interests. Canadian flood control obligations would change to an assumed Called Upon operation. Absent the Treaty obligation to coordinate for power, Canada might operate its projects for Canadian power, flood control, and other benefits. Two Canadian operational scenarios were developed to depict a range of possible flows across the border into the U.S. One scenario represented a Canadian operation with minimal Canadian reservoir storage draft, for local flood control only, and one scenario represented a Canadian reservoir draft for power production in Canada.

Continuation of Pre-2024 Conditions: The Treaty was assumed to continue post-2024 with the pre-2024 Flood Control Operating Plan (FCOP), AOPs, and Canadian Entitlement procedures. The initial long-term purchase of prescribed annual flood control operation by the Canadian projects constructed under the Treaty is set to expire in 2024 independent of potential Treaty termination. This study is not consistent with the existing Treaty language in that it assumed the current coordinated FCOP operation would continue post-2024. Therefore, new arrangements (e.g., an extension or replacement of the current flood control purchase) would be required to implement these study conditions. This study was conducted to provide a basis for comparison with current operations.

The three Phase 1 studies included 13 scenarios. The scenarios were designed to test and compare a range of possible situations with varying: 1) study time horizons, 2) maximum flood control flow objectives, 3) AOP procedures, and 4) observed and forecast mode water supply and inflow model simulations.

Expected outcomes of the studies were to identify, discuss, and evaluate the impacts of these alternative post-2024 scenarios on:

- Canadian and U.S. power operations

- Future Canadian Entitlement levels
- Potential Called Upon flood control operations
- Potential outflows across the border from Arrow and Duncan
- Elevations and storage contents at Canadian and U.S. reservoirs

Findings and Conclusions

In general, the Phase 1 studies showed that power and flood control operations have common interests and requirements, regardless of whether or not the Treaty is terminated. Both operations attempted to reshape the flow of the Columbia River from peaks in the spring into the winter. Beyond that, there were basic similarities and trade-offs between those two purposes under both the Treaty Continues and Treaty is Terminated studies:

If the Treaty remains in place after 2024...

- U.S. flood control and power benefited from an assured operating plan for Canadian storage.
- Canada benefited from continued Canadian Entitlement and increased flexibility to optimize generation in Canada.
- Although there is uncertainty with the estimate, Canadian Entitlement energy levels were expected to decrease from about 470 aMW in 2024 to a minimum level of about 290 aMW by around 2040. The amount of future thermal resources used to meet load in the PNWA was the most important factor affecting the Canadian Entitlement¹. The latter generally decreases with increases in thermal resources.
- Compared to the Treaty is Terminated scenario, coordinated U.S./Canadian assured power drafts provided substantial flood control benefits to the U.S., including more certainty and less volume of Canadian storage required during a Called Upon flood control request.
- The coordinated and assured operation provided substantial power benefits to the U.S. by shaping flows from Arrow from low power value months during the spring freshet to high-value winter/summer months, providing approximately 225 aMW of additional firm energy during the critical period compared with Treaty is Terminated, and maintaining a four-year critical period.²

If the Treaty terminates after 2024...

¹ Estimated energy conservation is one example of how Conservation assumptions can introduce uncertainty into the Entitlement calculation. The Phase 1 Entitlement calculation used conservation values from the NW Power and Conservation Council's 5th Power Plan, whereas the Council's 6th Power Plan included considerably more energy conservation. Higher conservation values result in a slower decline in Canadian Entitlement over time.

² Critical period is the historical streamflow period over which the water available from reservoir releases plus the natural streamflow is capable of producing the least amount of hydroelectric power in meeting system load requirements.

- Canada lost the Canadian Entitlement but gained flexibility to operate solely for Canadian power and non-power interests, with the exception of during a Called Upon operation.
- Canada was motivated to operate with Arrow elevations higher and on average more constant discharges across the year for more optimal power generation.
- Due to its proximity to the U.S./Canadian border, Arrow storage is more effective in providing U.S. flood control protection than either Mica or Duncan. Therefore, most of the Called Upon flood control draft was at Arrow.
- The Phase 1 power studies were limited to monthly time steps. However, average monthly flows do not represent the variability of discharges that may occur in actual operations. Uncertainty in daily/weekly/monthly flow releases could increase as Canada operated for its own needs and the operation was not coordinated.
- The reduction of Arrow plus Duncan outflows in August caused Grand Coulee to draft during the month and not fully refill during the fall and early winter in most years. In comparison, under the Treaty Continues scenario, the coordinated operation maintained flows from Arrow during this period and allowed a higher elevation at Grand Coulee.
- Overall average annual hydro energy production in Canada and the U.S. did not change much; however, the month-to-month shape of generation differed dramatically from the coordinated operation under the Treaty Continues scenario.
- The critical period was shortened from four years to one year and may be a concern during prolonged dry sequences.

Regardless of whether the Treaty is terminated or continues after 2024, system flood control operations are expected to change significantly, from an annual specified operation, to an operation as provided under Called Upon provisions. In either case, the U.S. will have access to flood control storage in Canadian reservoirs within the rights and limitations for Called Upon storage defined by the Treaty. Canada will be compensated by the U.S. for any operating costs incurred by Canada and economic losses arising directly from Canada forgoing alternative uses of the storage used to provide the flood control in the U.S. The Treaty provides the basic outline for Called Upon flood control but contains little detail with respect to procedures and methodologies for actual implementation. Those details remain to be resolved.

There are different views between the Entities with regard to interpretation of Called Upon rights and obligations and flood control objectives. Thus, two different flow objectives were simulated to provide information regarding a potential range of future operations. According to the FCOP, flooding begins around 450 kcfs as measured at The Dalles, Oregon, while major damages begin around 600 kcfs in the lower Columbia. Scenarios with maximum flood control objectives of 600 kcfs and 450 kcfs were conducted for both the Treaty Continues and Treaty is Terminated studies.

The Phase 1 studies are a starting point to understand Called Upon by examining one set of assumed procedures and methodologies. On the basis of those assumptions, some findings specific to Called Upon flood control include:

- The frequency that Called Upon flood control operations would be required was driven by the assumed procedure and maximum flood control target flow measured at The Dalles. As expected, the lower the target the more frequently Called Upon storage in Canada was needed. In scenarios where the target was 600 kcfs at The Dalles, Called Upon was needed in 21 years out of the 70-year record, and where the target at The Dalles was 450 kcfs, Called Upon was needed in 52 years of the 70-year record. This result was the same whether the Treaty continued or was terminated. The joint study team believes these results overestimate the frequency of Called Upon years, but further investigation was deferred to follow-up studies.
- The average volume of Called Upon storage required to meet U.S. flood control needs (additional storage over and above planned Canadian power and local flood control drafts) increased substantially when comparing the Treaty Continues and Treaty is Terminated studies, ranging from an average of 1 Maf to 11 Maf, respectively. The relative certainty of Canadian operations in the Treaty Continues versus Treaty is Terminated studies was the primary driver of Called Upon volumes as well as the duration of Called Upon events.
- The Treaty limits access to Called Upon storage only for flood events that cannot be adequately controlled by all related storage in the U.S. In the Phase 1 studies, effective use of flood control storage resulted in U.S. reservoirs being drawn down more frequently and deeper than current conditions, with reduced refill reliability. Comparing Called Upon years to non-Called Upon years, Hungry Horse, Dworshak and Brownlee reservoirs were drawn down an average of 45, 27 and 31 feet deeper, respectively, by April 30. Depending on the alternative flood control operation, Libby Reservoir in Called Upon years was drawn down an average of 11 to 47 feet deeper. At Grand Coulee, for Called Upon years in which refill began after May 1, the reservoir was drawn down an average of 14 to 18 feet deeper. In addition, Grand Coulee drafted empty four years out of the 70-year record in the base condition, compared to 30 years when the flow objective at The Dalles was 450 kcfs and 10 years when the flow objective was 600 kcfs.
- Most of the Called Upon draft from Canadian reservoirs is required from Arrow reservoir, since it is the most-effective Canadian reservoir for reducing flows at The Dalles. Because of the deep power draft at Mica, Called Upon did not usually affect Mica, and similarly, had only a minor impact at Duncan.
- Called Upon operation provided incidental power benefits to the U.S. while managing flooding in the U.S.

Possible Future Studies

The Phase 1 studies, while providing valuable information and knowledge, also generated many questions. Areas identified for possible further evaluation, either independently or jointly, include:

- **Called Upon Flood Control:** Regardless of a decision to continue or terminate the Treaty, the Canadian and U.S. Entities will be responsible for implementing Called Upon flood control operations after September 16, 2024, and there are many details to be resolved by the Entities. Assumed methods and procedures applied in the Phase 1

studies assisted in identifying some constraints and shortcomings. The Phase 1 report presents a series of recommendations for additional technical evaluations that should be undertaken to refine possible Called Upon flood control operations, including the associated economic losses and operating costs, and the use of all U.S.-related storage.

- **System Power Studies:** The Phase 1 studies did not examine optimizing the critical period and refill studies that determine operating criteria. Future studies could also explore methods to optimize firm load carrying capability and secondary energy production. In addition, other areas that were not considered or analyzed in detail in the Phase 1 studies were alternative scenarios for loads and resources, ability to meet peak loads, system reliability, the value of power, and the possible transition from an energy-deficit system to a capacity-deficit system.
- **Climate Change:** It is important when considering the future of the Columbia River Treaty or developing and assessing the implementation of Called Upon to consider the possible changes to the meteorology and hydrology of the Columbia Basin due to climate change. The scope of the Phase 1 studies did not include climate change scenarios; however, it is recognized that differing scenarios could be modeled in future studies.
- **Evaluation of Other Interests:** Analysis of the benefits and impacts associated with the Phase 1 studies described in this report was strictly limited to power generation and flood control. No attempt was made in this report to evaluate the future effects and benefits of the Phase 1 scenarios on other operating interests of the Columbia River system, such as fisheries, wildlife habitat, cultural resources, recreation, irrigation, water supply, water quality, and navigation. The Canadian and U.S. Entities recognize that evaluation of the potential impacts of system operations on other interests under alternative futures in which the Treaty is continued or terminated will be necessary in any future phases of study conducted under the Columbia River Treaty Review.

Either nation may choose to terminate most provisions of the Treaty as of 2024 with 10-year advance notice. At this time, no decision has been made by either the U.S. or Canada to terminate the Treaty. Similarly, no decision has been made to attempt to renegotiate or otherwise modify the current terms of the Treaty. Absent those decisions, the Entities will continue to collaborate to implement the existing Treaty within their authorities while seeking to more fully integrate mutually beneficial contemporary fish and other environmental and social needs into system operations. The Entities recognize that there are significant issues beyond the basic power and flood control scenarios examined in the Phase 1 studies. The U.S. and Canada will work to hear from regional interests, stakeholders, and sovereigns to define additional scenarios for analysis.

TABLE OF CONTENTS

Preface.....	xi
1. Introduction	1
1.1. Purpose.....	1
1.2. Treaty Operations Planning and Modeling Background.....	2
1.2.1. Flood Control Operating Plan	2
1.2.2. Called Upon Flood Control	3
1.2.3. Assured Operating Plan and Determination of Downstream Power Benefits....	4
1.2.4. Detailed Operating Plan	4
1.2.5. Treaty Storage Regulation.....	4
1.2.6. Canadian Flexibility Operations.....	5
1.2.7. Power Impact Studies.....	6
1.2.8. Other River Uses, Operations, and Agreements.....	6
2. Study Approach.....	8
2.1. Overview of Phase 1 Studies.....	8
2.2. Description of Studies	8
2.3. Overview of Study Scenarios.....	12
2.3.1. Scenario Descriptions.....	12
2.3.2. Scenario Assumptions and Variations.....	13
2.4. Critical Considerations Not Included in the Phase 1 Studies.....	15
2.5. Risks and Limitations of Studies.....	16
3. Methods and Results	17
3.1. Introduction	17
3.2. Power Loads and Resources.....	17
3.2.1. Introduction	17
3.2.2. Procedures and Assumptions.....	18
3.2.3. Study C Loads and Resources.....	20
3.2.4. Load/Resource Differences between Studies A, B, and C.....	22
3.2.5. Risk and Uncertainty in Forecasts of Loads and Resources	23
3.3. Assured Operating Plan and Determination of Downstream Power Benefits for Studies A and C.....	24
3.3.1. Introduction	24
3.3.2. Procedures and Assumptions.....	25
3.3.3. Results of AOP Studies	28
3.3.4. Results of DDPB Studies and Calculation of Canadian Entitlement	34
3.3.5. Uncertainty and Factors Affecting the AOP and Canadian Entitlement.....	39
3.4. Flood Control Operations: Studies A and B.....	41
3.4.1. Overview of Called Upon Flood Control Operations After 2024	41
3.4.2. Called Upon Flood Control Assumptions	42
3.4.3. Called Upon Flood Control Modeling Methodology.....	43
3.4.4. Results of Post-2024 Called Upon Flood Control Operations	45

3.5.	Called Upon Impacts to Canadian Composite Storage, Arrow plus Duncan Outflow, Grand Coulee, and Canadian and U.S. Generation	58
3.5.1.	Modeling Overview	58
3.5.2.	Called Upon Impacts to Canadian Composite Storage	60
3.5.3.	Called Upon Impacts to Arrow plus Duncan Outflow	62
3.5.4.	Called Upon Impacts to Grand Coulee Reservoir Elevation.....	65
3.5.5.	Called Upon Impacts to Canadian Generation	67
3.5.6.	Called Upon Impacts to U.S. System Generation	68
3.6.	70-Year Average and Critical Period Generation	71
3.6.1.	70-year Average Generation	71
3.6.2.	Critical Period Generation.....	74
4.	Summary and Key Findings	75
4.1.	Called Upon Flood Control	75
4.2.	Power Loads and Resources	76
4.3.	Long-term Planning (AOP)	76
4.4.	Determination of Downstream Power Benefits – Canadian Entitlement.....	77
4.5.	Reservoir Impacts.....	77
4.6.	Arrow plus Duncan Outflows.....	78
4.7.	Generation Impacts.....	78
5.	Recommendations for Future Studies	80
5.1.	Introduction	80
5.2.	Procedures and Methodologies	80
5.2.1.	Called Upon Flood Control	80
5.2.2.	Ongoing Corps of Engineers Flood Risk Assessment.....	83
5.2.3.	Capacity Credit Limit.....	84
5.2.4.	Additional Power Studies.....	85
5.3.	Scenarios	85
5.3.1.	Non-Power and Non-Flood Control Uses	85
5.3.2.	Climate Change – Physical Impacts.....	85
5.3.3.	Climate Change – Green Energy.....	86
5.3.4.	Ranges of Uncertainties.....	86

Tables

Table 2-1 – Comparison of Phase 1 Studies	9
Table 2-2 – Scenarios Analyzed as Part of Phase 1 Technical Studies	12
Table 3-1 – Forecast Loads for AOP14, C2024-25, and C2044-45	20
Table 3-2 – Resources for AOPs for 2013-14, 2024-25, 2044-45	20
Table 3-3 – Changes to Exports, Imports, Hydro Capability, & Thermal Resources between Studies A, B, and C	22
Table 3-4 – AOP Joint Optimum Results (aMW)	34
Table 3-5 – Comparison of Thermal Displacement Market, in average annual MW	35
Table 3-6 – Canadian Entitlement for Studies A and C and Comparison with AOP14	35
Table 3-7 – Calculation of the Thermal Displacement Market	36
Table 3-8 – Step II and III Critical Period Results	37
Table 3-9 – Calculation of 2044-45 Canadian Entitlement	37
Table 3-10 – Summary of Called Upon Frequency, Peak Flows and Volumes	46
Table 3-11 – Average Number of Days Called Upon Draft is Greater than the Planned Draft at Canadian Reservoirs	47
Table 3-12 – Called Upon Storage Volumes (Maf) Required from Canadian Projects	48
Table 3-13 – Comparison of Peak Flows at The Dalles	49
Table 3-14 – Libby	53
Table 3-15 – Hungry Horse	54
Table 3-16 – Dworshak	54
Table 3-17 – Brownlee	54
Table 3-18 – Grand Coulee	55
Table 3-19 – Canadian Reservoir Operation Applied in Each Comparison	59
Table 3-20 – Canadian Generation Difference Between Called Upon and Non-Called Upon Scenarios	68
Table 3-21 – U.S. System Generation Difference Between Called Upon and Non-Called Upon Scenarios	69
Table 3-22 – Generation by Scenario (70-year Average)	71
Table 3-23 – Monthly Differences between the Treaty is Terminated with Canadian Power Draft Scenario and the Treaty Continues Scenario (B2F minus A1F)	72
Table 3-24 – Study A and B2 Critical Period and Critical Period Generation	74
Table 4-1 – Phase 1 Results for Canadian Entitlement	77
Table 4-2 – Called Upon Years vs. Years Grand Coulee at 1208 ft on April 30	77

Figures

Figure 1-1 – Example of a Mica Flex Operation Compared to TSR Operation	5
Figure 1-2 – Example of a Corresponding Flex Operation for Arrow	6
Figure 3-1 – 2024-25 Resources for Study C	22
Figure 3-2 – Comparison of Actual PNWA Firm Loads to AOP Loads and Resources	23
Figure 3-3 – Comparison of Composite Canadian URCs, 70-yr Avg	27
Figure 3-4 – Grand Coulee 70-Year Average URC	28
Figure 3-5 – Total Canadian ORC (70-year average)	30
Figure 3-6 – 70-Year AOPA1 Total Canadian Storage	31

Figure 3-7 – 70-year Average Composite Canadian Storage	32
Figure 3-8 – Arrow plus Duncan 70-Year Average Outflows.....	33
Figure 3-9 – Arrow plus Duncan Outflows	33
Figure 3-10 - Entitlement Energy vs. Thermal Displacement Market.....	38
Figure 3-11 – Composite Called Upon Draft Minus Power or Canadian Local Flood Control Drafts for Forecast 600 kcfs Studies.....	50
Figure 3-12 – Composite Called Upon Draft Minus Power or Canadian Local Flood Control Drafts for Forecast 450 kcfs Studies.....	51
Figure 3-13 – Comparison of Unregulated Peak Flows to Peak Flows for B1F450 Scenarios	52
Figure 3-14 – Effects of Forecast Changes on Called Upon Operations.....	56
Figure 3-15 – Effects of Called Upon on High Winter Flows.....	57
Figure 3-16 – Mica + Arrow + Duncan Storage Content (A1, B2).....	61
Figure 3-17 – Mica, Arrow, Duncan Composite Storage Contents B1	62
Figure 3-18 – Arrow plus Duncan Average Outflows (A1, B2).....	63
Figure 3-19 – Arrow plus Duncan Outflows 20 Lowest Years (based on January-July Volume)	64
Figure 3-20 – Arrow plus Duncan Average Outflow for B1	65
Figure 3-21 – Grand Coulee Average Month-Ending Elevation (A1, B2).....	66
Figure 3-22 – Canadian Generation (A1, B2).....	67
Figure 3-23 – U.S. System Generation (A1, B2).....	69
Figure 3-24 – U.S. System Generation 20 Lowest Years (based on January-July volume).....	70
Figure 3-25 – Example of U.S. System Generation Variability for A1F and B2F.....	73

LIST OF APPENDICES

Appendix A	Current Methodology
Appendix B	Columbia River Treaty
Appendix C	List of Acronyms and Glossary of Terms

PREFACE

The Columbia River Treaty is an international agreement between Canada and the United States (U.S.) through which the two nations jointly regulate and manage the Columbia River as it flows from British Columbia into the U.S. The Treaty and an associated Protocol were approved in 1964 (the Protocol provides detailed additional guidance for execution of the Treaty not contained in the Treaty itself; throughout this document, unless otherwise stated, references to the Treaty include the Protocol).

The Treaty established the Canadian and U.S. Entities as the implementing agents for each government. British Columbia Hydro and Power Authority (BC Hydro) was designated as the Canadian Entity responsible for developing and implementing Treaty operating plans. In the United States, the Bonneville Power Administration (BPA) Administrator and the U.S. Army Corps of Engineers (Corps) Division Engineer, Northwestern Division, were designated as the U.S. Entity, with the BPA Administrator designated as U.S. Entity Chair.

The Treaty contains two provisions that take effect on September 16, 2024 (60 years after ratification), and remain in effect thereafter that could impact the current power and flood control benefits achieved by the Treaty. First, Canada's obligation to operate a dedicated amount of storage for a coordinated and pre-determined annual operation for flood control benefits in Canada and the U.S. will end. It is replaced by an obligation to operate any related storage in Canada when "Called Upon" by the U.S. for flood control needs that cannot be adequately met by related U.S. facilities. The U.S. must pay Canada for any Canadian operating costs from the Called Upon operation, as well as for any economic losses to Canada arising directly from forgoing alternative uses of the Canadian storage used for the Called Upon operation.

Second, while the Treaty has no specified end date, it does allow either Canada or the United States the option to unilaterally terminate most of the provisions of the Treaty at any time on or after September 16, 2024, with at least 10 years' minimum notice. Surviving provisions in the case of termination include Called Upon flood control and the coordinated operation of Libby reservoir. Thus, the year 2014 is the latest date that either nation could notify the other of intent to terminate the Treaty and still have termination take effect in 2024.

No decision has been made by either the U.S. or Canada to terminate the Treaty. Similarly, no decision has been made to attempt to renegotiate or otherwise modify the current terms of the Treaty. Absent any decision regarding termination or renegotiation, the Treaty will continue with its current terms indefinitely. However, given the significance of these provisions that will take effect on and after September 16, 2024, it is important that the parties to the Treaty work toward an understanding of the potential implications for post-2024 Treaty planning and Columbia River operations.

Toward that end, Phase 1 of the 2014/2024 Columbia River Treaty Review, the initial modeling and analysis phase, has been conducted as a joint effort between the Canadian and U.S. Entities. The purpose of the Phase 1 studies is to provide information about post-2024 conditions both with and without the current Treaty and from the limited perspective of the two primary purposes of the Treaty—power and flood control.

This report provides the results of the Phase 1 studies and identifies additional potential studies that could add to the understanding of the Treaty's post-2024 provisions. However, there is no commitment by the Entities to conduct any additional studies or to work jointly in conducting any additional studies.

This report was produced by the Columbia River Treaty Operating Committee (CRTOC), with the authorization of the Canadian and U.S. Entities. The Entities have drawn from their respective staffs at BC Hydro, BPA, and the Corps in conducting the Phase 1 studies and preparing this final Phase 1 report.

It is important to remember that while the Entities have been given broad discretion to implement the Treaty, they are not authorized to terminate, renegotiate, or otherwise modify the Treaty. In Canada, international treaties are within the prerogative of the executive branch of the federal government; a treaty may be ratified by parliamentary resolution. In the case of the Columbia River Treaty, Canada has assigned certain rights and obligations relating to the Treaty to British Columbia pursuant to the Canada-BC Agreement (July 8, 1963). In the U.S., authority over international treaties rests with the President, assisted in foreign relations and international negotiations by the Department of State and subject in certain cases to the advice and consent of the U.S. Senate.

Disclaimers

The scenarios included in this Phase 1 Report are identified for analysis purposes only and do not represent a determination, decision, or commitment of either the Canadian Entity or the U.S. Entity or their respective governments concerning any particular position, operation, or other course of action. Furthermore, assumptions used in developing the Phase 1 Report scenarios do not represent the future expected position, interpretation, or perspective on any matter of either Entity or its respective government.

Nothing in this report (including the studies undertaken) sets a precedent or implies agreement by either Entity concerning interpretation of Treaty rights and obligations. In addition, nothing in this report, or actions taken by the Entities and their representatives in preparing this report, represents a past practice or procedure or constitutes a Treaty modification or interpretation that prejudices, changes, or waives in any way Treaty rights and obligations. In preparing this report, the Entities have agreed that:

- Participating in this report is not to be considered as an acknowledgment or admission by either Entity of facts, rights, or obligations that may be implied by preparing the report, any assumptions used in the report, or the results of the report.
- No operating response identified by an Entity as a possible or likely response to any condition is an admission of the required response or is to be considered to limit options that may be available to the Entity or to affect or limit the response of the Entity.
- No assumption used in this report shall be considered to be an acknowledgment or admission by either Entity of facts, rights, or obligations that may be implied by any such assumption

used in the report, and each Entity reserves the future right to challenge any assumption, notwithstanding its use in this report.

- Neither Entity makes any representation or warranty concerning assumptions, inputs, or responses provided to the other Entity in conducting the Phase 1 studies.
- Failure of an Entity to object to an assumption or operating response in this report is not to be considered acceptance of that assumption or operating response.
- Report results are non-binding on the Entities and without prejudice.
- The absence of any scenario, alternative, curve, or similar output in this report is not to be considered an acknowledgment that such scenario, alternative, curve, or output is not valid or relevant to the 2014/2024 Columbia River Treaty Review.

The Treaty does not provide detailed procedures for Called Upon, and there are differences between the Entities with regard to interpretation of Called Upon rights and obligations, including flood control objectives (e.g., 600 kcfs or 450 kcfs). Thus, on a without prejudice basis, two different flow objectives were simulated to provide information regarding a potential range of future operations.

This page intentionally left blank

1. INTRODUCTION

1.1. PURPOSE

Since 1964, the Columbia River Treaty¹ (Treaty or CRT) has provided significant benefits to the United States and Canada through coordinated river management by the two countries. When the Treaty was negotiated, its two primary purposes were to provide substantial flood control and power generation benefits to both countries.

The Treaty contains two² provisions that could impact these benefits as early as the year 2024:

1. In 2024, Canadian flood control obligations automatically change from a pre-determined annual operation to a “Called Upon” operation.
2. The year 2024 is also the earliest date that either Canada or the U.S. can terminate most of the provisions of the Treaty, with a minimum 10-years’ written notice. Called Upon flood control and a few other Treaty provisions would continue regardless of termination.

The Phase 1 studies are not designed to establish future operating strategies, alternatives to the Treaty, or government policies, but simply to begin the learning process. Both Entities recognize that additional study, analysis, and consultation are required to fully understand the potential implications of future Treaty alternatives. These studies constitute the initial modeling and analysis of the 2014/2024 Columbia River Treaty Review and were designed to investigate and understand the implications of the post-2024 provisions on power and flood control, the two primary purposes recognized in the Treaty. This report describes and discusses the methodologies and assumptions employed; the findings and results; and the risks, limitations, and issues encountered throughout the Phase 1 planning, modeling, and reporting process.

The Entities designed the Phase 1 studies to model post-2024 river operations with three basic approaches:

1. The Treaty continues post-2024 with largely the same Treaty operations as today (Study C).
2. The Treaty continues post-2024 and Called Upon flood control is implemented (Study A).
3. The Treaty is terminated in 2024 and Called Upon flood control is implemented (Study B).

The scope of the Phase 1 studies was purposely very limited. The studies did not include actual operations for fisheries and other uses, as described further in section 2.4. These scenarios should be compared only against each other and not against actual operating conditions.

¹ A full text of the Columbia River Treaty and Protocol is included in Appendix B.

² The Treaty actually contains a third 2024 provision: Canada has a right to divert the Kootenay River above Libby into Columbia Lake to the extent streamflows at the border near Newgate, BC, are not below the lesser of 2500 cfs or natural flow. This diversion option was not examined in the Phase 1 studies.

Expected key outcomes of the studies were to identify, discuss, and evaluate the impacts of these alternative post-2024 scenarios on:

- The Assured Operating Plan (AOP) and Canadian and U.S. power operations
- Future Canadian Entitlement levels (the years 2025 and 2045 were selected for study)
- Estimated benefits, limitations, and impacts of potential Called Upon flood control operations for Canadian storage
- Potential outflows across the border from Arrow and Duncan reservoirs
- Potential end-of-period reservoir elevations and contents for the Treaty reservoirs (Mica/Arrow/Duncan/Libby) and certain U.S. reservoirs (Dworshak/Grand Coulee/Hungry Horse/Brownlee)

1.2. TREATY OPERATIONS PLANNING AND MODELING BACKGROUND

Phase 1 studies required the use (with some modifications) of current Treaty planning models and processes. The following sections are provided to give a general description of the various operating plans and Treaty studies that are currently conducted, along with how they were applied to the Phase 1 studies. For additional detail on current Treaty modeling, refer to Appendix A. A list of acronyms and glossary of terms are included as Appendix C.

1.2.1. FLOOD CONTROL OPERATING PLAN

The Treaty directs the U.S. Entity to develop a Flood Control Operating Plan (FCOP) that guides the operation of prescribed Canadian storage to minimize flood damage in both Canada and the U.S. Last updated in 2003, the FCOP is part of the coordinated operation of Canadian and U.S. projects. The goal of the FCOP is to reduce to non-damaging levels, insofar as possible, the flows at all potential flood damage areas and to regulate to the lowest possible level larger floods that cannot be controlled. Under terms of the Columbia River Treaty, the coordinated flood control operation described in the FCOP continues only through September 16th, 2024, and then is replaced by Called Upon flood control. Details of current flood control operations under the FCOP are contained in Appendix A.

Canadian storage is an integral part of the overall Columbia River reservoir system and is used in coordination with U.S. storage to achieve system flood control objectives. The Treaty FCOP prescribes criteria and procedures for operation of Mica, Duncan, and Arrow reservoirs to achieve flood control objectives in both countries. Libby reservoir is included in the FCOP to meet the Treaty requirement to coordinate Libby operation for flood control protection in Canada and for the system. The Corps ensures that the principles and operating criteria within the FCOP for Treaty storage are consistent with the overall system flood control requirements for the Columbia River. Design of the current system flood control is focused on reducing flows at the reference point at The Dalles, Oregon.

The Columbia River Treaty refers to two types of flood control storage space that is provided by Canadian reservoirs prior to September 16, 2024, Primary Storage and On-Call Storage.³ The United States purchased 8.45 Maf of Primary Storage through September 2024. Primary Storage space is available on an annual basis and is operated in accordance with procedures and criteria defined in the FCOP. Primary Storage was adjusted in 1995 to 8.95 Maf as part of an optional flood control storage reallocation between Mica and Arrow reservoirs. Prior to September 2024 the Treaty also requires Canada to operate any storage in addition to the Primary Storage in the Columbia River Basin in Canada as required to meet flood control needs in the United States that cannot adequately be met by Primary Storage and flood control facilities in the United States. The Protocol further defines this need prior to 2024 as arising only in the case of potential floods that would result in a peak discharge in excess of 600,000 cfs (600 kcfs) at The Dalles after the use of all related U.S. storage capacity existing and under construction in January 1961, Libby storage, and the Primary Storage. This additional Canadian space beyond Primary Storage is labeled On-Call Storage and can be used in accordance with the Treaty.

When the forecast of unregulated April through August runoff for the Columbia River at The Dalles exceeds the values described in the FCOP, the U.S. Entity may, at its discretion, initiate formal consultation with the Canadian Entity on the need for On-Call Storage. The Treaty requires that the United States pay Canada \$1,875,000 for each of the first four calls for On-Call Storage. In addition, the United States will deliver electric power equal to the power lost by Canada as a result of operating the storage to meet the flood control need for which the call was made. The U.S. has never requested On-Call Storage from Canada, mainly because the Primary Storage, combined with annual power drafts, has adequately controlled flood peaks that have occurred since the Treaty projects were completed in 1973. This description is only a summary of the relevant provisions of the Treaty, and is subject to the actual terms, which are provided for reference in Appendix B.

1.2.2. CALLED UPON FLOOD CONTROL

After 2024, Canada's obligation to operate Primary Storage for U.S. flood control will end. In place of that obligation, the Treaty allows the U.S. to call upon any Canadian storage for U.S. flood control needs that cannot be adequately met by all related U.S. projects, limited to no greater degree of flood control after 2024 than provided for under the Treaty before 2024. Prior to calling upon Canadian storage, the U.S. must first plan to use all related storage that would be effective in controlling flooding on the Columbia River in the U.S. In addition, for each request, the U.S. must pay the operating costs incurred in providing the flood control and any economic loss arising from Canada forgoing alternative uses of the storage. This description is only a high-level summary of certain provisions of the Treaty, and the reader is referred to the provisions themselves (provided in Appendix B).

The Entities expect that a Called Upon request would be implemented as needed within an

³ As standard naming conventions used in the FCOP and other implementation plans under the Treaty, the Entities refer to On-Call Storage as this additional Canadian storage needed over and above Primary Storage prior to 2024. Conversely, the term Called Upon refers to the Treaty flood control operation that will occur subsequent to 2024 in which the U.S. may call upon Canada to provide storage to control flooding that cannot be adequately met by flood control facilities in the U.S.

operating year. Therefore, to assess the impacts of Called Upon on the Canadian Treaty projects and U.S. system, Called Upon operations were not modeled in long-term planning studies (AOP) but instead were applied using short-term modeling that more closely approximated real-time flood control operations. This assumption is similar to the current use of On Call flood control as described in the FCOP, which is available to be used in an operational timeframe as may be needed, with no modeling within the long-term AOP studies. How a Called Upon request could be implemented has not been agreed between the Entities.

1.2.3. ASSURED OPERATING PLAN AND DETERMINATION OF DOWNSTREAM POWER BENEFITS

The Treaty requires that the Entities prepare annually an Assured Operating Plan for Canadian Storage and the resulting Determination of Downstream Power Benefits (DDPB). These plans are prepared annually for the sixth succeeding operating year. The AOPs are designed to achieve an optimum power operation in both Canada and the U.S. The DDPB calculates the Canadian Entitlement, which is defined to be one-half of the computed downstream power benefits in the U.S.

The AOP operating criteria consist primarily of a series of rule curves and requirements that guide reservoir operations for flood control and optimum power generation. Typically, Canadian Treaty reservoirs are guided by Operating Rule Curves and requirements that ensure flood control, optimum power, and refill for the coordinated system in average and better water years. During low flow conditions, Critical Rule Curves guide reservoir operations for firm power needs. In addition, procedures for flow and storage content objectives at Mica, together with storage and flow limits at Mica and Arrow, help optimize Canadian power generation within the overall system operation.

1.2.4. DETAILED OPERATING PLAN

Each year a Detailed Operating Plan (DOP) is prepared for the next operating year. The DOP includes procedures for implementing the AOP and the FCOP. If the Entities agree, the Treaty allows the DOP to include changes from the AOP and FCOP that may produce results more advantageous to both countries. Typically, there are only minor changes from the AOP to the DOP. Instead, the Entities often agree to mutually beneficial deviations from the DOP during the operating year through Supplemental Operating Agreements (SOAs) that meet Canadian and U.S. power, fish, wildlife, recreation, and other interests.

1.2.5. TREATY STORAGE REGULATION

The Treaty Storage Regulation (TSR) is a hydroregulation study that implements the DOP operating criteria. In actual operation, the TSR is updated twice monthly with actual inflows for prior months and forecast unregulated flows, flood control curves, and refill curves for future months. Operation of Canadian storage is implemented by the Entities agreeing each week on the total of Arrow plus Duncan outflows. These outflows are based on drafting or filling Canadian reservoirs to end-of-month storage levels determined by a TSR study, as may be

modified by any SOAs. For the purposes of the Phase 1 studies, no SOAs or DOPs were modeled; therefore, the operating criteria used in the TSR modeling were directly from the AOP.

1.2.6. CANADIAN FLEXIBILITY OPERATIONS

Treaty power operating plans specify individual project operations for each of the three Canadian storage projects, but the obligation to operate Canadian storage is fulfilled through a monthly reservoir balancing relationship for the whole of Canadian storage. Canada has the flexibility (Flex) to operate individual projects for maximum Canadian benefits, so long as the sum of Arrow plus Duncan outflows is the same as that specified in the TSR. Thus, to correctly evaluate the changes in Canadian operations and assess the effect of Called Upon flood control on Canadian generation, a Flex operation was assumed for the studies in which the Treaty continues. Typically, a Flex operation is a reservoir operation that better meets the needs of British Columbia. Post-2024, as flood control requirements shift from FCOP to Called Upon, the ability for Canada to shift water between Canadian reservoirs increases as the Canadian Flex operation is no longer restricted by the annual primary flood control obligation.

Figure 1-1 shows an example of how Mica is drafted deeper within the Operating Year compared to the TSR. The deeper draft at Mica represents the shift of water from Mica to Arrow. As shown in Figure 1-2, Arrow is kept higher than the TSR would indicate to maximize generation at that project. While there is no impact to the U.S. from this operation in terms of amount or timing of flows coming across the border, it could have implications for Called Upon implementation, as described in section 3.4.4.6.

Figure 1-1 – Example of a Mica Flex Operation Compared to TSR Operation





Figure 1-2 – Example of a Corresponding Flex Operation for Arrow



1.2.7. POWER IMPACT STUDIES

In order to assess the impacts of Called Upon on operations, power impact studies were performed assuming Called Upon was implemented. Since Called Upon operations were assumed to be implemented in short-term operations planning, it was important to model their implementation using TSR studies with Canadian Flex operations. The power impact studies most closely resemble a TSR study. However, it was recognized that since the TSR is a monthly study it could not adequately capture true real-time implementation, but instead would provide a general assessment of the impacts of Called Upon with and without the Treaty-specified power operation.

1.2.8. OTHER RIVER USES, OPERATIONS, AND AGREEMENTS

The Phase 1 studies looked at modeling Treaty planning as it pertains to power and flood control only. Therefore, the Phase 1 study results for Canadian and U.S. reservoirs were not necessarily representative of how the projects would be operated in actual operations. Most Canadian and U.S. reservoirs are operated not only for power and flood control, but also for fish, wildlife, recreation, and other non-power/non-flood control uses. For many of these operations, the key driver has been for the benefit of fish. Examples of operations for fish include:

- Libby white sturgeon and bull trout release
- Vernita Bar protection flows for salmon
- McNary fish flow objectives for salmon
- Chum operation in fall and winter below Bonneville Dam
- Spill for fish at U.S. projects
- Operation of projects to no lower than flood control level (or minimum flow) during the fall through spring to improve flows for fish

- Draft of projects during the summer to enhance flows for fish
- Whitefish and trout spawning incubation flows below Arrow

These additional uses of the river are addressed through SOAs under the Treaty and its DOPs for within-year operations when mutually beneficial. There have been numerous SOAs entered into over the years, from a few in the 1970s to usually one or more every year since the mid-1990s.

The Libby Coordination Agreement (LCA) is another agreement under the Treaty that often has resulted in operations that help address operations for fish on an annual basis. The LCA was entered into by the Entities in February 2000 to help resolve issues at that time concerning the operation of Libby Dam. Additional annual agreements have been entered into for use of Canadian non-Treaty storage (i.e., space at the Treaty projects in Canada that is not operated under the Treaty) when mutually agreed upon to provide for fish flows and other uses.

SOA, LCA, and non-Treaty operations are implemented on a year-to-year basis and not normally included in long-term Treaty planning studies. Accordingly, SOA, LCA, and non-Treaty operations were not included in the modeling for these studies.

2. STUDY APPROACH

2.1. OVERVIEW OF PHASE 1 STUDIES

For these Phase 1 technical studies, the Entities agreed to limit the scope of the analyses to the three studies described below:

Study A - Treaty Continues: The Treaty was assumed to continue post-2024 with its current provisions. Under this study, Canadian flood control obligations changed from the current prescribed annual operation of a dedicated amount of storage to an assumed Called Upon operation. Assured Operating Plans for power benefits and Canadian Entitlement provisions were assumed to continue, but modifications to current procedures would be required to reflect revised Canadian flood control obligations.

Study B - Treaty is Terminated: The Treaty was assumed to terminate in 2024 with no replacement agreement. The U.S. payment by means of the Canadian Entitlement would end, as would the requirement for Canada to regulate flows for U.S. power interests. Canadian flood control obligations changed from the current prescribed annual operation of a dedicated amount of storage to an assumed Called Upon operation (same principles as Study A). Absent the Treaty obligation to coordinate for power, Canada could operate its projects for Canadian power, flood control, and other benefits. For the purposes of Study B, two Canadian operational scenarios were developed to depict a range of possible flows across the border into the U.S. One scenario represented a Canadian operation with minimal Canadian draft, for local flood control only, and one scenario represented a Canadian reservoir draft for power production in Canada. Many other scenarios are possible, including different operations from year to year.

Study C - Continuation of Pre-2024 Conditions: The Treaty was assumed to continue post-2024 with the existing pre-2024 Flood Control Operating Plan, Assured Operating Plan, and Canadian Entitlement procedures. The initial long-term purchase of prescribed annual flood control operation by the Canadian projects constructed under the Treaty is set to expire in 2024 independent of potential Treaty termination. Study C is not consistent with the existing Treaty language because it assumes the current coordinated FCOP operation would continue post-2024. Therefore, new arrangements (e.g., an extension or replacement of the current flood control purchase) would be required to implement these study conditions. Study C was conducted to provide a basis for comparison with current operations.

2.2. DESCRIPTION OF STUDIES

Table 2-1 provides additional information about each study in Phase 1.

Table 2-1 – Comparison of Phase 1 Studies			
	Study A: Treaty Continues	Study B: Treaty is Terminated	Study C: Continuation of Pre-2024 Conditions
Overview	Treaty continues post-2024 with its current provisions. Canadian flood control obligations change from the current assured annual operation to a Called Upon operation. This study forecast what the AOP, Canadian and U.S. power and flood control operations, and Canadian Entitlement, might look like under these conditions post-2024.	The Treaty is terminated in 2024 and Called Upon flood control is implemented. This study assessed two potential Canadian operational scenarios—one with minimal Canadian draft, for local flood control only; and one with reservoir draft specifically for power production in Canada.	Treaty continues with the current AOP, FCOP, and Canadian Entitlement procedures. This study forecast the AOP operating criteria and resulting Canadian and U.S. power and flood control operations, and the Canadian Entitlement, assuming the CRT continues with the existing pre-2024 provisions.
Flood Control	<ul style="list-style-type: none"> ➤ Called Upon flood control based on regulating flows at The Dalles to a maximum flood control objective (450 kcfs or 600 kcfs).⁴ ➤ Libby standard flood control draft. ➤ Hungry Horse VarQ⁵ flood control draft. ➤ A1 Study: Grand Coulee flood control includes adjustment for Canadian upstream power draft. ➤ A2 Study: Grand Coulee flood control includes adjustment for upstream flood control draft only. 	<ul style="list-style-type: none"> ➤ Called Upon flood control based on regulating flows at The Dalles to a maximum flood control objective (450 kcfs or 600 kcfs). ➤ Libby VarQ flood control draft. ➤ Hungry Horse VarQ flood control draft. ➤ B1 Study: Grand Coulee flood control includes adjustment for Canadian flood control draft ➤ B2 Study: Grand Coulee flood control includes adjustment for Canadian power draft 	<ul style="list-style-type: none"> ➤ Mimics the current Annual FCOP procedures. ➤ Libby standard flood control draft. ➤ Hungry Horse VarQ flood control draft. ➤ Grand Coulee flood control includes adjustment for upstream flood control draft.

⁴ Refer to section 2.3.2.2 for a description of the U.S. Flood Control Objectives.

⁵ Refer to section 3.4.2 for a description of VarQ and standard flood control operations.

Table 2-1 – Comparison of Phase 1 Studies			
	Study A: Treaty Continues	Study B: Treaty is Terminated	Study C: Continuation of Pre-2024 Conditions
Loads and Resources	Projected loads and resources for 2024-25.	Projected loads and resources for 2024-25.	Projected loads and resources for both 2024-25 and 2044-45.
Assured Operating Plan (AOP)	<ul style="list-style-type: none"> ➤ Performed using current methodology, without the Canadian primary flood control obligation. ➤ Based on 2024-25 operating year. ➤ Performed critical period and 70-year hydroregulation studies using current methodology. 	<ul style="list-style-type: none"> ➤ No AOP. Instead, Canadian operation for power and flood control in Canada only, and U.S. operation modeled with an AOP-like study using assured fixed Canadian operation. ➤ Performed critical period and 70-year hydroregulation studies using current methodology. ➤ Based on 2024-25 operating year. 	<ul style="list-style-type: none"> ➤ Performed using current methodology. ➤ Based on 2024-25 and 2044-45 operating years. ➤ Critical period and 70-year hydroregulation studies performed for 2024-25 only. ➤ 2044-45 AOP study streamlined based on 2024-25 study work.
Canadian Entitlement (DDPB)	Performed critical period and 30-year studies for determining Canadian Entitlement for 2024-25 operating year.	Canadian Entitlement discontinued.	Performed critical period and 30-year studies for determining Canadian Entitlement for 2024-25 and 2044-45 operating years.
Called Upon Power Impact Study	TSR-like studies were performed to assess power impacts due to Called Upon operation	TSR-like studies were performed to assess power impacts due to Called Upon operation	No power impact assessments were done for this study.
Simulation Mode	<ul style="list-style-type: none"> ➤ A1: Both observed and forecast. ➤ A2: Observed only 	<ul style="list-style-type: none"> ➤ B1: Observed and forecast. ➤ B2: Forecast only. 	<ul style="list-style-type: none"> ➤ Observed mode only.

Table 2-1 – Comparison of Phase 1 Studies			
	Study A: Treaty Continues	Study B: Treaty is Terminated	Study C: Continuation of Pre-2024 Conditions
Key Assumptions and Factors	<ul style="list-style-type: none"> ➤ AOPs and Canadian Entitlement provisions continue, but modifications to current procedures would be required to reflect the different Canadian flood control obligations. ➤ Called Upon is considered a real-time operation and is not modeled in the planning studies but instead occurs in power studies and real-time modeling. 	<ul style="list-style-type: none"> ➤ U.S. flood control operation treats Canadian power draft as assured, even though it is not assured with Treaty termination. ➤ Called Upon is considered a real-time operation and is not modeled in the planning studies but instead occurs in power studies and real-time modeling. 	<ul style="list-style-type: none"> ➤ The current FCOP remains in place; however, new arrangements (e.g., an extension or replacement of the current flood control purchase) would be required to implement these study conditions. ➤ This study was conducted to provide a basis for comparison with current operations and to model the potential change in Canadian Entitlement over time.

2.3. OVERVIEW OF STUDY SCENARIOS

2.3.1. SCENARIO DESCRIPTIONS

The three Phase 1 studies were analyzed using 13 different scenarios. The scenarios were designed to test and compare a range of possible situations with varying 1) study time horizons, 2) flood control maximum flow objectives, 3) AOP procedures, and 4) observed mode and forecast mode water supply and inflow forecast procedures. Table 2-2 lists each scenario analyzed as part of the Phase 1 technical studies.

Table 2-2 – Scenarios Analyzed as Part of Phase 1 Technical Studies

Study A - Treaty Continues				
Scenario	Abbrev. Name	Time Horizon	Flood Control Objective	Simulation Mode
Called Upon and AOP procedures	A1O600	2024-25	600 kcfs	Observed
Called Upon and AOP procedures	A1O450	2024-25	450 kcfs	Observed
Called Upon and TSR procedures	A1F600	2024-25	600 kcfs	Forecast
Called Upon and TSR procedures	A1F450	2024-25	450 kcfs	Forecast
AOP procedures	A2O600	2024-25	600 kcfs	Observed

Study B - Treaty is Terminated				
Scenario	Abbrev. Name	Time Horizon	Flood Control Objective	Simulation Mode
Canadian Local Flood Control	B1O600	2024-25	600 kcfs	Observed
Canadian Local Flood Control	B1O450	2024-25	450 kcfs	Observed
Canadian Local Flood Control	B1F600	2024-25	600 kcfs	Forecast
Canadian Local Flood Control	B1F450	2024-25	450 kcfs	Forecast
Canadian Power Draft	B2F600	2024-25	600 kcfs	Forecast
Canadian Power Draft	B2F450	2024-25	450 kcfs	Forecast

Study C - Continuation of Pre-2024 Conditions				
Scenario	Abbrev. Name	Time Horizon	Flood Control Objective	Simulation Mode
Current FCOP and AOP procedures	C2025	2024-25	ICF ⁶	Observed
Current FCOP and AOP procedures	C2045	2044-45	ICF	Observed

The naming convention for the abbreviated names of the different scenarios under Studies A and B is as follows:

- The first character (A or B) identifies which Phase 1 study, as described in section 2.1.
- The second character:

⁶ Initial controlled flow (ICF) is a controlled flow designed to prevent reservoir space from filling too soon, which may result in damaging uncontrolled flows. See Appendix A for more details.

- For A studies identifies the method used to address the Grand Coulee flood control adjustment (1 = upstream power draft used, 2 = Canadian local only used).
- For B studies identifies the Canadian operation used in the scenario (1 = Canadian local flood control only, 2 = Canadian power draft).
- The third character (O or F) designates whether the study was conducted in observed or forecast mode.
- The last three characters refer to the flood control maximum flow objective used (450 or 600 kcfs) at The Dalles.

For example, A1O600 is an A study using upstream power draft for the Grand Coulee flood control adjustment, done in observed mode, and using 600 kcfs as the flood control maximum objective.

In Study C, scenarios were completed for operating year 2024-25 (C2025 or C25) and operating year 2044-45 (C2045 or C45). The purpose of Study C was to provide a basis to compare and investigate the Canadian Entitlement under pre-2024 conditions. The current flood control operations were continued after 2024, there was no Called Upon operation, and forecast mode studies were not simulated.

Under Study B, Treaty is Terminated, it was assumed that there would no longer be coordinated planning between Canada and the U.S. through the FCOP or AOP. In that case, Canadian operations from year to year would be highly uncertain. To address that uncertainty, two scenarios were developed to evaluate certain possible future Canadian operations. For the B1 studies, it was assumed that the Canadian projects were operated principally for local flood protection in British Columbia. In the B2 studies, the projects were operated to a Canadian power draft, which was provided by BC Hydro for study example purposes only. The assumptions used to model the “B1” and “B2” scenarios are:

- **B1 Scenarios: Canadian Local Flood Control.** Canada operated its storage projects for Canadian local flood control needs only; Mica, Duncan, and Arrow reservoirs were held at higher, more stable elevations without deep seasonal power drafts. The Canadian local flood control objectives were based on assumed Canadian flood level criteria.
- **B2 Scenarios: Canadian Power Drafts.** Canada operated its storage projects for Canadian power and local flood control only. Drafting the projects to meet Canadian power needs with annual refill provided corollary flood control and power benefits downstream in the U.S. The power drafts developed for the Phase 1 studies were treated as an assured operation, although in reality there would be no assurance that the projects could or would be operated in this manner if the Treaty was terminated.

2.3.2. SCENARIO ASSUMPTIONS AND VARIATIONS

2.3.2.1. Study Horizons

All studies were conducted for the 2024-25 operating year. In addition, Study C modeled the 2044-45 operating year to estimate the decline in the computed downstream power benefits.

2.3.2.2. U.S. Flood Control Objective

In studies that reflected a shift to a Called Upon flood control operation (Studies A and B), a maximum flood control flow objective for the Lower Columbia as measured at The Dalles, Oregon, was the primary factor directing the flood control operation of the entire Columbia River system once Called Upon was activated. The Treaty does not provide detailed procedures for Called Upon, and there are differences between the Entities with regard to interpretation of Called Upon rights and obligations, including flood control objectives (i.e., 450 or 600 kcfs). Thus, without prejudice, two different flow objectives were simulated to provide information regarding a potential range of future operations. According to the current FCOP, flooding begins around 450 kcfs in the lower Columbia, while major damages begin around 600 kcfs. Scenarios with maximum flood control objectives of 600 kcfs and 450 kcfs at The Dalles were conducted in Studies A and B.

While Studies A and B used a specified maximum flow objective at The Dalles, Study C was based on the current FCOP, which calculates an ICF at The Dalles based on changing forecasts of peak flow, residual volume, and upstream storage.

2.3.2.3. Grand Coulee Flood Control Adjustment

The existing AOP procedures were used in Study C, including an adjustment to Grand Coulee's flood control curve based on only the upstream flood control draft. In actual operations, Grand Coulee's flood control curve is adjusted for the additional power draft at upstream reservoirs. The difference is significant for the operation of Grand Coulee but has only a small impact on Canadian storage operations.

For Study A, two scenarios were completed reflecting a much smaller Canadian local flood control draft. In Study A1, the existing AOP procedures were modified to account for the power draft at Canadian projects. In Study A2, the Step I Joint Optimum study was repeated without the Grand Coulee adjustment for Canadian power draft. Other procedures for conducting AOP studies post-2024 are possible but were not explored in the Phase 1 studies due to time limitations.

Study B, with two scenarios of Canadian storage operations, used the total draft of Canadian storage, whether for power or flood control, even though those drafts are not assured, to adjust Grand Coulee's flood control curve.

2.3.2.4. Simulation Mode

Flood control regulation studies can be simulated in observed mode and forecast mode (as described below). Application of these two modes comes into play in two modeling periods: 1) during the drawdown period in order to provide reservoir space for the anticipated spring runoff and 2) during the reservoir refill period to reduce runoff peaks and provide for assured refill of the reservoirs.

Observed mode. In observed mode, reservoir regulation decisions are assumed to be made with “perfect foresight” of all future runoff volumes and inflows across the entire Columbia Basin. Modelers draft and refill the system with complete knowledge of the volume and shape of the inflows during each period. Studies conducted in observed mode do not consider the uncertainty inherent in actual operations and will therefore tend to underestimate the storage required for flood control (or alternatively will provide less-effective flood control for the available storage space). For AOP and other planning studies, the Entities have always used observed mode to optimize the critical period operation and determine flood control and refill curves.

Forecast mode. In forecast mode, modelers use historical water supply forecasts and associated errors to determine the drawdown of the reservoirs, thus incorporating runoff volume uncertainty and error into the modeling of the system. During refill, the system modelers make reservoir regulation decisions with a limited forward-looking time window to emulate the uncertainty of streamflow forecasting. Forecast mode is generally used for short-term planning, in actual operation such as the TSR, or whenever the uncertainty associated with runoff forecasting must be considered.

For the Phase 1 studies, all AOP studies were performed in observed mode, just as is done in actual Treaty planning. The various scenarios were generally done in both observed and forecast mode; forecast mode is more appropriate when trying to reflect how Called Upon and Canadian Flex would actually be implemented.

2.4. CRITICAL CONSIDERATIONS NOT INCLUDED IN THE PHASE 1 STUDIES

Other River Uses. Analysis of the benefits and impacts associated with the alternative scenarios described in the Phase 1 studies was strictly limited to the two primary purposes authorized under the Treaty—power generation and flood control. For these preliminary studies, there was no incorporation of other operating purposes and benefits related to the Columbia River system, including but not limited to fisheries, wildlife habitat, recreation, irrigation, water supply, water quality, and navigation.

Global Climate Change. The potential effect of global climate change on the benefits and operations of the Columbia River system in Canada and the U.S. is an important regional consideration. The potential impacts of climate change on the future timing and volume of precipitation in the Columbia River Basin and possible impacts on reservoir system operations were not incorporated into the Phase 1 studies.

Economic Costs and Benefits. The Phase 1 studies utilized a monthly time-step model to estimate the potential power impact. Since at least a daily time-step model is required to estimate impacts on both firm energy and capacity, the Phase 1 studies did not include any calculation of the economic benefits or costs of scenarios for hydropower. Potential future generation quantities under the scenarios were estimated, but no dollar values were placed on that generation. Likewise, flood control operations were described in terms of effects on reservoir storage, required Canadian storage for Called Upon, and peak flows at The Dalles and other locations in the system, but these Phase 1 studies did not calculate flood damages prevented or

economic losses (opportunity costs) associated with flood control storage operation under the scenarios.

2.5. RISKS AND LIMITATIONS OF STUDIES

While careful attention and expertise went into modeling and projecting what the future may hold in 2024-25 and as far out as 2044-45, there are always risks and limitations to those projections. These risks and limitations apply to all aspects of defining the future, including models, scenarios, and assumptions. The results of the Phase 1 studies contain useful preliminary information; however, it is important to recognize that caution should be used in interpreting the data. Areas where risks, uncertainty and limitations can be found include but are not limited to:

- **Methodologies and Requirements of Called Upon:** Since the actual implementation of Called Upon post-2024 was not expected to be defined through this effort, the modeling of Called Upon in the Phase 1 studies was a combination of new approaches and current methodologies. There may be differences between the Entities on interpretation and implementation requirements under the Treaty, and it is likely that Called Upon implementation will be different from what was defined in the Phase 1 studies.
- **Power Load and Resource Assumptions:** Load and resource assumptions play a key role in all aspects of Treaty planning and modeling as well as in assessing the capabilities of the U.S. system if the Treaty is terminated. Projections of loads and resources for the Phase 1 studies included assumptions and estimates based on information available at the time of development. As with any forecast, the numbers have an associated risk and uncertainty around them.
- **Modeling and Procedural Assumptions:** The Phase 1 studies adopted current modeling techniques and methodologies where possible and feasible. Some modeling procedures evolved over time as understanding of the studies increased, such that not all procedures were consistent across the studies. Places where it is known that procedures impacted the results are identified throughout the report. Modeling and procedures will need to be evaluated and modified for any future studies.
- **Future Canadian Operating Scenarios:** Only two scenarios were modeled regarding possible Canadian operations under the Treaty is Terminated assumption. It is recognized that this does not capture the full range of possibilities, or even the most likely possibility.

3. METHODS AND RESULTS

3.1. INTRODUCTION

This section 3 summarizes the procedures used and the results obtained from the Phase 1 studies. It describes potential future conditions related to flood control and hydropower after 2024 under the three alternative studies: Study A, Treaty Continues; Study B, Treaty is Terminated; and, Study C, Continuation of Pre-2024 Conditions. The focus is on comparing and contrasting the various scenarios.

Section 3 is structured as follows:

Section 3.2 summarizes how power loads and resources were developed and how the assumptions influenced the outcomes of the power studies and estimates of Canadian Entitlement after 2024 in the Phase 1 studies.

Section 3.3 summarizes the long-term planning results for the AOPs, DDPBs, and Canadian Entitlement under Studies A and C.

Section 3.4 summarizes how Called Upon flood control was modeled in the short- and long-term studies and the resulting Called Upon operations and impacts to the Canadian and U.S. systems.

Section 3.5 compares and contrasts the relative impacts of Called Upon in the various scenarios, both with and without the Treaty, on reservoir storage and elevations in both Canada and the U.S., outflows from Arrow and Duncan, and power generation.

Section 3.6 summarizes the 70-year generation differences between scenarios.

3.2. POWER LOADS AND RESOURCES

3.2.1. INTRODUCTION

Electrical loads and resources are an important driver in the development of hydropower operating plans. The net result of the determination of the loads and resources is the Residual Hydro Load⁷ for the coordinated hydropower system to meet. The amount and shape (month to month) of that load has a direct impact on the development of Canadian and U.S. storage operating criteria, actual storage operations, and the calculation of the Canadian Entitlement.

Loads are defined as the amount of electrical power required to be delivered to a given point to meet demand. Resources are generation installations that are needed to meet the forecast loads and include a variety of energy sources such as hydro, thermal (e.g., coal, natural gas, nuclear), and renewables (e.g., wind, solar).

⁷ Residual Hydro Load is the net result of PNWA loads, thermal installations, and other resources; a residual load for the coordinated hydropower system to meet.

For the purposes of the Phase 1 studies, forecast loads and resources were developed for the U.S. Pacific Northwest Area (PNWA)⁸ as defined in the Treaty. Two sets of loads and resources were forecast. The first was developed for the period August 2024 through July 2025 and was applied to all three Phase 1 studies (Studies A, B, and C). The second set of loads and resources, developed for the period August 2044 through July 2045, was used only in Study C to forecast changes to the Canadian Entitlement over time. Both sets included the effect of energy conservation.

Developing a set of loads and resources for the Phase 1 studies involved numerous steps and assumptions because of the complexity of the power system and the uncertainty in forecasting the future. Market forces, new regulations, and political decisions will shape the future physical limits, transmission constraints, and environmental requirements. This section summarizes the Phase 1 study methodology used to develop the PNWA loads and resources, the forecast results, and risks associated with these forecasts.

3.2.2. PROCEDURES AND ASSUMPTIONS

Procedures used for determining the loads and resources for 2024-25 and 2044-45 are similar to those used in the most recent studies for the Assured Operating Plan, i.e., AOP 2013-14 (AOP14).

Loads for AOP studies are the PNWA firm load, plus the estimated flow of power at points of interconnection with adjacent areas (imports and exports), minus miscellaneous resources. Miscellaneous resources include many small PNWA hydropower projects, wind, and other non-thermal resources. Resources include the Canadian Treaty storage, coordinated Canadian facilities, the Base System⁹ hydropower projects, and other coordinated hydropower projects and coordinated thermal installations. Maintenance and transmission losses and peak reserves are subtracted from the resources.

The loads and resources are based on the median forecast from BPA's January 2008 draft of the 2007 Pacific Northwest Loads and Resources Study (White Book).¹⁰ The White Book has been used for most AOP load and resource data since 1994 and is an accepted regional standard for BPA contract and ratemaking purposes. Data from the White Book included in the Phase 1 studies are energy and capacity forecasts for:

- PNWA regional load
- Firm exports and imports
- Thermal generating installations
- Miscellaneous generation including wind, small hydro and other renewables

⁸ The Pacific Northwest Area is Oregon, Washington, Montana west of the continental divide, and Idaho, except areas served in September 1964 by the California-Oregon Power Company (now part of PacifiCorp) and Utah Power and Light Company (now Rocky Mountain Power).

⁹ The 24 projects listed in the Treaty, plus post-1961 projects added on the mainstem of the Columbia.

¹⁰ Study #50, which is the same as the 2007 BPA White Book published in March 2008 (available at [www:bpa.gov](http://www.bpa.gov)) except for minor updates that were included in the published document.

A complicating issue in forecasting the loads and resources is that the U.S. hydropower system has fisheries requirements that are not included in AOP studies. As a result, the PNWA hydropower system in the AOP has about 1000 aMW more energy capability than it does in actual operations, where fisheries requirements must be met. With the Treaty requirement for balanced loads and resources, the AOP studies must necessarily serve different loads and/or include different resources from those shown in the White Book to balance this inconsistency between Treaty planning and actual operations. For the AOP studies, some of the White Book load and resource data is therefore adjusted to meet Treaty requirements. The most significant include:

- Canadian Entitlement exports are adjusted to the expected results for the Phase 1 studies.
- Seasonal exchanges (imports and exports that balance on an annual basis) are added to account for the difference in annual shape between the hydropower generation from an AOP study and the generation from actual U.S. operations that are affected by fishery requirements.
- Wind and other renewable resource forecasts from the White Book are increased as needed to meet renewable portfolio standards for Oregon, Washington, and Montana.
- Thermal installations¹¹ are adjusted to balance loads and resources.
- Hydro and thermal maintenance, transmission losses, and capacity reserves are adjusted to reflect the difference between AOP and White Book loads and resources.

An iterative process is required to determine the Residual Hydro Load and the generic thermal installation,¹² which is sized to balance the loads and resources. A hydroregulation simulation is conducted to determine the critical period¹³ and the Firm Energy Load Carrying Capability (FELCC)¹⁴ of the hydropower system. In this power study the reservoir operation is adjusted to maximize its ability to meet the Residual Hydro Load. If the FELCC is less than the Residual Hydro Load, imports are added or the generic thermal installation is increased to balance the loads and resources. Conversely, if the FELCC is greater than the Residual Hydro Load, exports are added or the generic thermal installation is reduced to balance loads and resources. This iterative procedure adjusts the generic thermal installation until the Residual Hydro Load equals the system FELCC determined by the Step I critical period studies.

¹¹ Thermal resources include Columbia Generating Station (CGS), a nuclear generating facility located in the State of Washington.

¹² Generic thermal installations represent all individual existing and potential thermal projects, with the exception of Columbia Generating Station

¹³ Critical period is the historical streamflow period over which the water available from reservoir releases plus the natural streamflow is capable of producing the least amount of hydroelectric power in meeting system load requirements.

¹⁴ FELCC is the critical period energy capability shaped the same as the firm load, except any surpluses or deficits are shaped to match desired load or resource adjustments.

3.2.3. STUDY C LOADS AND RESOURCES

The calculation of Study C loads for the 2024-25 and 2044-45 operating years is shown in Table 3-1. Data from AOP14 is provided as a comparison.

Table 3-1 – Forecast Loads for AOP14, C2024-25, and C2044-45

U.S. System Loads (aMW)	AOP14	AOP C2025	AOPC2025 - AOP14	AOP C2045	AOPC2045 - AOPC2025
PNWA Firm Load	22803	26280	3477	34700	8420
Total Exports ¹⁾	1605	1434	-171	1630	196
Total Imports ²⁾	-1177	-1213	-37	-2099	-886
<u>Miscellaneous Resources</u>	<u>-2841</u>	<u>-5404</u>	<u>-2563</u>	<u>-6454</u>	<u>-1050</u>
AOP Load	20390	21097	707	27778	6681

¹⁾ Exports are the sum of the firm contracts with California, plus British Columbia, plus seasonal exchanges.

²⁾ Imports are the sum of forecast firm contracts, imports from British Columbia and California needed for White Book firm energy deficits, and seasonal exchanges.

The 2024-25 average annual PNWA firm load was up 3,477 MW from 2013-14 (the last completed AOP), which is a 1.5 percent average annual load growth from the White Book base case operating year (2006-07). The forecast firm loads for the 20 years beyond 2024-25 increased at an annual rate of 1.4 percent per year, for a total increase of 32 percent or 8,420 MW. There is little change in the forecast amount of exports in comparing 2013-14, 2024-25, and 2044-45 because the seasonal load shape did not change across the studies. Imports increased from 2024-25 to 2044-45 to help meet load growth. Miscellaneous resources increased by 90 percent from 2013-14 to 2024-25 and by 19 percent from 2023-24 to 2044-45.

Study C resources are summarized in Table 3-2. The resources were set equal to the net system load by adjusting the amount of thermal installations and imports and exports. Data from AOP14 is provided as a comparison.

Table 3-2 – Resources for AOPs for 2013-14, 2024-25, 2044-45

U.S. System Resources (aMW)	AOP14	AOP C2025	C2025 – AOP14	AOP C2045	C2045 – C2025
Coordinated Hydro Resources ¹⁾	11057	11025	-32	11025	0
Thermal Installations	10031	10853	823	17785	6932
<u>Maint, trans. losses, & resrv. ²⁾</u>	<u>-697</u>	<u>-781</u>	<u>-84</u>	<u>-1032</u>	<u>-241</u>
AOP Resources	20390	21097	707	27778	6681

¹⁾ Hydro resources based on 1928-29 flows.

²⁾ Maintenance, transmission losses, and reserves are shown as negative, so increases are shown in the difference column as a larger negative value.

Hydropower capability for Study C was the same for 2024-25 and 2044-45, because there were no changes in the assumptions for installed capacity, irrigation depletions, non-power constraints, and Residual Hydro Load shape. Transmission losses and peak reserves are a fixed percentage of the energy and capacity loads, so they increase over time.

Thermal installations included Columbia Generating Station (878 aMW) and the generic thermal installation sized as needed to balance the loads and resources, as described in section 3.2.2. As


a result of all the other assumed load and resource changes, the total thermal installations for Study C were up 8.2 percent from 2013-14 to 2024-25, and up 64 percent from 2024-25 to 2044-45. For the period from 2013-14 to 2023-24, the PNWA firm load increase (+3477) was met primarily by the addition of wind and renewable resources (+2563). From 2024-25 to 2044-45, the firm load increase (+8420) was met primarily by thermal resources (+6932) and wind and renewables (+1050).

The generic renewable resources (not currently planned or built) added are those required to meet the Montana, Oregon, and Washington Renewable Portfolio Standards (RPS) implemented in 2006 and 2007. RPSs are state policies that require electricity providers to obtain a minimum percentage of their power from renewable energy resources by a certain date. With increased focus on renewable energy the assumed percentage of renewable may increase in the future. In particular, the large increase in thermal resources from 2024-25 to 2044-45 may not be consistent with initiatives that are currently being investigated by government entities such as the Western Climate Initiative.¹⁵

The coordinated hydro resources (i.e., resources to meet the Residual Hydro Load) amount was not significantly different for AOPs for operating years 2013-14, 2024-25, and 2044-45 because the seasonal exchanges were designed to reflect the difference between AOP and real-world hydro capability. The portions of AOP system load met by coordinated hydro, imports, miscellaneous resources, and thermal installations are shown in Figure 3-1.

¹⁵ The Western Climate Initiative is a collaboration of independent jurisdictions working together to identify, evaluate, and implement policies to assess and address climate change at a regional level. This comprehensive effort seeks to reduce greenhouse gas pollution, spur growth in new green technologies, help build a strong clean-energy economy, and reduce dependence on foreign oil (www.westernclimateinitiative.org)

Figure 3-1 – 2024-25 Resources for Study C



3.2.4. LOAD/RESOURCE DIFFERENCES BETWEEN STUDIES A, B, AND C

The hydro system operation in Studies A, B, and C varied depending on whether the Canadian storage was operated for joint optimum power (Treaty Continues) or power in Canada only (Treaty is Terminated). There are also differences due to the flood control operations in each study. In response to changes in the hydro system operation the exports, imports, and thermal installations also changed between Studies A, B, and C. As described in section 3.2.2, the generic thermal installation was adjusted so that the Residual Hydro Load was equal to the FELCC. The different values for exports, imports, and thermal installations shown in Table 3-3 reflect the differences in loads and hydropower capability between the studies.

Table 3-3 – Changes to Exports, Imports, Hydro Capability, & Thermal Resources between Studies A, B, and C

(aMW)	Study C	Study A1	Study B1	Study B2
Exports	1434	1434	1005	1005
Imports	-1213	-1213	-784	-784
Firm Hydro Capability	11025	11031	9411	11094
Thermal Installations	10853	10846	12466	10784


Study A and Study C used identical loads and resources except for small changes in thermal resources needed to respond to changes in hydropower capability. This confirmed the

assumption that with the Treaty, changes to flood control post-2024 will not significantly affect the firm load that the system can support. Under Study B (Treaty is Terminated), the amount of firm load that the system can support is dependent on how Canada decides to operate (i.e., scenario B1, B2, or other).

3.2.5. RISK AND UNCERTAINTY IN FORECASTS OF LOADS AND RESOURCES

The process of forecasting loads and resources for the sixth succeeding operating year in AOP studies is highly uncertain. The forecasts are a function of many interrelated factors that are affected by the overall economy, power markets, political policy and laws, and social trends. Extending these forecasts to 2024-25 and 2044-45 operating years is even more speculative. Forecast errors have had a significant impact on the Canadian Entitlement calculation. Figure 3-2 compares historical PNWA firm load used in past AOP studies with actual regional firm loads. The load forecast error is as much as 20 percent in some years. Hydro and thermal resources used in AOP studies are also provided in Figure 3-2 (in the legend, CP means Critical Period).

Figure 3-2 – Comparison of Actual PNWA Firm Loads to AOP Loads and Resources



Other factors that were not studied or explored in the Phase 1 studies that could potentially have significant impact on loads and resources, and consequently impact the Canadian Entitlement, are:

- **Future resource mix within the PNWA:** The allocation between thermal installations and renewable resources in the future is highly uncertain, as is the need for reserves for variable output resources such as renewables.
- **Imports and exports:** Building for export or buying imports is dependent on the relative costs of new resources in different regions, transmission availability, and government regulations.
- **Type of thermal installations and maintenance schedule:** The type of thermal installation (e.g., coal vs. combustion turbine) can affect the determination of the critical period due to the different plant factors (ratio of average to peak generation). The assumed maintenance schedule has a large impact on the Residual Hydro Load.
- **Future non-power constraints:** Changes in non-power constraints for non-Base System hydropower projects can result in changes to loads and resources in AOP studies. Changes in non-power constraints for Base System hydropower projects can decrease the actual power benefits at U.S. projects in Study B, but not the Canadian Entitlement in Studies A and C.
- **Methods for transition from an energy-constrained system to a peak-constrained system:** As the PNWA loads increase, and variable output resources (e.g., wind) are added, it is expected that the power system will become peak or capacity deficit. The current procedures for determining peak load-resource balance, which use instantaneous hydro peak capability, 11 percent peak load reserves, and full reservoir draft during the critical period, may not be adequate and thus require development of new procedures. This could result in a change in Canadian storage operating criteria and a change in the calculation of the Canadian Entitlement.

3.3. ASSURED OPERATING PLAN AND DETERMINATION OF DOWNSTREAM POWER BENEFITS FOR STUDIES A AND C

3.3.1. INTRODUCTION

This section presents the forecast of post-2024 AOPs and Canadian Entitlement for the Phase 1 scenarios Treaty Continues (Study A) and Continuation of Pre-2024 Conditions (Study C). Some information from Study B, Treaty is Terminated, with no AOP and no Canadian Entitlement, is reported for comparison. The primary topics addressed are:

- Procedures and assumptions for development and modeling of the AOP/DDPB post-2024
- Flood control rule curves for AOP studies, and the effect of different assumptions on the AOP results
- AOP operating criteria and results of 70-year hydroregulation studies
- Canadian Entitlement results for the 2024-25 and 2044-45 operating years
- Risk and uncertainty for forecasting future AOP/DDPB study results

The Treaty requires the Entities to agree annually on an AOP and the resulting downstream power benefits for the sixth succeeding operating year. Except for occasional daily flood control operations, the AOP is the default plan for the operation of Canadian storage unless the Entities otherwise agree. Typically the Entities do agree in the Detailed Operating Plan, and other agreements, to allow some changes from the AOP. But all such agreements are based on negotiations that measure incremental benefits from the (default) AOP operation. AOPs are developed to provide flood control and power benefits and do not include many of the requirements for fish and other non-power objectives.

The AOP is defined in the Treaty as Step I of the AOP/DDPB process. It is based on hydroregulation studies of the operation of Canadian storage and other projects in Canada,¹⁶ the U.S. Base System, and the coordinated hydropower projects and other generating resources in the U.S. PNWA. The AOP study process develops operating criteria for Canadian and U.S. reservoirs and simulates the operation over the 70-year historical streamflow record years from August 1928 to July 1998.¹⁷

The DDPB procedures calculate the Canadian Entitlement. The DDPB is based on two hydroregulation studies that measure power benefits in the U.S. Base System with and without Canadian Treaty storage. The two studies are referred to in the Treaty as Step II and Step III of the DDPB process. The Canadian Entitlement is one-half the increase in downstream U.S. power benefits between the Steps II and III studies. Once calculated by the DDPB studies, the Canadian Entitlement cannot be changed and must be delivered regardless of actual loads, resources, streamflows, or other factors affecting the actual benefits.

The Treaty has detailed requirements for AOP/DDPB studies, which are explained in Appendix A. The loads and resources that are input to the AOP studies are discussed in section 3.2.

3.3.2. PROCEDURES AND ASSUMPTIONS

The current procedures and assumptions for conducting AOP studies and Canadian Entitlement calculations are described in Appendix A and were used without significant change for Studies A and C. The only exception is the change to Canadian and U.S. flood control rule curves, which were modified in Study A to reflect the post-2024 changes to flood control.

Flood control upper rule curves (URCs) define the maximum end-of-month elevation at each reservoir during the evacuation and refill periods. The URCs are derived from system flood control studies and are used as reservoir upper limits for power operations in AOP regulation studies. Adapting URCs for post-2024 flood control provisions and examining the effects on Canadian storage and Grand Coulee operation were important procedural questions explored in the Phase 1 studies.

¹⁶ Other Canadian projects: Revelstoke, Upper Bonnington, Lower Bonnington, South Slokan, Brilliant, Seven Mile, Waneta, Corra Linn, and Kootenay Canal.

¹⁷ In accordance with the Treaty, only the 30-year streamflow record from August 1928 to July 1958 is used to develop AOP operating criteria and measure the downstream power benefits.

There are two significant changes to the URCs used in the AOP/DDPB studies for Study A that distinguish Study A from Study C, which uses current methodology. These two changes—use of Canadian Local URCs for Mica, Arrow, and Duncan, and incorporation of the Grand Coulee adjustment—are described in the following sections. The Phase 1 studies assumed that Called Upon flood control storage operations are not included in the AOP but instead are implemented as an operational decision during the operating year.


3.3.2.1. Use of Canadian Local Upper Rule Curves in AOP and DDPB Studies

Study C, Continuation of Pre-2024 Conditions, used URCs based on the procedures described in the FCOP. In Study A, the Canadian flood control URCs were based on Canadian local flood control needs only. The contrast between the Study A and Study C URCs is shown in the 70-year average composite Canadian flood control rule curves on Figure 3-3. The average local Canadian flood control draft in Study A is so small that it is not noticeable in the graph. The URCs used in AOP14 are also shown on the graph and are identical to those in Study C.

AOP/DDPB procedures use the same flood control URCs for AOP (Step I) and DDPB (Steps II and III) studies.¹⁸ This approach was applied to Study A and Study C, where all three Steps were conducted. However, future procedures could be done differently. For example, different flood control URCs could be used in each step because the numbers of reservoirs and storage volumes are significantly different in the Steps I, II, and III systems. Due to limited time and resources for the Phase 1 studies, alternative procedures for the Step II and Step III flood control URCs were not explored.

¹⁸ The URCs developed for Step I are used in Steps II and III. However, some of the Step II and III URCs look different because of adjustments for the different storage levels between the Steps I, II, and III systems.

Figure 3-3 – Comparison of Composite Canadian URCs, 70-yr Avg




3.3.2.2. Grand Coulee Upper Rule Curve Adjustment in AOP and DDPB Studies

A procedural change from current AOPs made in Study A was to include the adjustment to raise Grand Coulee’s flood control rule curve as a result of additional draft for power below URCs at upstream Canadian reservoirs. This adjustment for upstream power drafts has been included in actual operations since the early 1970s but is not included in AOPs. Incorporating the adjustment in AOPs would require iterative studies, and although the higher Grand Coulee flood control rule curves result in an increase in U.S. power generation, the adjustment has had little impact on the operation of Canadian storage in current AOP's.

Study C reflects how flood control is implemented in current AOP/DDPB modeling, where the Grand Coulee adjustment is based only on current flood control draft at upstream reservoirs. The additional draft for power was not included. In Study A, the difference between the Canadian local URC and the additional AOP power draft at Canadian projects is much larger and therefore was expected to have some impact on Canadian storage operations. To evaluate these different approaches to the Grand Coulee adjustment under post-2024 conditions, two scenarios, A1 and A2, were completed. In A1, the adjustment was based on the upstream Canadian power draft, whereas in A2 the adjustment was based on the (much smaller) Canadian local flood control draft. Comparison of scenarios A1 and A2 provides a way to assess the impacts of using the power draft adjustment to Grand Coulee flood control rule curves. Only the AOP Step I was conducted for A2; the DDPB Step II and III studies were not conducted due to time and resource constraints.

The Grand Coulee URCs for Study C and the A1 and A2 scenarios are shown in Figure 3-4, with AOP14 included for comparison. The use of Grand Coulee upstream power draft adjustment in A1 resulted in higher Grand Coulee URCs in comparison to Study C and those used in past AOPs. Study C and scenario A2 both use the Canadian URCs to calculate Grand Coulee’s URCs; Study C used the FCOP for Canadian URCs, and A2 used the Canadian local flood control curves. Since the Canadian flood control draft in A2 was very small (local flood control needs only), the Grand Coulee URCs were lower than those in previous studies.

Figure 3-4 – Grand Coulee 70-Year Average URC



3.3.3. RESULTS OF AOP STUDIES

The AOP study results are the Canadian and U.S. operating criteria and the simulated operation of Canadian and U.S. reservoirs over the 70 historical water years. In general, the AOP study results and operating criteria for Studies A and C were quite close, as these studies used the same PNWA load shape from the same BPA White Book, and the same resources, refill parameters, 2000 modified flow, operating constraints, and so on. Furthermore, seasonal exchanges were used to produce similar Residual Hydro Loads. The key differences among these studies were the Canadian flood control curves and the amount of Canadian draft space used for the Grand Coulee flood control adjustments. Even though the 70-year annual average generation, regulated flows, and storages were very close, there are noticeable differences among the year-to-year monthly regulated flows and the monthly flow shapes.

3.3.3.1. AOP Operating Criteria


The first process in developing AOP operating criteria is the iterative process of balancing loads and resources in the critical period that was described in section 3.2.2. The storage contents during the critical period become critical rule curves that guide proportional¹⁹ draft of the coordinated reservoir system during future low flow sequences. Typically, proportional draft to meet firm loads occurs about one-quarter to one-third of the time.

There was no significant difference in FELCC among the A1, A2, and C scenarios. For scenarios A1 and C, this is because the Canadian local flood control rule curves were much higher than (were significantly above) the critical period reservoir contents, so the different flood control assumptions did not control Canadian storage operations. In these low flow years, the operation was driven by power needs. In scenario A2, the Grand Coulee flood control adjustment resulted in lower Grand Coulee flood control curves, which in turn caused its critical rule curves to be lower and also resulted in changes to the critical rule curves at other projects. This resulted in a slight decrease in the FELCC.

The second process is refill studies, which determine ORCs that guide reservoir operations for optimum production of secondary energy in the U.S. while maintaining a 95 percent confidence of reservoir refill. Secondary energy, also referred to as non-firm energy, is power that can be generated in years that are wetter than those experienced in the critical period. The refill criteria ensure capability to meet future firm loads. Typically, ORCs guide reservoir operations in about two-thirds to three-fourths of the water conditions. Figure 3-5 shows the 70-year average total Canadian ORC (also called Energy Content Curve or ECC) for scenarios A1 and C. The result of this process is referred to as the U.S. Optimum study.

¹⁹ Each reservoir has a critical rule curve for each year in the critical period. When additional draft is needed to produce the hydro FELCC of the U.S. system, the Canadian Treaty Storage and all reservoirs in the U.S. system are drafted proportionally between their respective Operating Rule Curves and their first Critical Rule Curves. If additional storage is required after system reservoirs reach their first Critical Rule Curves, the proportional draft is made between their first and second Critical Rule Curves, their second and third Critical Rule Curves, and so on.

Figure 3-5 – Total Canadian ORC (70-year average)




The Composite Canadian Operating Rule Curves were essentially unchanged among scenarios A1, A2, and C except during low water years, when the ORCs were slightly higher in January due to Canadian storage not being constrained by U.S. flood control. The resulting effect on winter flows is discussed in section 3.3.4.2.

The third and last process is the Mica/Arrow Re-operation, which produces the Joint Optimum study. The Mica/Arrow Re-operation optimizes Canadian generation such that the joint Canadian and U.S. hydropower system capability is increased, sometimes at the expense of de-optimizing the U.S. system generation. The Mica/Arrow operating criteria do not always produce the same net flow at the border as the U.S. Optimum. The Joint Optimum operation flows at the border vary from the U.S. Optimum in about 36 percent of the months over the 70 modeled water years.

The results of the Mica/Arrow Re-operation for Studies A and C are similar to AOP14 and prior AOPs. Figure 3-6 compares the results of the U.S. Optimum operation with the Joint Optimum operation. Figure 3-6 shows slightly higher Canadian storage in January and February (due to added maximum outflow limits) for median levels, and lower storage contents in June and July in the Joint Optimum operation.

Figure 3-6 – 70-Year AOPA1 Total Canadian Storage



3.3.3.2. 70-Year Simulation Studies Using AOP Operating Criteria

The final AOP Joint Optimum hydroregulation study simulates the operation of Canadian storage over the 70 historical water years using AOP operating criteria. Figure 3-7 shows the composite 70-year average Canadian storage contents for scenarios A1, A2, and C. AOP14 values are shown for comparison. In general, AOP14 and Study C are very similar except that Study C resulted in slightly deeper draft during August through January. Scenarios A1 and A2 are almost the same as each other. There were differences in average Canadian storage draft between Study C and scenarios A1 and A2, due mainly to changes in the ORC. The ORC differences do not appear to be due to the changes in critical rule curves but instead due to changes in the flood control curves. These ORC differences probably could have been eliminated had the full ORC optimization studies been completed.

Figure 3-7 – 70-year Average Composite Canadian Storage




Figure 3-8 shows a comparison of the net Arrow plus Duncan 70-year average regulated outflows between the four scenarios. The changes are similar to and reflect the difference in storage operations shown in Figure 3-7. AOP14 and Study C are almost the same. Scenarios A1 and A2 are almost the same as each other. Scenario A1 compared to Study C shows lower outflows in December-January and higher in May-July. These differences were caused by changes to the flood control rule curves and because no refill study was performed to adjust the ORCs. Refill studies are typically performed to optimize the ORCs during the refill period.

Figure 3-8 – Arrow plus Duncan 70-Year Average Outflows





Figure 3-9 is an example of the volatility surrounding these 70-year averages.

Figure 3-9 – Arrow plus Duncan Outflows



The Canadian and U.S. generation values from AOP14 and the A1, A2, and C scenarios are shown in Table 3-4. The reduction in generation between AOP14 and Study C is due mainly to a decrease in Hungry Horse storage, updated flood control curves, and updated generation capacity. The changes between Study C and scenarios A1 and A2 are in general very small. Scenario A1 shows slightly more Canadian generation than Study C. Scenario A2 shows slightly less U.S. generation than scenario A1.

Table 3-4 – AOP Joint Optimum Results (aMW)

70-year Avg.	AOP 14	Study C	Study A1	Study A2	Study C minus AOP14	Study A1 minus Study C	Study A2 minus Study A1
Canadian Generation	3287	3275	3281	3281	-12	6	0
U.S. System Generation	15402	15346	15340	15339	-56	-6	-1
U.S. Federal Generation	9476	9434	9433	9433	-42	-1	0

3.3.4. RESULTS OF DDPB STUDIES AND CALCULATION OF CANADIAN ENTITLEMENT

The DDPB is based on two hydroregulation studies that measure power benefits in the U.S. Base System with and without Canadian Treaty storage. The two studies are referred to in the Treaty as Step II and Step III of the DDPB process.

When the Treaty was negotiated in the 1960s, negotiators recognized that power benefits created by reservoir storage would diminish over time as growth in regional power demand is met by thermal installations. The procedures used in the calculation of the DDPB reflect these principles; an explanation of why this occurs is provided in the following paragraph.

The operation of Canadian storage increases the amount of U.S. Base System usable energy.^{20,21} Thermal installations are sized to meet load assuming only firm hydro energy is available, so any secondary hydro energy can be used to displace thermal generation. A higher Thermal Displacement Market (TDM)²² increases the amount of secondary hydro energy that is usable. This is important because the Treaty assumes that any secondary hydro energy that can be used for thermal displacement is just as valuable as firm hydro energy. In general, an increase in the TDM results in a disproportionate increase of usable secondary energy in the Step III system in

²⁰ The Treaty defines usable energy as the hydro energy in the critical period (also called firm energy), plus secondary hydro energy (also called non-firm energy) that can be used to displace thermal installations, and 40% of the remaining secondary energy.

²¹ Canadian storage increases usable energy by augmenting low inflows, reducing spill, raising U.S. reservoir elevations, and storing unusable secondary energy for release when it is usable.

²² In accordance with the 1988 Entity agreements on Principles and Procedures, Step I thermal installations, as the highest-cost marginal resource, are presumed to support all PNWA exports (system sales), with a few exceptions. So the Thermal Displacement Market is essentially the thermal installations that are needed to meet load in the PNWA minus the non-displaceable minimum thermal generation.

comparison to the Step II system. Consequently, the Entitlement energy, which is one-half of the difference between the Step II usable energy and the Step III usable energy, will decline as the TDM increases. As a result, the TDM is the primary factor affecting the Entitlement energy until secondary energy is fully utilized for displacing thermal in Steps II and III. When this occurs, the minimum Entitlement energy is reached, as discussed in section 3.3.5.2.

3.3.4.1. Calculation of Canadian Entitlement for 2024-25

The determination of the Thermal Displacement Market for 2024-25 is shown in Table 3-5.

Table 3-5 – Comparison of Thermal Displacement Market, in average annual MW

	Thermal Displacement Market	AOP14	AOPC25	AOPA1	AOPC25-AOP14	AOPA1-AOPC25
1	Coordinated Thermal Installations	10031	10853	10846	822	-7
2	Minimum Thermal Generation	226	248	248	22	0
3	System Sales	227	91	91	-136	0
4	Thermal Displacement Market ^{1/}	9578	10514	10507	936	-7
Notes: ^{1/} TDM = Coordinated Thermal - Min Thermal - System Sales						

Table 3-6 provides the computation of Canadian Entitlement for Studies C and A for the Joint Optimum Generation in Canada and the U.S. AOP14 is shown for comparison.

Table 3-6 – Canadian Entitlement for Studies A and C and Comparison with AOP14

1	Entitlement Capacity	AOP14	AOPC25	AOPA1	AOPC25-AOP14	AOPA1-AOPC25
a)	Step II CP Average Energy	8935	8929	8929	-6	0
b)	Step III CP Average Energy	6942	6956	6956	14	0
c)	Step I CP Average Load Factor	74.6%	74.7%	74.7%	0.1%	
d)	Capacity Benefit	2671	2641	2641	-30	0
e)	Capacity Limit ^{1/}	4328	4144	4144	-184	0
f)	Capacity Entitlement ^{2/}	1336	1320	1320	-16	0
2 Entitlement Energy						
a)	Step II firm energy	8898	8892	8892	-6	0
b)	Step II thermal displacement	2472	2543	2506	71	-37
c)	Step II other usable energy	56	30	35	-26	5
d)	Total Step II usable Energy	11425	11464	11432	39	-32
e)	Step III firm energy	6169	6200	6201	31	0
f)	Step III thermal displacement	3921	4070	4047	149	-23
g)	Step III other usable energy	326	255	251	-71	-4
h)	Total Step III usable Energy	10416	10526	10500	110	-26
i)	Energy Entitlement ^{3/}	506	469	466	-37	-3
Notes: ^{1/} Capacity Credit Limit uses method defined in Appendix A						
^{2/} Entitlement Capacity = Lines ((1a - 1b) / 1c) / 2						
^{3/} Entitlement Energy = Lines (2d -2h) / 2						

In comparing Study C with AOP14, the Canadian Entitlement energy was reduced by 37 aMW, due largely to an increase of 936 aMW in the Thermal Displacement Market. The difference in Canadian Entitlement energy between Study A and Study C was only 3 MW.

The Canadian Entitlement capacity at 1,320 MW was the same in both Study A and Study C, and 16 MW less than in AOP14. Between AOP14 and the 2024-25 studies there were offsetting effects from the decrease in average critical period load factor, which increased the Entitlement capacity, and changes in the average critical period Steps II and III energy capability, which decreased the Entitlement capacity.

3.3.4.2. Estimate of Canadian Entitlement in 2045

In order to assess changes in Canadian Entitlement with time, the Canadian Entitlement was estimated for Study C for the 2044-45 operating year using the Streamline Procedures. Only Study C was performed, since the difference between Study C and Study A was not expected to be significant for 2044-45. In the Streamline Procedures, the AOP Step I operating criteria and hydropower generation are assumed to be the same as in previous AOPs (in this case 2024-25). Therefore, the only studies that needed to be completed to calculate the Canadian Entitlement were the Steps II and III critical period and 30-year hydroregulation studies.

Table 3-7 compares the thermal installations and Thermal Displacement Market between AOPC25 and AOPC45.

Table 3-7 – Calculation of the Thermal Displacement Market

	Thermal Displacement Market	AOPC25	AOPC45	Difference
1	Coordinated Thermal Installations	10853	17776	6923
2	Minimum Thermal Generation	248	421	173
3	System Sales	91	0	-91
4	Thermal Displacement Market ^{1/}	10514	17355	6841
Notes: ^{1/} TDM = Coordinated Thermal - Minimum Thermal - System Sales				

The change in the Study C 2045 Step II hydro load shape due to the increase in thermal installations, compared to 2025, caused a change in the length of the Step II critical period. Significant load reductions in September and October caused surpluses to occur in September and October 1943 that required adjusting the system to full contents in these periods. This changed the Step II critical period, which had been identical in all previous AOP/DDPB studies, and resulted in a 306 aMW increase in the critical period average energy because the September-October loads were lower than the critical period average. The Step III critical period was not unusually affected and remained the same as in previous AOP/DDPBs. The Step III critical period average energy was reduced by 28 aMW from AOPC25 to AOPC45. A summary of the critical period and critical period average energy is provided in Table 3-8.

Table 3-8 – Step II and III Critical Period Results

	Length (months)	Critical Period Start Date	Critical Period End Date
All previous Step II	20	Sep 1, 1943	Apr 30, 1945
All recent Step III*	5.5	Nov 1, 1936	Apr 15, 1937
Study C 2044/45 (Step II)	18	Nov 1, 1943	Apr 30, 1945
Study C 2044/45 (Step III)	5.5	Nov 1, 1936	Apr 15, 1937

*Since 2006

Table 3-9 shows a comparison between the AOPC45 and AOPC25 Canadian Entitlement. The Entitlement capacity increased from 1,320 MW for 2024-25 to 1,524 MW for 2044-45 due to the higher Step II average critical period generation. The slight increase in average critical period load factor from 74.73 to 75.71 percent reduced the Entitlement capacity. The Entitlement energy decreased from 469 aMW in 2024-25 to 290 aMW in 2044-45. The reduction is largely due to the 6,841 aMW increase in the Thermal Displacement Market.


Table 3-9 – Calculation of 2044-45 Canadian Entitlement

1	Entitlement Capacity	AOPC25	AOPC45	Difference
a)	Step II CP Average Energy	8929	9235	306
b)	Step III CP Average Energy	6956	6928	-28
c)	Step I CP Average Load Factor	74.7%	75.7%	1.0%
d)	Capacity Benefit	2641	3047	406
e)	Entitlement Capacity Limit	2621	1995	-626
f)	Entitlement Capacity^{1/}	1320	1524	204
2	Entitlement Energy			
a)	Step II firm energy	8892	8854	-38
b)	Step II thermal displacement	2543	2633	90
c)	Step II other usable energy	30	0	-30
d)	Total Step II usable Energy	11464	11488	24
e)	Step III firm energy	6200	5925	-275
f)	Step III thermal displacement	4070	4983	913
g)	Step III other usable energy	255	0	-255
h)	Total Step III usable Energy	10526	10908	382
i)	Entitlement Energy^{2/}	469	290	-179
Notes: ^{1/} Entitlement Capacity = Lines ((1a - 1b) / 1c) / 2				
^{2/} Entitlement Energy = Lines (2d - 2h) / 2				

The Entitlement energy estimates for 2044-45 are more speculative than those for the 2024-25 studies for many reasons, but primarily due to the uncertainty in the forecast of PNWA firm load, the load shape, and the mix of thermal/renewable resources needed to meet firm load. The Entitlement capacity is also speculative due to the potential to switch from an energy-critical system to a capacity-critical system, as discussed in section 3.3.5.2.

The 2044-45 study results indicate that the minimum Entitlement energy may be reached sometime before 2044-45. To estimate that effect, the fundamentals can be shown by looking at the 2024-25 studies. For the AOPC25 studies the 30-year average annual energy in the Step II study was 11,509 aMW and in the Step III study 10,908 aMW, a difference of 601 aMW. The maximum monthly secondary hydro energy in the Step II study was 11,700 aMW and in the Step III study about 15,500 aMW. With a TDM of 15,500 aMW, the difference in usable energy would be 601 aMW, and the Entitlement energy would be one-half that value at 300 aMW. The AOPC45 study shows an Entitlement of 290 aMW for the 2044-45 operating year, which is lower than the AOPC25 would suggest, because the TDM is not the only factor determining the amount. As the thermal resources increase, the Steps II and III load shapes change, thus changing the 30-year average energy. The relationship between TDM and the Canadian Entitlement energy for AOPC25 is shown in Figure 3-10.

Figure 3-10 - Entitlement Energy vs. Thermal Displacement Market



At some point in the future, the TDM is expected to grow as large as the highest surplus energy in the Step III 30-year hydroregulation study; thus, any increase in the TDM above 15,000 aMW will have only a small effect on the Entitlement energy due to the changes in hydro load shape.

The April 1994 “Forecast of Canadian Entitlement to Downstream Power Benefits, Entitlement Forecast Studies” estimated the minimum Entitlement energy at 260 MW and the Entitlement capacity for 2023-24 between 1,198 MW and 1,434 MW. The differences between the Phase 1 study results and the 1994 forecast were not analyzed but likely are due to a number of differences in assumptions, including load shape, thermal maintenance, installed hydro capacity, non-power constraints, and irrigation requirements.

3.3.5. UNCERTAINTY AND FACTORS AFFECTING THE AOP AND CANADIAN ENTITLEMENT

There are many complex and interrelated factors that affect the AOP and DDPB. In general, all of the factors affecting the AOP also affect the DDPB, but some are more important and have a much larger impact on the DDPB than on the AOP. Other factors have no impact on the AOP but do affect the DDPB.

The most significant factors are generally the same as those identified in the 1960s when the Treaty was negotiated. It was recognized that increased generating capability at U.S. dams, new reservoirs in the PNWA, increased irrigation depletions, increased thermal installations, and increased electrical intertie capability between the PNWA and California could have a significant effect on Canadian storage operation and the downstream power benefits. The procedures in the Treaty for the AOP and calculation of the DDPB allow some of these changes and limit others to create a balance of expected benefits. Today, there are many new issues and factors that may affect the AOP and DDPB, and others may arise in the future. The most significant are discussed below.

3.3.5.1. AOP

The AOP operating criteria for Canadian storage are affected mainly by changes to the Residual Hydro Load shape. The average annual hydro load is essentially fixed by the amount of water available in the critical period and the operating policy and constraints. The Residual Hydro Load shape can vary considerably, however, and that affects how the water is stored and released throughout the year. The Residual Hydro Load shape is affected by many factors, including the shape of regional loads; exports; imports; generation pattern of other resources, especially thermal maintenance and plant factors; and changes to non-power requirements and installed capacity at non-Base System projects.

If the PNWA firm load shape were to stay the same in the future, and added thermal and other resources had a flat annual capability, then the Residual Hydro Load would become larger in the winter and smaller in the summer. That was the expectation in the 1960s, but it appears unlikely now. Summer loads are growing faster than winter loads, and much of the resources are either purchased or operated as needed to meet seasonal needs, including seasonal exchanges.

The amount of Residual Hydro Load has varied little in recent AOP studies. Looking at past AOPs, there have been some significant changes in seasonal exchanges with California (matching import/exports) and thermal maintenance schedules that have been big enough to change the Residual Hydro Load shape. In general, higher hydro load in some months will result in higher Canadian outflows in those months to help meet that load.

The AOP operating criteria could also be changed dramatically as the system switches from an energy-constrained to a capacity-constrained system, depending on the optimization goals at that time. This switch could result in different operating policies that may attempt to maximize FELCC, Firm Power Load Carrying Capability (FPLCC), average energy, or certain flows and reservoir elevations.

3.3.5.2. DDPB

The Entitlement energy is affected primarily by the Thermal Displacement Market, which is affected by the future mix of thermal/renewable resources, PNWA load growth, and load shape. Uncertainty in the forecasts of these parameters affects the projected Entitlement energy. At some point in the future, the TDM is expected to grow as large as the highest surplus energy in the Step III 30-year hydroregulation study, and any further increase will have no effect on the Entitlement energy. The Canadian Entitlement energy will be mainly derived from spill reductions and head gain at U.S. projects, due to operation of Canadian Treaty Storage. At that point, Canada is required to operate only the amount of Canadian storage needed to provide that level of regulation, and that could be less than the full 15.5 Maf defined in the Treaty.

The Entitlement capacity is affected by the changes in length of the Steps II and III critical period and the average Step I critical period load factor. The length of the Steps II and III critical period is affected mainly by the load shape, the shape of the thermal resource generation, and changes to non-power constraints, including flood control. The Step I critical period has not changed significantly (varies between 42 and 42.5 months) since the early 1970s.

Switching from an energy-constrained to a capacity-constrained system is affected by all factors that affect the Canadian Entitlement capacity. This includes average critical period load factor, peak reserves (which may be affected by the thermal/renewable resource mix), and changes to the critical period. The more non-displaceable resources are added to the system, the higher the chance that the system will move from an energy-critical system to a capacity-critical system. As capacity becomes critical in Step I, non-baseload resources may potentially be considered to be used to meet the capacity need. However, if capacity becomes critical in Step II, the Capacity Credit Limitation (CCL; see section 3.3.5.3 and Appendix A) may become an issue.

The Phase 1 studies forecast the Canadian Entitlement capacity to be increased from around 1,300 MW in 2024-25 to around 1,500 MW in 2044-45 due to a shorter Step II critical period. The amount of thermal installation has significantly reduced September and October hydro loads of both Steps II and III and causes the Step II Critical Period to start at November instead of September. The use of significant amounts of non-displaceable and variable wind resources may require a higher level of peak reserves and hence could increase the probability of a capacity-critical system in any or all three Steps. That is why the Canadian Entitlement capacity will be very volatile and unpredictable.

The Canadian Entitlement capacity is especially sensitive to the Residual Hydro Load shape of Step II and III systems, because the start and end dates for the critical period can be affected. The total PNWA firm load is not used in the DDPB; instead, only the PNWA firm load shape is used. The Residual Hydro Load for the Steps II and III systems is created for each study by adding the critical period hydro capability to the thermal installation capability to create a total firm load that is then shaped the same as the PNWA firm load. Thus, the PNWA firm load shape and thermal installation amount and shape are the only factors affecting the hydro load shapes for the Steps II and III studies.

3.3.5.3. Capacity Credit Limitation

The CCL is defined in the Treaty and clarified in Protocol section IX. In general, it sets a limit on the maximum amount of Entitlement capacity. The Capacity Credit Limit has not limited any Entitlement capacity to date but may in the future.

Although the CCL did not apply in the Phase 1 studies, it could apply by 2024 or sooner, depending on the requirements for peak reserves and possibly different methods for calculating peak load capability. The CCL is described in Appendix A.

3.4. FLOOD CONTROL OPERATIONS: STUDIES A AND B

A primary goal of the Phase 1 studies has been to assist in understanding Called Upon flood control operations after 2024. The Treaty describes Called Upon flood control in general terms. In addition, the Treaty Protocol describes the consultation process to be used by the Entities for Called Upon use of flood control storage in Canadian projects. However, neither the Treaty nor the Protocol contains sufficient details and procedures to fully guide the Entities in real-time implementation of Called Upon operations. The Phase 1 studies are the Entities' first attempt to identify the uncertainties associated with implementation of Called Upon flood control after 2024.

3.4.1. OVERVIEW OF CALLED UPON FLOOD CONTROL OPERATIONS AFTER 2024

Treaty flood control operations under the FCOP prior to 2024 are summarized in section 1.2.1 and described in detail in Appendix A. The current operations provide a baseline to compare the study methodologies applied in the Phase 1 technical studies. However, the focus of the Phase 1 studies is on one possible approach to implement Called Upon flood control operations. The Treaty states that after 2024 the U.S. can call upon Canada to operate storage to control potential floods in the U.S. that could not be adequately controlled by all the related storage facilities in the U.S. Called Upon flood control operation begins when the operation of Canadian reservoirs to provide additional storage volumes or to reduce outflows determined to meet U.S. needs is initiated. Once the operation begins, the Entities will need to begin calculating Canadian operating costs and economic losses associated with the Called Upon action²³ so the U.S. can reimburse Canada. Prior to making the formal Called Upon request, Canadian and U.S. system operators will need to conduct short-term and real-time planning studies to determine if Called Upon operations will be required and to determine volumes of Canadian storage needed to control flooding downstream in the U.S. The Phase 1 study scenarios, particularly those conducted in forecast mode, attempted to simulate what those methodologies and procedures might entail post-2024 without any consideration of the consultation process.

²³ Methodologies and procedures to calculate operating costs and economic loss to Canada associated with Called Upon flood control operations are not defined by the Treaty or Protocol, and no attempt was made in the Phase 1 studies to develop those procedures or to estimate Canadian costs and losses of the Phase 1 scenarios. However, Phase 1 studies quantified the potential difference in Canadian storage reservoir operations that this preliminary Called Upon operation caused.

Throughout this document, the following terminology is used to describe Called Upon flood control operations:

- A *threshold* is a forecast volume of runoff for the Columbia River system for the April through August period that may lead to potential flood levels that cannot be adequately controlled by U.S. facilities. The threshold volume varies for each month from January through April. If a runoff volume forecast for a given month exceeds the threshold for the corresponding month, a calculation to determine the required Canadian Called Upon flood control drafts is triggered.
- *Called Upon flood control drafts* are calculated drafts from Canadian projects to meet U.S. flood control needs and are based on the assumptions used in the various Phase 1 studies. Note that at this point only the calculation of Called Upon draft requirements is triggered; there is no formal procedural request to Canada for change in reservoir operations to meet Called Upon requirements. However, in the Phase 1 modeling, the U.S. reservoirs were drafted for effective use of flood control storage in all triggered periods.
- *Called Upon action*. In cases where the Called Upon flood control draft is less than the power drafts, then Canadian reservoirs would operate to the power draft, and this is not considered a Called Upon action. Called Upon actions would occur only in cases where Called Upon flood control draft is deeper than the anticipated power draft. In the Phase 1 modeling, any day that the Called Upon flood control draft was deeper than the power draft was considered a Called Upon action.
- *Called Upon year*. A Called Upon year is any year in which there is at least one month in which the runoff volume forecast exceeded the threshold and operation at any Canadian Treaty project is changed to meet U.S. flood control needs under a Called Upon action.

3.4.2. CALLED UPON FLOOD CONTROL ASSUMPTIONS

A number of assumptions pertaining to flood control operations that went into defining the various scenarios considered under the three Phase 1 studies are described in section 2.1. A number of additional assumptions made to model flood control and Called Upon operations in the Phase 1 studies are described below.

Process for Requesting Called Upon. The Called Upon operation was assumed to be assured and immediate. Modeling in the Phase 1 study did not consider time that may be needed to follow a consultation process outlined in the Treaty Protocol where the U.S. would request Called Upon storage from Canada and Canada could take up to 10 days to consider the request before responding. If the Entities do not agree on the call or its terms the matter is then submitted to the Permanent Engineering Board.²⁴ The total time between requesting and starting the implementation of Called Upon action could be up to 20 days. For the purpose of modeling Phase 1 scenarios, no attempt was made to emulate the request/consultation process. For study

²⁴ The Columbia River Treaty established the Permanent Engineering Board (PEB) to handle tasks such as assembling flow records, assisting in settling differences that may arise between the Entities, and creating annual reports of the results being achieved.

purposes only, it was assumed that if Called Upon storage was needed based on the calculated flood control draft, then the requirement was met automatically.

Effective Use of U.S. Flood Control Storage Space. For the Phase 1 studies, an initial attempt was made to define how the U.S. system could be effectively used to control flood events. The U.S. headwater projects (Libby, Dworshak, and Hungry Horse) were assumed to be operated to the effective use procedure. In demonstrating the effective use, the projects were drafted to at least the extent necessary to ensure that the projects could be operated at minimum flows during the peak flow period. Grand Coulee and Brownlee were drafted toward empty. It is possible that other projects may also be able to provide some degree of flood protection, but this possibility was not investigated in Phase 1.

Assured Operation from Canada. If the Treaty is terminated after 2024 there will no longer be coordinated planning between Canada and the U.S. through the FCOP or AOP. In that case, Canadian operations from year to year will be highly uncertain. The power drafts developed for the Phase 1 studies were treated as an assured operation, although in reality there would be no assurance that the projects would be operated in this manner if the Treaty were terminated. It should be noted that the operations for the B1 and B2 studies are monthly estimates of potential operations. The variation of the day-to-day operation may be significant, as the Canadian system will be able to fully respond to market conditions and B.C. power and non-power needs without having AOP limitations.

Variable Flow Flood Control. Variable Flow (or VarQ) refers to a system flood control operation developed by the Corps for Libby and by Reclamation for Hungry Horse as an alternative to standard flood control operations. In general, the intent of VarQ flood control is to improve the likelihood of refill and potentially provide more instream flow for fisheries during and after the refill season. For this reason, VarQ procedures generally can result in higher reservoir elevations at Libby and Hungry Horse and higher corresponding spring outflows than standard flood control procedures. VarQ flood control influences operations for system flood control at Grand Coulee Dam and can cause it to draft deeper than it otherwise would.

All of the Phase 1 studies modeled Hungry Horse using VarQ operations. However, because Libby VarQ is not used in Treaty studies, Libby was operated to Standard flood control in the studies where the Treaty continues (Studies A and C). Libby VarQ flood control was used only in the B studies. In Called Upon years, the reservoir was drafted to the deeper of its effective use space or the relevant (VarQ or Standard) Storage Reservation Diagram (SRD).

Kootenay Lake IJC. These studies were conducted in compliance with the 1938 International Joint Commission (IJC) Order for Kootenay Lake (for details regarding the IJC order, see Appendix A, section A.2.4.5).

3.4.3. CALLED UPON FLOOD CONTROL MODELING METHODOLOGY

The Treaty does not specify how Called Upon flood control operations would be implemented post-2024. However, Appendix A of the FCOP describes a general approach for using On-Call

flood control prior to 2024. For the Phase 1 studies, the Called Upon procedure was assumed to follow a similar approach.

There were some adjustments to the Called Upon methodology as the studies progressed, based on lessons learned, so the initial methodology was refined as the studies progressed. Differences between studies are highlighted in the sections below.

3.4.3.1. Drawdown Period (generally January through April 15)

During the drawdown period, the water supply volume forecast²⁵ was assumed to be known on the first day of each month. If the volume forecasts throughout the drawdown period were less than a certain threshold,²⁶ then Called Upon was not required for that year. However, if the volume forecast exceeded the threshold in at least one month, then the calculation to determine the required Canadian Called Upon draft was performed. This calculation assumed that the Canadian reservoirs would begin to draft on the first day of that month toward their end-of-month Called Upon draft objectives.²⁷ In the U.S., the headwater projects (Libby, Dworshak and Hungry Horse) were assumed to be drafted toward their effective use amount,²⁸ while Grand Coulee and Brownlee were drafted toward empty by April 30.

If a subsequent water supply forecast dropped back below the threshold, then it was assumed that the U.S. reservoirs would pass inflows until the calculated drafts intersected with the SRD draft. For the Canadian reservoirs, the A1 and B1 studies assumed that the Canadian projects would pass inflows until the reservoir elevations intersected with the power or local flood control levels. The B2 study assumed that the Canadian projects would release minimum flows until the reservoir recovered to the power operation levels.

If the calculated Canadian Called Upon draft was deeper than the power draft on any day,²⁹ then calculated Called Upon operations were implemented and the year was considered to be a Called Upon year. For the Phase 1 studies, this Called Upon action was assumed to be assured and immediate.

²⁵ For the Phase 1 studies, synthetic volume forecasts were developed using historical meteorological data with current procedures (to the extent possible).

²⁶ The threshold volume represents the maximum runoff volume to which the U.S. projects alone are able to control flows below the flow objective. To account for forecast uncertainty, threshold volumes included a reduction equivalent to one standard deviation of the forecast errors for each month.

²⁷ For Studies A1 and B1, the Canadian Called Upon draft objectives were based on the On-Call SRDs from the FCOP for Arrow, Mica, and Duncan, except that the Arrow On-Call SRD was modified to provide a variable draft between 3.6 and 7.1 MAF depending on the forecast at The Dalles. For Study B2, the Canadian Called Upon draft was based on the modified Arrow On-Call SRD only. The procedure for Study B2 was changed based on the results from Study A1, which indicated that the power drafts at Mica and Duncan were likely sufficient so that additional Called Upon storage from Mica and Duncan would not be required.

²⁸ The effective use amount was determined based on the greater of (1) the space required on April 30 for the project to fill on June 30 (as determined using the volume forecast and while releasing minimum flow during May and June) and (2) the project's SRD draft.

²⁹ Daily drafts were calculated using straight-line interpolation between month-end storage objectives.

3.4.3.2. Refill Period (generally April 16 through July)

Refilling of flood control projects is an important part of system power studies to ensure that reservoirs have the maximum amount of water in storage to begin the next operating year. If projects are not refilled yearly, the ability to meet future system firm load is reduced; therefore, refill of all projects was a priority after meeting flood control needs. Refill is also important for meeting other operating objectives that were not considered in the Phase 1 studies, such as fisheries and recreation.

During the refill period, reservoirs begin to refill based on the timing of the Initial Controlled Flow using the procedures described in the FCOP. The U.S. headwater projects, having been drafted for effective use, would release minimum flows during the refill period. Grand Coulee would operate to meet the ICF at The Dalles. The Canadian projects would generally refill while releasing minimum flows until recovering to the power operation levels. After the peak unregulated flow at The Dalles had passed and streamflow had receded, the headwater projects continued to release minimum flow to fill or might release more than minimum flow to prevent projects from filling too rapidly, resulting in the need to pass inflow at a high rate in the future.

3.4.4. RESULTS OF POST-2024 CALLED UPON FLOOD CONTROL OPERATIONS

This section summarizes the key findings and results of the Phase 1 studies, including comparing Called Upon operations across the scenarios. The emphasis is on interpreting the effects of the various assumptions made with regard to implementation of Called Upon flood control.

3.4.4.1. Frequency and Duration of Called Upon Operations

An objective of the Phase 1 studies was to determine the approximate frequency that the U.S. might need to call upon Canada for flood control storage after 2024 and the relative duration of Called Upon operations. The maximum flood flow objective at The Dalles was the strongest determinant of the frequency of Called Upon flood control operations. The runoff volume forecast ultimately determined the frequency Called Upon was triggered over a multi-year period. The studies confirmed what may have been considered an obvious assumption going into Phase 1: the higher the maximum flow objective in the U.S., the less frequently Called Upon operations in Canada will be required.

As shown in Table 3-10, every scenario with 600 kcfs as the maximum flow objective triggered Called Upon operation in 21 years (30%) out of the 70-year period of record evaluated. For every scenario in which 450 kcfs was the maximum flow objective, Called Upon was triggered in 52 years (74%). This result occurred regardless of whether the Treaty continued (A Studies) or was terminated (B Studies), because the assumptions to trigger the Called Upon calculation were the same. Called Upon action from Canada was required in all years when the Called Upon calculation was triggered. In years when Called Upon was not triggered (flood control storage space in the U.S. was presumed to be adequate to control floods to the maximum flow objective at The Dalles without additional Called Upon storage in Canada), all U.S. reservoirs operated in accordance with existing procedures. There was no significant difference in system flood control

operations from study to study in non-Called Upon years, so they are not discussed as part of the results in this section.

Table 3-10 – Summary of Called Upon Frequency, Peak Flows and Volumes

Scenario	# of Years Triggered by Volume Forecast	Drawdown Period (Jan-Apr 15)			Refill Period (Apr 16-Jun)			Total Canadian Called Upon Storage Required (Maf)	Year of Maximum Requirement
		# of Years Objective Exceeded	The Dalles Peak (kcfs)	Year of Peak	# of Years Objective Exceeded	The Dalles Peak (kcfs)	Year of Peak		
A1F600	21	0	539	1974	1	669	1948*	2.3	1974
B1F600	21	0	557	1982	1	714	1948	15	1976
B2F600	21	0	547	1982	1	674	1948	6.4	1972
<i>A1F600**</i>						<i>574</i>	1997		
<i>B1F600**</i>						<i>519</i>	1997		
<i>B2F600**</i>						<i>513</i>	1997		
A1F450	52	2	539	1974	7	585	1974	3.2	1958
B1F450	52	5	504	1974	5	581	1948	15	1934
B2F450	52	2	517	1974	5	554	1948	6.2	1956

*Water year 1948 did not trigger as a Called Upon year due to a very inaccurate water supply forecast; the actual total volume runoff greatly exceeded the forecast amount

** Peak flows in the Called Upon years are italicized for A1F600, B1F600 and B2F600

Table 3-11 provides additional details with respect to the potential frequency and duration of Called Upon operations by comparing the number of days that the U.S. would request Called Upon flood control from Canadian reservoirs. In Table 3-11, “planned draft” is the operation of Canadian reservoirs for power and/or flood control if the U.S. had not Called Upon flood storage. The number of days Called Upon flood control exceeded the planned draft of Canadian reservoirs is shown. As expected, Called Upon duration would be longer in the scenarios in which the Treaty is terminated and Canada operates principally for local flood control (B1) than in the scenarios where the Treaty continues (A1) or the Treaty is terminated and Canada operates principally for power operation (B2). This is because deeper seasonal power drafts in the latter two sets of scenarios provide incidental flood storage benefits. In the B2 study, assumptions were made to use only Arrow for Called Upon flood control, because Mica and Duncan were already drafted deeply for power, precluding the need for additional space requests at Mica and Duncan. A similar assumption could have been made in Study A1, which would likely preclude the need for additional space from Mica and Duncan.

Table 3-11 – Average Number of Days Called Upon Draft is Greater than the Planned Draft at Canadian Reservoirs

Average Number of Days Called Upon Draft is Greater than Power Draft or Canadian Local Flood Control during January through June in Called Upon Years				
		Mica	Arrow	Duncan
A1F600	Min	0	0	10
	Max	140	119	176
	Avg	47	37	135
B1F600	Min	111	80	91
	Max	182	182	182
	Avg	166	156	166
B2F600	Min	0	56	0
	Max	0	182	0
	Avg	0	128	0
A1F450	Min	0	0	85
	Max	151	123	181
	Avg	46	33	149
B1F450	Min	142	133	150
	Max	182	182	182
	Avg	177	167	179
B2F450	Min	0	56	0
	Max	0	182	0
	Avg	0	151	0

It is important to note that these results reflect the Phase 1 study assumptions and methodologies. However, the results may overstate the number of years that Called Upon operations would be required to meet U.S. flood control needs in actual operation. This is especially the case with the frequency that Duncan is Called Upon in all studies and the frequency that Mica is Called Upon in Study A1. In the A1F450 study Duncan was used for Called Upon Flood control in all 52 years that Called Upon was triggered. Arrow and Mica Called Upon drafts were used in 14 years and 15 years, respectively. When Called Upon was triggered and the call was made, Duncan drafted to the Called Upon draft from the FCOP. The Duncan Called Upon draft required Duncan to draft 1.4 Maf by February 28, while the full Mica and Arrow Called Upon draft did not occur until March 31. This early draft for Duncan increases the number of days that Duncan is in a Called Upon situation and might imply that Duncan was overused in the studies. In actual operations it is likely that the use of Duncan would not have occurred in the years that Mica and Arrow were not Called Upon for flood control.

3.4.4.2. Volume of Canadian Called Upon Storage

Another important objective of the Phase 1 studies was to identify the volume of Called Upon storage in Canadian reservoirs needed to meet U.S. flood control needs after 2024, based on certain assumptions. Table 3-12 summarizes the average Called Upon volume required under

the different scenarios for Called Upon years and the maximum Called Upon storage volumes required. Note that these volumes do not represent the total volume of Canadian storage required to control flood events downstream in the U.S. Rather, they represent the additional increment of Called Upon storage over and above the local flood control or power drafts under the planned operation of Canadian reservoirs if Called Upon storage was not required. Figure 3-11 and Figure 3-12 show the Called Upon storage required from Canadian reservoirs for Called Upon Years in the 600 and 450 kcfs maximum objective scenarios, respectively.

Table 3-12 – Called Upon Storage Volumes (Maf) Required from Canadian Projects

	Treaty Continues (A1)	Treaty is Terminated (CND Power draft) (B2)	Treaty is Terminated (CND local draft) (B1)
<i>600 kcfs objective</i>			
Average over 21 Called Upon years	1.3	4.7	10.7
Maximum (year)	2.3 (1974)	6.4 (1972)	15 (1976)
<i>450 kcfs objective</i>			
Average over 52 Called Upon years	1.5	4.7	11.4
Maximum (year)	3.4 (1958)	6.2 (1956)	15 (1943)

As expected, the volume of Called Upon storage will generally be less if the Treaty continues after 2024. This result is attributable to the understanding that the Treaty projects would continue to be operated in coordinated fashion by Canada and the U.S. to optimize hydropower under an annual AOP with assured power drafts that would provide incidental flood control benefits. The largest expected volumes of Called Upon storage were under the B1 scenarios, in which the Treaty is terminated and Canada operates principally for local flood control, drafting Arrow only 2 feet in most years. The B2 studies, in which the Treaty is terminated, also provided an assumed power draft, although it is not assured, so the Called Upon volume was less than expected when compared to the B1 scenarios. Composite Called Upon drafts were similar between the 600 kcfs and 450 kcfs studies, because the Called Upon volume drafted for flood control was the same once Called Upon was triggered. As discussed below, this should be improved for any further studies.

This finding demonstrates that the volume of storage requested by the U.S. for Called Upon varied significantly depending on whether the Treaty continues or is terminated. Under the Treaty is Terminated assumption, there was a wide range of volume of storage that may be required for Called Upon, depending on how the Canadian storage was operated.

For future implementation of Called Upon operations, it will be important for Canada and the U.S. to agree on the base condition against which Called Upon operations will be measured, as this will influence the accounting for Called Upon volumes. Under the Treaty, after 2024, the

U.S. will be required to reimburse Canada for operating costs and economic losses associated with Called Upon operations. No attempt was made to calculate the economic losses associated with Called Upon operations under the Phase 1 scenarios.

3.4.4.3. Effects on Peak Flows

No attempt was made to calculate potential flood damages in the U.S. or Canada resulting from the Phase 1 scenarios. For the purposes of Phase 1, peak flows at The Dalles were used as a proxy for levels of flood control provided. The following paragraphs compare the relative effects of the Phase 1 scenarios on peak flows at The Dalles.

When the Called Upon operation was triggered, the Canadian and U.S. reservoirs were all drafted to the same volume, regardless of maximum flow objective, closely following the existing SRDs defined in the FCOP, and the regulation in the spring is similar. As a result, the peak flows were similar. Table 3-13 compares peak flows at The Dalles under the A and B studies that were conducted in forecast mode. As seen in Table 3-13, the average difference between the 450 kcfs and 600 kcfs maximum flow objectives studies was less than 20 kcfs. This finding indicates the need to investigate alternative draft calculations or procedures for different flow objectives in future studies.

Table 3-13 – Comparison of Peak Flows at The Dalles

The Dalles Flows (kcfs)				
Scenario	Average Peak in 21 Called Upon Years	Average Peak in 52 Called Upon Years	Average Peak in Non-Called Upon Years	70-Year Peak Average
A1F600	437		363	386
A1F450	432*	389	314	370
B1F600	413		413	413
B1F450	394*	367	363	366
B2F600	407		363	376
B2F450	391*	361	316	349

*The 600 kcfs objective triggered Called Upon in 21 years
 The 450 kcfs objective triggered Called Upon in 52 years
 To compare the effect of 450 kcfs vs. 600 kcfs, the peak flows at The Dalles for the same 21 years triggered by the 600 kcfs objective were averaged.

Figure 3-11 – Composite Called Upon Draft Minus Power or Canadian Local Flood Control Drafts for Forecast 600 kcfs Studies





Figure 3-12 – Composite Called Upon Draft Minus Power or Canadian Local Flood Control Drafts for Forecast 450 kcfs Studies




In the scenarios with a maximum flow objective of 600 kcfs (B1, B2, A1), there was only one year where the flow objective was exceeded, and that was not a Called Upon triggered year (in 1948 the forecast was substantially under-forecasted, and therefore Called Upon did not trigger). The regulated peak flow in this year was similar in the two power studies (A1 and B2), at about 670 kcfs. The regulated peak flow in the B1 study that used Canadian local flood control was 714 kcfs. The studies that included power drafts reduced the peak flow by about 44 kcfs in this non-triggered year.

3.4.4.4. Flow Reduction at The Dalles due to U.S. Projects and Canadian Projects

The B1F450 study was used to determine how much U.S. projects could reduce flows at The Dalles. Figure 3-13 shows reductions in peak flows at The Dalles for the 52 Called Upon Years by operation of the U.S. projects when Canadian projects were operating on local flood control. The figure also shows how the U.S. projects operating with the Canadian projects on Called Upon flood control further reduced flow at The Dalles. U.S. projects and Canadian local flood control reduced unregulated flows by an average of 243 kcfs, which is the difference between the “Unregulated” points and the “B1F450 Can Local” points in Figure 3-13. The minimum reduction was 36 kcfs and the maximum reduction was 319 kcfs. Canadian Called Upon operations reduced the flow 86 kcfs on average, with a minimum of 7 kcfs and a maximum of 187 kcfs. This is the difference between the “B1F450 Can Local” points and the “B1F450 Can CU” points.

Figure 3-13 – Comparison of Unregulated Peak Flows to Peak Flows for B1F450 Scenarios



3.4.4.5. Impacts on Use of U.S. Reservoir Storage

During initial operations for flood protection in the Phase 1 studies, before Called Upon operations were initiated U.S. reservoirs were operated to their SRDs. When a Called Upon operation was triggered, in order to make effective use of U.S. flood control storage Libby, Hungry Horse, and Dworshak reservoirs were drafted in the final Called Upon regulation to the deeper of their SRD or effective use space. In Called Upon operations Grand Coulee and Brownlee reservoirs were drafted toward empty. This effective space draft allowed the U.S. projects to draft and then refill on minimum flow, so the U.S. reservoir contribution of flow at The Dalles was the minimum possible, thus making effective use of space. This was required to demonstrate effective use even though Called Upon may not have been needed if Canadian power draft was deeper than the required Called Upon draft.

This concept of operating the U.S projects to effective use versus standard SRDs is new. To determine the impact on storage at the U.S. projects, the additional draft required for the effective use operation was examined for the 52 Called Upon years from the F450 kcfs studies. In non-Called Upon years, there was no effective use requirement, and the U.S. projects were operated to the existing SRDs for the individual projects. As may be expected, the U.S. projects were drafted significantly deeper during years that Called Upon operations were triggered, and the number of years that the projects did not refill also increased.

Tables 3-14 to 3-18 show the values for the F450 kcfs scenarios. The total draft requirements were similar for Study A and Study B in the F450 and F600 kcfs scenarios, so only one data set is provided.

The effects on Libby when using effective space versus both Standard SRD and VarQ are shown in Table 3-14. Compared with VarQ operation, in years when Called Upon was triggered, Libby drafted on average an additional 47.2 feet on April 30. In three of the Called Upon years, Libby also did not refill, due to forecast error. When using effective space versus Standard SRDs, Libby drafted on average an additional 10.8 feet on April 30.

Table 3-14 – Libby

<i>VarQ minus Effective Space, difference in feet</i>				
	Jan	Feb	Mar	Apr
Average	8.5	16.4	28.5	47.2
Median	3.4	5.9	28.3	53.6
Max	27.7	49.7	68.4	79.9
Min	0.0	0.0	0.0	0.0
<i>Standard minus Effective Space, difference in feet</i>				
	Jan	Feb	Mar	Apr
Average	1.0	1.7	4.8	10.8
Median	0.0	0.0	0.0	0.0
Max	12.2	23.1	36.4	46.6
Min	0.0	0.0	0.0	0.0

As shown on Table 3-15, Hungry Horse drafted on average an additional 45.1 feet on April 30 using effective space versus VarQ in years when Called Upon was triggered. In six of the Called Upon years, Hungry Horse did not refill, due to forecast error.

Table 3-15 – Hungry Horse

<i>VarQ minus Effective Space, difference in feet</i>				
	Jan	Feb	Mar	Apr 30
Average	11.0	20.4	30.6	45.1
Median	11.7	23.1	35.6	48.1
Max	14.1	29.5	44.4	55.4
Min	3.1	4.4	0.0	27.6

Table 3-16 shows that Dworshak drafts on average an additional 27.1 feet on April 30 when using effective space versus Standard SRDs. In seven of the Called Upon years, Dworshak did not refill, due to forecast error.

Table 3-16 – Dworshak

<i>Standard minus Effective Space, difference in feet</i>				
	Jan	Feb	Mar	Apr 30
Average	4.6	11.8	25.3	27.1
Median	0.0	8.1	22.3	1.2
Max	17.9	37.9	64.8	74.6
Min	0.0	0.0	0.0	0.0

Brownlee (Table 3-17) drafts on average an additional 31.4 feet on April 30 when using effective space versus Standard SRDs. Brownlee refilled in all Called Upon years.

Table 3-17 – Brownlee

<i>Standard minus Effective Space, difference in feet</i>				
	Jan	Feb	Mar	Apr
Average	0.1	0.7	14.3	31.4
Median	0.0	0.0	15.3	30.0
Max	5.4	8.7	47.6	97.8
Min	0.0	0.0	0.0	0.0

In Called-Upon years, Grand Coulee was drafted to empty, elevation 1208 feet, on April 30 when the Called Upon calculation was triggered in April. A comparison was made for the F450 studies between Grand Coulee drafting based on current procedures (Canadian project and Libby drafts were based on the FCOP; other U.S. projects were based on current SRDs; and no power drafts) and operating in Called Upon years. On average, Grand Coulee was drafted from 9.3 to 12.4 feet deeper than in current operations on April 30. The negative values in the table below indicate an early start of refill, before April 30. The average additional draft at Grand Coulee for

Called Upon years occurred when refill started May 1 or later, and Grand Coulee was drafted on average 14.4 to 18.3 feet deeper than current procedures. The project refilled every year but was also drafted empty an additional 24 to 26 years (depending on scenario) over the current operations.

Table 3-18 – Grand Coulee

<i>April 30 difference in draft (SRD minus effective use; feet)</i>						
All Called Upon Years				Called Upon Years in which Refill Began after May 1		
	A1F450	B1F450	B2F450	A1F450	B1F450	B2F450
Ave	9.3	12.4	12.2	14.4	17.8	18.3
Med	11.4	12.2	12.2	12.2	18.0	20.4
Max	31.1	31.1	32.8	31.1	31.1	32.8
Min	-25.6	-24.6	-27.1	1.5	4.0	1.5
Number of years GCL is empty on April 30th						
Base	A1F450	B1F450	B2F450			
4	29	30	28			

3.4.4.6. Called Upon Operations and Flex Operations

In the A1 scenarios, where the Treaty continues after 2024, Canada may flex operations between Arrow and Mica (shift storage of water between reservoirs) subject to maintaining the combined Arrow and Duncan outflows and meeting Flood Control requirements at each project. A cursory evaluation was conducted on a selected number of years to determine if it was physically possible to switch from a projected Flex operation to the Called Upon draft requirements and how long it would take to return to the Flex operation after Called Upon was no longer required.

The Flex operation at Arrow usually had Arrow 1 to 3 Maf higher than the Called Upon draft required. The assumption used to transition Arrow from the Flex operation to the Called Upon operation was to increase Arrow outflow up to approximately 65 kcfs.

The Flex operation at Mica normally had the project 1 to 3 Maf lower than the Called Upon operation. The assumption used to transition Mica to the Called Upon operation was to reduce outflows at Mica to minimum flow until the Flex operation intersected the Called Upon operation. It took approximately 2 months for Mica to transition from the Flex operation to the Called Upon operation. If the switch from Flex to Called Upon occurred in January, February, or March, then the system could be on the Called Upon operation by the end of April. If the switch occurred in April, then achieving the Called Upon operation by the end of the month would result in flows from Arrow in excess of 100 kcfs.


For years when Called Upon was triggered in one month and not needed in succeeding months, it was found that it took Mica and Arrow up to two months to recover from the Called Upon operation to the Flex operation. This analysis did not, however, consider B.C. domestic load requirements and other non-power constraints. It is unlikely that Mica could be reduced to minimum flow in winter without a very high risk to BC Hydro power reliability and risk of impacts to non-power requirements. Further investigation is required as to how much Flex operation can affect Called Upon operation.

3.4.4.7. Runoff Volume Forecast Changes in Called Upon Years

In some years the runoff volume forecasts fluctuated from month to month above and below the runoff volumes that trigger Called Upon flood control operations. When this occurs, Called Upon flood control can be triggered in one month, not triggered in the next month, and then triggered again in the following month. This can cause flow fluctuations that may be undesirable for fish and other purposes.

For example, Figure 3-14 illustrates this effect in water year 1967. With 600 kcfs as the maximum flow objective, Called Upon was first triggered in February, not triggered in March, and then triggered again in April. This caused Arrow month-average outflows to fluctuate from 100 kcfs to 3 kcfs and then back to above 100 kcfs in February, March, and April. Arrow reservoir attempted to fill back up to its intended power operation when Called Upon was not triggered in March. Further investigation is required to refine procedures for mitigating these impacts.


Figure 3-14 – Effects of Forecast Changes on Called Upon Operations



3.4.4.8. Prioritizing Between Winter and Spring Called Upon Flood Control

Modeling to control for winter flood events was not a primary objective for the Phase 1 studies; however, it was discovered that by regulating projects using the assumptions that were developed, Called Upon drafts increased flows to what might be considered undesirably high flows in the winter period. As a result, drawdown for Called Upon in January through April sometimes caused flows to be higher than spring flows. Figure 3-15 shows an example of how Called Upon drafts occurring in conjunction with a winter rain event could cause an increase in flow with a high unregulated winter flow event. In 1974 under the B1O600 scenario, the winter peak flow exceeded 500 kcfs. It is unlikely that the Entities would incur a deliberate and certain high flow to avoid the possibility of an uncertain high flow at a later time. Winter flows higher than spring flows was not a rare occurrence: for the A1F450 study, in 13 years the winter flows were higher than the spring flow; the B1F450 and B2F450 years showed 19 years and 14 years, respectively.

Figure 3-15 – Effects of Called Upon on High Winter Flows



3.5. CALLED UPON IMPACTS TO CANADIAN COMPOSITE STORAGE, ARROW PLUS DUNCAN OUTFLOW, GRAND COULEE, AND CANADIAN AND U.S. GENERATION

3.5.1. MODELING OVERVIEW

A second important goal of the Phase 1 Studies was to understand the impacts of Called Upon flood control operations on 1) Canadian and Grand Coulee reservoirs, 2) Arrow plus Duncan outflows, and 3) Canadian and U.S. generation. Called Upon implementation was assessed for Treaty Continues (A1) and Treaty is Terminated (B) scenarios. In order to determine the possible impacts to these three aspects of system operations, several modeling and operating criteria assumptions were made for:

- Flood control and Called Upon operation
- Canadian Flex operation
- Short-term modeling

The results from the long-term modeling (AOP or AOP-like) operating criteria, the Canadian Flex operation, and the Called Upon operations all provided input to the short-term power impact studies that were used to determine the impacts of Called Upon.

The following briefly describes these assumptions and overall approach for assessing Called Upon impacts.

Called Upon Operations. Called Upon was assumed to be implemented during short-term planning (drawdown period) and in real-time operations (drawdown and refill); however, for the purposes of the Phase 1 studies it was applied in the short-term modeling of the system. In years determined to require Called Upon storage from Canada, the Called Upon draft of Canadian projects was compared to how they otherwise would have drafted (which is dependent on the scenario being modeled) to assess the impact of Called Upon.

Canadian Flex Operation. Canadian Flex is the ability of Canada to balance water between Canadian reservoirs so long as the total Canadian storage content and the flow across the border is the same as defined in Treaty planning. The Canadian Flex operation was applicable only in the Treaty Continues A1 scenarios. Therefore, when assessing the impacts of Called Upon in the A1 scenarios, the Called Upon draft was compared to the Canadian Flex operation in years where Called Upon was required.

Short-term Modeling. Since Canadian Flex and Called Upon operations are to be implemented in short-term or real-time operations, it was important to model their implementation as closely as possible using existing modeling techniques. In order to assess the impacts of these two operations, power impact studies were conducted for each scenario. These power impact studies most closely resembled 70-year continuous hydroregulation studies using monthly time-steps, in forecast mode, with Called Upon and/or Flex operations applied where appropriate. The

monthly model did not capture the daily and hourly variability that is necessary to fully understand the impacts of Called Upon on Canadian generation.

Overall Approach. For each of the A1 and B scenarios a set of two short-term or power impact models were compared. For each of these studies, a base “no-Called Upon” and a “Called Upon” study was completed.

The no-Called Upon study set the Canadian projects to their Flex operation in the A1 scenarios, the Canadian local flood control operation in B1, or the Canadian only power operation in the B2 scenarios.

In the Called Upon study, the Canadian projects were set to the same operation as in the no-Called Upon studies, except in those years when Called Upon was required by the U.S. In these years the Canadian operation was set to the requested Called Upon draft.

In both studies, the U.S. projects were operated according to existing SRDs in years where the Called Upon threshold was not exceeded and to an “effective use” operation in years where the threshold was exceeded.

Essentially, only the Called Upon years were different between each set of studies. Table 3-19 describes the Canadian operations in each set of studies. By performing a no-Called Upon and a Called Upon set of studies, the impact of Called Upon to Canadian and U.S. operations was assessed. The end result was a monthly difference in storage operations and generation between the Called Upon and no-Called Upon scenarios. For the purposes of the Phase 1 studies, no value was assigned or calculated for the generation differences.

Table 3-19 – Canadian Reservoir Operation Applied in Each Comparison

Description of Each Set	A1	B1	B2
No-Called Upon	Flex	Canadian local flood control	Canadian only power operation
Called Upon	Flex or Called Upon	Canadian local flood control or Called Upon	Canadian only power operation or Called Upon

Scenarios and Comparisons. The following sections focus on comparing the A1 and B2 studies to assess the impacts of Called Upon between a Treaty Continues scenario and a Treaty is Terminated scenario. The B1 study was also modeled in order to look at Called Upon needs under the Treaty is Terminated condition with a Canadian local flood control operation only. Each of the following graphs illustrates the impacts of Called Upon, plotting the Called Upon only years against the average 70-year values to show the relative differences between Called Upon and the overall 70-year set. For the 600 and 450 kcfs maximum flow objective at The Dalles, there were 21 and 52 Called Upon years, respectively. Caution should be used when interpreting the graphs and tables that compare the 70-year average data to Called Upon years, as the data is affected by the frequency of Called Upon years and the tendency for Called Upon years to have higher annual volume runoff.

3.5.2. CALLED UPON IMPACTS TO CANADIAN COMPOSITE STORAGE

Canadian composite storage in the Phase 1 studies is the combined total Treaty storage of Mica, Arrow, and Duncan reservoirs. Under a Treaty Continues scenario (A1), the maximum storage used was 15.5 Maf. However, in the Treaty is Terminated scenarios (B1 and B2), the full storage amount would be available for use. Therefore, under the Treaty is Terminated scenarios the full Canadian Treaty and non-Treaty³⁰ storage amount of 20.4 Maf was used. For the Canadian composite storage figures, when the storage value dropped below zero, the storage had been drafted below the Treaty storage total of 15.5 Maf and was drafting further into the full storage amount.

3.5.2.1. Cross-study Comparison – A1, B2 (Figure 3-16)


Because the methodology used to draft the Canadian projects for Called Upon was essentially the same for either the 600 kcfs or the 450 kcfs maximum flow objective (i.e., the same SRDs were used despite the differences in flood control flow objectives), all the Called Upon years drafted Canadian composite storage to roughly the same level.

Implementation of Called Upon resulted in a deeper draft of the Canadian composite storage than the draft for Canadian Flex operation (A1) or the Canadian power draft (B2) scenarios. In both scenarios, additional winter draft was required to create space for regulation of the spring runoff. Because the Canadian only power operation (B2) required less draft than the Treaty operation (A1), the Called Upon draft from the assumed Canadian project operations was more for the Canadian only power operation than the Treaty operation.

During the August to December period, any differences between the power and Called Upon operations were due to differences in the average power operations over 70 years versus over the Called Upon years only. There were no Called Upon operations during this period.

³⁰ Mica was constructed with more storage than is specified in the Treaty. The additional 5 Maf of storage is called Non-Treaty storage, and its use is managed under additional agreements between the Entities.

Figure 3-16 – Mica + Arrow + Duncan Storage Content (A1, B2)




3.5.2.2. B1 Scenarios (Figure 3-17)

Figure 3-17 shows the Canadian composite storage if the projects were operated to provide only local flood control protection in Canada compared with the implementation of Called Upon from Canadian storage by the U.S. for flood control. In the B1 studies, the Canadian local flood control maintains the Canadian composite storage relatively full until the March through June period, when there is a small draft and refill for local flood control. As expected, the Called Upon scenarios resulted in a deeper draft of the Canadian composite storage. Once again, due to the methodology used in the Phase 1 studies, the overall Called Upon draft of the Canadian composite storage was relatively close for the 600 kcfs and 450 kcfs maximum flow objectives at The Dalles.

Of interest, Canadian power draft with Called Upon under the Treaty is Terminated scenario (B2) drafted the Canadian composite storage deeper than the B1 scenario. In the B2 scenarios there was limited incidental flood control benefit from the Canadian power operation. In the scenario provided, most of the Canadian power draft came from Mica and was usually more than needed for U.S. flood control. The most effective Canadian storage for Called Upon is from Arrow; however, the preferred Canadian operation at Arrow was to keep it as full as possible year around. Because of this preferred operation at Arrow, the U.S. was frequently required to request Called Upon storage from Arrow to create needed Called Upon space. Therefore, the total Mica power draft plus the Mica and Arrow Called Upon draft in B2 was greater than the total Mica and Arrow Called Upon draft in B1. In essence, the Canadian preferred power draft

did not necessarily provide the specific space and location needed for the most effective use of Canadian storage for U.S. flood control.

Figure 3-17 – Mica, Arrow, Duncan Composite Storage Contents B1



3.5.3. CALLED UPON IMPACTS TO ARROW PLUS DUNCAN OUTFLOW

While flows across the border into the U.S. are a result of various outflows from Arrow, Duncan, Libby, Kootenay Lake, and the Pend Oreille River, the following looks at only the outflows from Duncan and Arrow to reflect the regulated changes specific to Canadian Treaty projects and operations.

3.5.3.1. Cross-study Comparison – A1, B2 (Figure 3-18)


The Canadian power operation provided for the Treaty is Terminated (B2) scenarios attempted to maintain Arrow as close to full as possible year around, resulting in a relatively steady outflow, on average, from Arrow and Duncan, with only a slight increase during the April-June period (dashed black line in Figure 3-18).

Under the Treaty Continues scenario (A1) the shape of the Arrow plus Duncan outflows was a result of an optimized, coordinated power draft and any Called Upon requirements, resulting in deeper winter storage drafts and higher releases in the January to March period (solid black line).

For the Treaty is Terminated scenarios (B2), the Arrow plus Duncan outflows mimicked the outflow shape of the Treaty Continues scenarios (A1) only when Called Upon was implemented. In fact, Called Upon years resulted in more dramatic seasonal swings than the A1 70-year

average, with even higher outflows in the winter and lower outflows during the runoff season or spring.

Figure 3-18 – Arrow plus Duncan Average Outflows (A1, B2)



3.5.3.2. Assessment of 20 Lowest January-July Volume Years


While Figure 3-18 provides an overall perspective of how Called Upon implementation increased Arrow plus Duncan outflows during the winter and decreased outflows during the spring or refill season, it does not show the overall impact to the Arrow plus Duncan outflows from low water years, when Called Upon is less of a factor in the operation of the system. Figure 3-19 shows the 20 lowest January-July volume years compared to the 70-year average power operations for the A1 and B2 scenarios. Even though this analysis examined the 20 lowest January through July runoff years, there was still one Called Upon year in the 600 kcfs flow objective set and five Called Upon years in the 450 kcfs flow objective set. This frequency was either relatively low (as in the 600 kcfs set) or of minimal impact due to a limited implementation of Called Upon during the year, as with the five cases at the 450 level (none of these years took Grand Coulee to empty at the end of April).

For the A1 studies with Called Upon flood control, the Arrow plus Duncan outflows in the 20 lowest years were, in general, less than the 70-year average power operation for January through May and higher the remainder of the year. Outflows still increased in the winter, but not to the level as with the full set of Called Upon years or as high as the power operation. There was little difference in outflows between the 450 kcfs and 600 kcfs flood control objectives.

For the B2 studies in the 20 lowest years, the 600 kcfs objective was relatively close to the 70-year power operation, generally maintaining a steady 35-45 kcfs outflow from Arrow throughout the year, despite low water conditions. At the 450 kcfs flood control objective, the Arrow plus Duncan outflows were much higher in January through March, and lower during April through June, but overall less than the 70-year power operation during this period. This difference in shape from the 600 kcfs objective is due to the influence of the five Called Upon years at the 450 kcfs flow objective.

Figure 3-19 – Arrow plus Duncan Outflows 20 Lowest Years (based on January-July Volume)


Arrow plus Duncan Outflows, kcfs												
Outflows for 20 lowest water years based on The Dalles Jan-Jul observed volumes												
kcfs	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL
A1 Power Operation (70-Year Avg)	65	54	40	41	40	62	47	30	20	28	42	58
A1F600 20 lowest (Pwr/CU)	64	57	42	46	46	54	33	25	20	20	67	52
A1F450 20 lowest (Pwr/CU)	64	57	42	46	46	57	35	26	19	19	64	51
B2 Power Operation (70-Year Avg)	47	44	42	41	43	44	43	41	38	44	53	47
B2F600 20 lowest (Pwr/CU)	49	45	47	39	41	45	41	39	36	40	42	35
B2F450 20 lowest (Pwr/CU)	44	44	44	40	41	60	56	50	30	22	34	41



3.5.3.3. B1 Scenarios (Figure 3-20)

Figure 3-20 shows the shape of Arrow plus Duncan outflows should the Canadian projects operate for local flood control only (black line). Both the 600 kcfs and the 450 kcfs maximum flow objectives resulted in relatively the same Called Upon outflows due to the methodology used in the Phase 1 studies.

Figure 3-20 – Arrow plus Duncan Average Outflow for B1



3.5.4. CALLED UPON IMPACTS TO GRAND COULEE RESERVOIR ELEVATION

3.5.4.1. Cross-study Comparison – A1, B2 (Figure 3-21)

For both the Treaty Continues (A1) and the Treaty is Terminated (B2) scenarios, implementation of procedures to make effective use of U.S. storage before requesting Called Upon caused Grand Coulee to draft substantially deeper during the Called Upon years compared to non-Called Upon years. Implementation of effective use caused Grand Coulee to draft to 1208 feet (minimum pool) 28-30 times out of the 52 Called Upon years for the 450 kcfs maximum flow objective at The Dalles and only 9-10 times for the 600 kcfs objective. Grand Coulee refilled in all years.


In non-Called Upon years, Grand Coulee’s flood control drafts were computed based on its SRDs. There were, however, some differences in how the simulation was conducted between scenarios A1 and B2. The difference in A1 and B2 70-year average elevation shown in Figure 3-21 is an artifact of the modeling and not a real difference between scenarios A1 and B2.

In Figure 3-21, all Called Upon years drafted Grand Coulee deeper than without Called Upon; however, the lowest point on the figure does not show Grand Coulee reaching 1208 feet on average for the Called Upon years only. This is because in some years Called Upon was either no longer required by the end of April or because refill was initiated prior to the end of April due to an early runoff.

Although Grand Coulee refilled in all years, reduced August outflows from Arrow plus Duncan in the Treaty is Terminated (B2) scenarios caused Grand Coulee to draft to meet power needs,

resulting in a lower Grand Coulee elevation starting in August and lasting until the beginning of the winter flood control draft period.

Figure 3-21 – Grand Coulee Average Month-Ending Elevation (A1, B2)




3.5.5. CALLED UPON IMPACTS TO CANADIAN GENERATION

3.5.5.1. Cross-study Comparison – A1, B2 (Figure 3-22)

Figure 3-22 shows the Canadian generation patterns for scenarios A1 and B2 with and without Called Upon, which is driven by the two distinct power operations used in each study—the Flex operation provided for A1 and the Canadian power operation provided for B2.

Figure 3-22 – Canadian Generation (A1, B2)

Canadian Generation* - aMW												
aMW	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL
A1Power Operation (70-Year Avg)	3861	3487	2601	3845	4534	4290	3025	2584	1885	2697	3013	3230
A1F600 21 Called Upon Years	4034	3565	2667	3630	4470	4584	3338	2942	2249	2793	3122	3323
A1F450 52 Called Upon Years	3950	3531	2621	3817	4514	4386	3172	2658	1972	2707	3081	3239
B2 Power Operation (70-year Avg)	3076	2979	3424	3622	3857	3696	3695	3933	2771	2767	3109	2701
B2F600 21 Called Upon years	2884	2774	3188	3573	3976	3768	3883	4102	3284	2849	3179	3055
B2F450 52 Called Upon years	3055	2921	3310	3608	3906	3681	3701	4052	2893	2717	3126	2873



*Canadian Generation includes: Mica+Revelstoke+Arrow+Corra Linn+U. Bonnington+L. Bonnington+South Slokan+Canal+Brilliant+Seven Mile+Waneta

Table 3-20 provides a summary of the generation differences due to Called Upon within each study. In general, annual Canadian generation losses due to Called Upon flood control operations were relatively small compared to the total generation. However, the monthly impacts within a given Called Upon year may be potentially much greater. For the Treaty Continues (A1) scenario, the average loss for Canadian generation was 24-27 aMW, ranging from a gain of 155 aMW to a loss of 191 aMW. The Treaty is Terminated (B2) scenario comparisons produced an average loss of generation of 60-73 aMW, showing the greater generation impact of Called Upon draft in B2 compared to A1. The range of impact varies from a gain of 545 aMW to a loss of 519 aMW.

In reality, the impact to the Canadian operation will be highly dependent upon the Canadian real-time power and non-power needs as well as market conditions. In order to fully understand the

impacts of Called Upon to Canadian generation, daily modeling with variable peak, heavy, and light load hour sub-time steps will be necessary

Table 3-20 – Canadian Generation Difference Between Called Upon and Non-Called Upon Scenarios

Study		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug ¹	Jan-Aug aMW for all CU Years ²	Years of Called Upon	70 year Annual Avg, aMW
Treaty Continues: Called Upon												
A1F600 (Flex)	Max	1	64	0	11	7	7	0	8			
A1F600 (Called Upon)	Average	-14	-25	-62	-32	-48	-28	-10	-1	-27	21	-5.5
	Min	-36	-114	-135	-77	-107	-118	-128	-15			
A1F450 (Flex)	Max	64	255	127	147	85	19	136	91			
A1F450 (Called Upon)	Average	-11	2	-58	-8	-41	-35	-24	2	-23	52	-11.4
	Min	-44	-139	-277	-131	-163	-156	-163	-61			
No Treaty: Called Upon, Canadian operation for power												
B2F600 (Canadian Power Op)	Max	0	194	37	10	3	2	65	27			
B2F600 (Called Upon)	Average	-68	-113	-119	-118	-103	-70	3	1	-73	21	-13.5
	Min	-407	-519	-184	-184	-178	-183	-6	-2			
B2F600 (Canadian Power Op)	Max	545	418	314	182	56	20	119	64			
B2F450 (Called Upon)	Average	-56	-60	-40	-75	-138	-79	-31	-3	-60	52	-30.2
	Min	-408	-519	-344	-214	-432	-241	-269	-84			
Generation differences = Called Upon Study - Base Case Study												
¹ Aug of next operating year												
² aMW values are for Called Upon years only												

3.5.6. CALLED UPON IMPACTS TO U.S. SYSTEM GENERATION

Figure 3-23 shows the U.S. generation patterns for scenarios A1 and B2. In the Treaty Continues scenario (A1), Called Upon shifted additional generation from spring into winter. Terminating the Treaty and relying on a Canadian power operation only (B2) resulted in significantly lower winter generation and higher spring generation for the U.S., essentially de-optimizing the U.S. power operation compared to the Treaty Continues scenarios (A1). Only after Called Upon is required in the Treaty is Terminated scenarios (B2) was there some reshaping of generation back into the winter; however, there was still relatively higher generation during the spring, a lower power value period.

Figure 3-23 – U.S. System Generation (A1, B2)




Table 3-21 provides a summary of the U.S. system generation differences due to Called Upon. The gain in annual average generation from Called Upon was small relative to total generation, ranging from 13 aMW to 60 aMW. The monthly impacts within a given Called Upon year can be much greater, as shown in Table 3-21.

Table 3-21 – U.S. System Generation Difference Between Called Upon and Non-Called Upon Scenarios


Study		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug ¹	Jan-Aug aMW for all CU Years ²	Years of Called Upon	70 year Annual Avg, aMW
Treaty Continues: Called Upon												
A1F600 (Flex)	Max	1360	2985	2971	3731	133	85	20	30			
A1F600 (Called Upon)	Average	503	780	220	377	-629	-362	-273	-8	68	21	13.5
	Min	-41	-1412	-2787	-970	-1797	-1442	-1724	-99			
A1F450 (Flex)	Max	2229	3005	2691	3019	136	325	676	204			
A1F450 (Called Upon)	Average	784	564	530	64	-688	-520	-362	14	42	52	19.6
	Min	-137	-1367	-1539	-1356	-2347	-3088	-1810	-99			
No Treaty: Called Upon, Canadian operation for power												
B2F600 (Canadian Power Op)	Max	2371	4640	3630	3976	0	20	315	0			
B2F600 (Called Upon)	Average	1197	1778	86	73	-1003	-1004	-17	0	124	21	28.0
	Min	0	-2711	-2606	-2153	-2232	-2694	-342	0			
B2F600 (Canadian Power Op)	Max	6035	9636	8201	4411	272	191	490	70			
B2F450 (Called Upon)	Average	1917	2857	1888	-289	-2401	-2295	-484	-5	127	52	59.4
	Min	0	-2571	-2834	-3586	-6216	-5921	-3953	-82			
Generation differences = Called Upon Study - Base Case Study												
¹ Aug of next operating year												
² aMW values are for Called Upon years only												

3.5.6.1. Assessment of 20 Lowest January-July Volume Years

While Figure 3-23 provides an overall perspective on how Called Upon implementation would provide a shift in energy from the spring into the winter months, it does not show the overall impact to U.S. generation when Called Upon is less of a factor in the operation of the system. Figure 3-24 shows the 20 lowest January-July volume years compared to the 70-year average power operations for the A1 and B2 scenarios. Even though this analysis examines the 20 lowest January through July runoff years, there was still one Called Upon year in the 600 kcfs flow objective set and five Called Upon years in the 450 kcfs flow objective set. This frequency was either relatively low (as in the 600 kcfs set) or of minimal impact due to a limited implementation of Called Upon during the year, as with the five cases at the 450 level (none of these years took Grand Coulee to empty at the end of April).

As expected, the results show that in low water conditions, the U.S. System generation was substantially lower than the 70-year average generation. Also, the A1 and B2 generation shape and magnitude were generally aligned, with the exception of the months of June and September, whether relying on a coordinated Treaty operation or an independent Canadian power draft.

Figure 3-24 – U.S. System Generation 20 Lowest Years (based on January-July volume)



3.6. 70-YEAR AVERAGE AND CRITICAL PERIOD GENERATION

The following section describes the general findings of the A1, B1, and B2 studies, on an average basis, with respect to 70-year average generation and U.S. Critical Period generation.

In this phase, the power impact studies were performed with a monthly time-step model using the monthly average Called Upon flood control flow. However, because the Called Upon and Canadian Flex operation are both daily operations, the monthly time-step study can provide only a rough estimate of the generation impact. Daily modeling with variable peak, heavy, and light load hour sub-time-steps would be a more appropriate tool for future study to estimate the impact on both daily energy and capacity.

3.6.1. 70-YEAR AVERAGE GENERATION

Table 3-22 shows the 70-year average generation for the Canadian projects, the U.S. Federal System, and U.S. Total System for each of the forecast scenarios from A1 (Treaty Continues), B1 (Treaty is Terminated with only Canadian local flood control), and B2 (Treaty is Terminated with a pre-defined Canadian power draft).

Table 3-22 – Generation by Scenario (70-year Average)

Study	70-Year Average Generation (aMW)		
	Canadian	U.S. Federal	U.S. System
<i>Treaty Continues</i>			
A1F600 (Pwr)	3258	9419	15322
A1F600 (Pwr/CU)	3253	9429	15336
A1F450 (Pwr)	3259	9417	15317
A1F450 (Pwr/CU)	3247	9433	15337
<i>No Treaty, CDN local</i>			
B1O600 (Pwr)³¹	2967	9327	15014
B1F600 (Pwr/CU)	3066	9420	15173
B1F450 (Pwr/CU)	3175	9501	15325
<i>No Treaty, CDN Power</i>			
B2F600 (Pwr)	3301	9498	15304
B2F600 (Pwr/CU)	3288	9518	15333
B2F450 (Pwr/CU)	3271	9516	15365

Table 3-22 provides the average annual generation for each scenario; however, the within-year variation between scenarios is much more dramatic. Table 3-23 shows these averages by month and comparing the Treaty Continues (A1) and Treaty is Terminated (B2) scenarios. In general, for the U.S. System there was a significant shift out of high-power need, high-value winter months (e.g., an average 2,619 aMW reduction in January U.S. System generation), into low-need, low-value freshet months (e.g., an average 3,036 aMW increase in June generation) when comparing Treaty is Terminated (B2) to Treaty Continues (A1). The similar average annual U.S. generation in scenarios A1 and B2 indicates that the Canadian operation reduced the same

³¹ B1F600 (Pwr) was not modeled. A power study was done for only the B1O600 scenario.

amount of spill at U.S. facilities whether the Treaty continues or is terminated. The value for U.S. power under Treaty Continues is the regulation of water from low power value periods to high power value periods.

In addition to the changes in generation at Canadian projects, U.S. Mid-Columbia utilities, and the U.S. Federal System, there were significant reductions in generation for U.S. Pend Oreille River projects and Idaho Power Company’s Middle-Snake River projects.

Table 3-23 – Monthly Differences between the Treaty is Terminated with Canadian Power Draft Scenario and the Treaty Continues Scenario (B2F minus A1F)

Canadian Generation, 70-year Average (aMW)

B2 – A1	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Avg
600 kcfs objective	-784	-508	823	-223	-653	-616	642	1329	860	52	83	-525	35
450 kcfs objective	-785	-511	825	-223	-679	-628	624	1363	835	0	63	-532	25

U.S. System Generation, 70-year Average (aMW)

B2 – A1	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Avg
600 kcfs objective	-141	-1814	-96	170	-95	-2619	-2544	399	2135	1446	3036	-27	-3
450 kcfs objective	-140	-1832	-104	163	-110	-2010	-1160	1288	1499	577	2164	-49	28

U.S. Federal Generation, 70-year Average (aMW)

B2 – A1	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Avg
600 kcfs objective	-357	-1074	0	298	162	-1612	-1480	433	1726	851	2245	-178	89
450 kcfs objective	-374	-1094	-7	294	125	-1114	-515	1046	1182	157	1480	-197	83

U.S. Mid-Columbia Utilities,³² 70-year Average (aMW)



B2 – A1	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Avg
600 kcfs objective	-52	-380	-30	-4	-15	-540	-621	73	432	66	462	23	-46
450 kcfs objective	-48	-383	-30	-4	-26	-272	-237	225	281	-101	372	23	-16

³² The non-Federal project owners, referred to as the “Mid-Columbias” due to the location of their dams on the Columbia River, which provide 27.5 percent of the agreed Canadian Entitlement energy return.

In addition to within-year variability, year-to-year variability can also be dramatic. Figure 3-25 is an example of the year-to-year variability for the B2 power operation scenario for U.S. System generation.

Figure 3-25 – 70 Years of U.S. System Generation Variability for A1F and B2F

U.S. System Generation Variability - aMW												
aMW	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL
A1F Power Operation (10 %ile)	11051	11036	9875	11269	12974	12518	11533	10499	10833	13552	14042	12524
A1F Power Operation (25 %ile)	11130	11101	9966	11379	13113	13306	12814	12667	11857	16635	14680	12638
A1F Power Operation (Median)	12199	11224	10114	11723	13287	18435	18121	15877	14886	19321	18890	16329
A1F Power Operation (75 %ile)	13889	12113	10611	13145	14483	20609	20114	19169	17635	22912	22505	20261
A1F Power Operation (90 %ile)	15566	13152	12354	16017	17775	23074	22086	20738	21026	24871	25036	22217
B2F Power Operation (10 %ile)	11966	9583	9651	11885	12769	13812	11544	11485	11414	11665	15140	11507
B2F Power Operation (25 %ile)	12013	9671	9763	12005	12891	13986	11774	11716	13579	19186	19128	11746
B2F Power Operation (Median)	12080	9732	9890	12239	13075	14220	11962	16551	17379	21965	23185	16126
B2F Power Operation (75 %ile)	12809	9839	10689	13077	15111	14558	16993	20779	20941	24328	25805	20961
B2F Power Operation (90 %ile)	13752	10544	12531	15630	16961	19252	20873	22952	23008	25956	27177	22471



3.6.2. CRITICAL PERIOD GENERATION

The Critical Period is the period in the historical streamflow record for the Columbia River System during which the least amount of electrical energy can be generated while fully drafting the reservoirs according to seasonal demands. It generally defines the generation capabilities of the system under low water conditions, typically referred to as the Firm Energy Load Carrying Capability (FELCC). The critical period for the A1 scenarios was August 16, 1929 - February 1932. For the B2 scenarios, the critical period was shorter: August 1, 1936 - April 15, 1937. The FELCC for the U.S. Federal and System generation also decreased between the B2 and A1 scenarios.

For Study B2 compared to Study A1 (Table 3-24):

U.S. Federal decreased by 139 aMW
 U.S. System decreased by 225 aMW

Although the hypothetical Canadian power operation under the B2 studies showed little change to the average annual U.S. generation, it reduced the U.S. firm energy capabilities, indicating a diminished FELCC under low water conditions. As well, the reduced critical period (from 4 years to 1 year) may impact power reliability during a prolonged dry sequence.

Table 3-24 – Study A and B2 Critical Period and Critical Period Generation

Study	U.S. Federal		U.S. System	
	Critical Period	CP Generation aMW	Critical Period	CP Generation aMW
A1 AOP (Joint Optimum)	Aug 16, 1929 - Feb 1932	7202	Aug 16, 1929 - Feb 1932	11909
B2 600 (Base Case)	Aug 1, 1936 - Apr 15, 1937	7063	Aug 1, 1936 - Apr 15, 1937	11684

4. SUMMARY AND KEY FINDINGS

The Phase 1 technical studies provided a broad range of information and data that required considerable assessment and evaluation. The outcomes were a result of not only the scenarios selected, but also the assumptions and the modeling methodologies employed. As a result, considerable review was required to understand these outcomes and results. This section is meant to summarize and focus on the key outcomes and conclusions from the Phase 1 studies.

4.1. CALLED UPON FLOOD CONTROL

- Regardless of whether the Columbia River Treaty continued after 2024, changes in flood control operations from the FCOP to Called Upon had significant effects on the operations of both U. S. and Canadian storage reservoirs.
- The frequency that Called Upon operations was required was driven by the procedure and maximum flood control objective at the Dalles, Oregon. Based on the assumed procedure and objectives used in these studies, Called Upon storage in Canadian reservoirs was needed 21 years (30%) out of 70 years for every scenario when the maximum flow objective at The Dalles was 600 kcfs, and 52 years (74%) when 450 kcfs was the maximum flow objective. The joint study team believes those results overestimated the frequency of Called Upon years. Refinement of models, assumptions, and evaluation criteria is recommended to better estimate the frequency and duration of Called Upon storage needs (see section 5). Although flow objectives of 600 kcfs and 450 kcfs were used in the studies, there are differences between the Entities with regard to interpretation of Called Upon rights and obligations, including flood control objectives.
- The volume of Canadian storage requested by the U.S. for Called Upon was significantly less under the Treaty Continues studies (approximately 1-1.5 Maf on average) compared to Treaty is Terminated. Under Treaty is Terminated, the (power or flood control) draft at Canadian projects had a major impact on the additional draft needed for U.S. flood control, and there was a wide range (generally 5-11 Maf) in the volume of storage that was required for Called Upon.
- Canadian Treaty storage was very effective in controlling flood events in the United States. In the Phase 1 studies, peak flow at The Dalles was the best measure of flood control effectiveness of the scenarios investigated. Peak flows varied little across all the scenarios in Called Upon years. However, this study outcome was due largely to the modeling methodology used in the studies. When Called Upon operation was triggered, Canadian and U.S. reservoirs were all drafted to the same volume regardless of maximum flow objective, and the regulation in the spring was similar. While this approach was effective in controlling flooding in the U.S., it may not represent the most efficient use of water and storage across multiple operating purposes. Other strategies and procedures for implementing Called Upon operations need to be investigated (see section 5).
- Most of the Called Upon draft was required from Arrow reservoir since it is the most effective Canadian reservoir for managing reductions in flows at The Dalles. Because of the deep power draft at Mica, Called Upon did not usually affect Mica, and similarly, had only a minor impact at Duncan.

- A cursory evaluation of the impacts of Called Upon and Flex operations on each other showed that it was physically possible to transition from a Flex operation to a Called Upon operation. However, having Mica on minimum flow (and therefore low generation amounts) for up to three months in winter in order to transition to a Called Upon operation poses a high risk to BC Hydro power reliability and may impact non-power requirements. The impact of Flex on Called Upon needs to be investigated further (see section 5).

4.2. POWER LOADS AND RESOURCES

- The projected loads used in all the Phase 1 studies showed an increase of 3,477 MW between 2013-14 and 2024-25 and an 8,420 MW increase from 2024-25 to 2044-45.
- To meet this load increase in the Phase 1 studies, resources were added during each forecast period. From 2014-15 to 2024-25, the majority of the load increase was met by renewables, primarily wind generation (2,563 MW). During the period 2025-26 through 2044-45, the majority was met through thermal generation (6,932 MW), with the remainder generally being met by wind (1,050 MW).
- The seasonal shape (month to month) of firm loads, imports/exports, and thermal resources is very important yet highly uncertain. The net result of these loads and resources is the Residual Hydro Load, which has a direct effect on the Canadian storage operation and the Canadian Entitlement.

4.3. LONG-TERM PLANNING (AOP)

- Called Upon flood control was assumed to be implemented in short-term and real-time planning and operations rather than in long-term planning such as the AOP. Therefore, flood control in this section does not refer to implementation of, or impacts from, Called Upon flood control requests.
- There were minor changes to the AOP operating criteria because of the use of Canadian local flood control rule curves. Grand Coulee's flood control curve was adjusted for Canadian power draft in the AOP, resulting in some impact on Canadian storage operation, but negligible impact on annual U.S. generation (+1 aMW). However, the change in monthly generation pattern is noticeable. This estimate of impacts may be an effect of the limited analysis, so the procedure needs to be reviewed in future studies. In general, the post-2024 flood control changes did not have a major impact on the AOP or DDPB modeling.
- On average, there were only minor differences in the monthly generation and operating criteria among scenarios A1, A2, and C, because the loads and resources were adjusted using imports/exports to produce the same Residual Hydro Load. The minor differences were due to the different flood control URCs used in each scenario. Other scenarios and factors that may change this Residual Hydro Load will need to be considered in the future to ensure an optimum power operation and to assess the impacts on the AOP and DDPB (see section 5).

4.4. DETERMINATION OF DOWNSTREAM POWER BENEFITS – CANADIAN ENTITLEMENT

- Based on the assumptions used, the Phase 1 studies indicated that Canadian Entitlement energy decreased from 472 aMW in 2025 to a minimum value of approximately 290 aMW by about 2040, as shown on Table 4-1. The Entitlement capacity increased from 1340 MW to 1524 MW, primarily due to a change in the length of the critical period.

Table 4-1 – Phase 1 Results for Canadian Entitlement

	AOP 14	C-2025	A-2025	C-2045
Entitlement Energy (aMW)	506	472	468	290
Entitlement Capacity (MW)	1340	1320	1320	1524

- The primary factors affecting the Canadian Entitlement Energy are the amount of load growth and type of new resources, especially the mix of thermal and renewable resources. There is a high level of uncertainty associated with these parameters. Less load growth and more renewable resources would reduce the need for thermal installations, and having less thermal generation would actually increase the Canadian Entitlement energy.
- A high degree of uncertainty remains regarding the future amount and value of the Canadian Entitlement and the operation of the hydro system. As the system transitions from an energy-deficit system to a capacity-deficit system, there could be different operating policies, such as maximizing FPLCC or average energy, or operating to market price or certain flows and reservoir elevations.

4.5. RESERVOIR IMPACTS

- Implementation of procedures to make effective use of U.S. storage caused the U.S. projects to draft substantially deeper during Called Upon years compared to current flood control operations.
- As shown on Table 4-2, implementation of effective use of U.S. projects with the maximum flow objective at 450 kcfs caused Grand Coulee to draft empty 28 to 30 times out of 70 years. Under the Treaty Continues with pre-2024 flood control (FCOP), only 4 years out of 70 required Grand Coulee to draft empty.

Table 4-2 – Called Upon Years vs. Years Grand Coulee at 1208 ft on April 30

	C2025 AOP	A1F600	A1F450	B1F600	B1F450	B2F600	B2F450
Total Called Upon Years		21	52	21	52	21	52
Years Grand Coulee is on Empty April 30	4	10	29	10	30	9	28

- Implementation of effective use of U.S. projects caused occasional refill failures (3 years at Libby, 6 at Hungry Horse, and 7 at Dworshak, but Grand Coulee refilled in all 70 years). While power draft of Canadian composite storage provided flood control benefits to the U.S., the Canadian reservoir elevations under either a Flex operation (A1) or a power operation (B2) often did not provide enough draft at Arrow for U.S. flood control.
- The Phase 1 studies examined Treaty planning and modeling as they pertain to power and flood control; however, impacts and results for many U.S. reservoirs were not necessarily representative of how the projects are actually operated because most U.S. reservoirs also include operations for fish and other non-power uses. Similarly, Canadian Flex operation for the Phase 1 studies was developed based on the current load-resource balance, market conditions, and other factors without any consideration of non-power and other environmental needs. If additional evaluations of the Treaty future and the impacts to U.S. reservoirs are undertaken, it is recommended that these evaluations consider applying non-power requirements to the results of the Phase 1 studies (see section 5).

4.6. ARROW PLUS DUNCAN OUTFLOWS

- Without a coordinated Treaty operation, the outflows from Arrow plus Duncan were more uncertain. Further work is needed to understand these uncertainties (see section 5).
- The Treaty is Terminated (B2) scenarios were intended to simulate a possible Canadian power operation. In this operation, Arrow plus Duncan outflows (without Called Upon implementation) were relatively constant across the year compared to the A1 Treaty power operations in order to minimize spill and maximize generation at Arrow. In comparison to Treaty Continues (A1), there was less flow in the winter and summer and more flow in spring.
- For the Treaty is Terminated studies (B2), the Arrow plus Duncan outflows mimicked the outflow shape of the Treaty Continues studies (A1) only when Called Upon was implemented, which required additional draft in the winter and less outflows during the refill period in the spring.
- In the Treaty is Terminated scenarios (B2), the reduction of Arrow plus Duncan outflows in August caused Grand Coulee to draft during the month and never recover toward full during the fall and early winter in most years. In the Treaty Continues scenarios (A1 and C), draft of Canadian projects for power maintained flows from Arrow during this period and allowed Grand Coulee to remain fuller.

4.7. GENERATION IMPACTS

- In the Treaty Continues scenarios (A1), the coordinated U.S./Canada assured power drafts provided substantial flood control benefits to the U.S., including more certainty and less additional volume of Canadian storage required as a direct result of a Called Upon flood control request.
- Overall, in the Treaty is Terminated scenarios (B2) the average annual energy production in Canada and the U.S. remained essentially unchanged in comparison to the A1 studies;

however, the monthly shape differed dramatically from the coordinated operation found in the Treaty Continues scenarios.

- On average, the B2 scenarios shifted generation from high-value winter months to low-value spring freshet months, with the exception of Called Upon years where the flood control Called Upon operation reshaped the generation into the winter and out of the spring.
- On average, the Canadian generation impacts due to Called Upon flood control operations were relatively small compared to their total generation. Actual impacts to the Canadian operation will be highly dependent on the Canadian real-time power (both energy and capacity) and non-power needs and market conditions.
- Under the Treaty is Terminated scenarios (B2), the ability of the U.S. hydro system to meet firm loads in the critical water year diminished by approximately 225 aMW. In addition, the Critical Period was shortened from 4 years to 1 year, which may be of concern during prolonged low inflow conditions.

5. RECOMMENDATIONS FOR FUTURE STUDIES

5.1. INTRODUCTION

While the Phase 1 studies provided valuable information and knowledge about the modeling and evaluation of various post-2024 Treaty and Called Upon scenarios, they also generated as many questions as they answered. From the beginning of this effort, the Phase 1 studies were designed to be the initial steps toward understanding some of the implications of the post-2024 provisions on power and flood control. However, it was clear as work progressed that other possible approaches, assumptions, alternatives, and scenarios would need to be considered for future studies and phases. This section describes some of the areas and issues that were discussed for possible future consideration. There is, however, no commitment at this time by the Entities to conduct such studies or to work jointly in conducting any additional studies.

The following discussions have been grouped into two categories. Section 5.2 deals primarily with how to model and approach various issues. It is focused on modeling techniques, procedures, and implementation. Section 5.3 addresses possibilities for expanding the focus of the Phase 1 studies by examining influences and uncertainty beyond the focus of the original studies.

5.2. PROCEDURES AND METHODOLOGIES

5.2.1. CALLED UPON FLOOD CONTROL

As described in this report, a number of modeling methods and procedures were developed and used in the Phase 1 studies to evaluate the alternative scenarios. Lessons were learned regarding the use of those methods that can be applied to any future studies and possibly to implementation of Called Upon operations after 2024. In summary, the Called Upon procedures as used in the Phase 1 studies will need to be refined, or an entirely new procedure may be developed in any future studies.

5.2.1.1. Called Upon Trigger

For future studies of Called Upon flood control operations, the concept of using a predetermined maximum flow objective and how that objective may be used to calculate Called Upon storage requirements will need to be reevaluated. It is possible that a trigger may be developed that is not directly tied to the flow objective. For example, a higher trigger runoff volume may be selected based on examination of results of the Phase 1 studies. The Called Upon trigger runoff volume may be tested in forecast studies to see the resulting performance. Given forecast runoff volume and inflow shape uncertainty inherent in forecast studies and real operations, it is assumed that the system cannot reduce flows to below 450 kcfs in all years. While it can reduce flows to below 600 kcfs more often than to 450 kcfs, there are infinite possibilities of hydrologic occurrences that are not captured in the 70-year period studied. We therefore cannot say that the system will always be able to be regulated to a maximum flow of 600 kcfs. We also note that

there are differences between the Entities with regard to interpretation of Called Upon rights and obligations, including flood control objectives.

5.2.1.2. Canadian Called Upon Draft Volume

The Corps concluded that the Called Upon draft procedure used in the Phase 1 studies frequently drafted Canadian reservoirs deeper than needed for flood control. In order to be able to operate the system to a regulated peak flow at The Dalles that is closer to the maximum peak flow objective, a procedure will need to be developed to reduce Called Upon draft volumes when Called Upon is triggered, and to increase the trigger runoff volume so that Called Upon is not triggered as frequently. The goal will be to deviate from planned Canadian operations as little as possible. Based on the preliminary studies, future studies will refine draft volume requirements by changing the sliding scale using appropriate flood risk analysis studies. A new Called Upon SRD may be required for implementing the Called Upon procedure.

5.2.1.3. Priority of Drafting Canadian Projects

For purposes of meeting flood control objectives at The Dalles, Arrow is the most effective Canadian reservoir for reducing flows, because the response time from Arrow to The Dalles is shorter than from Mica and Duncan to The Dalles. However, the local flood control needs at Revelstoke and downstream of Arrow can usually be met by the assumed power draft operation at Mica (generally, operating Arrow reservoir at elevation 1442 feet, two feet from full, is adequate to dampen the daily flow fluctuations). The priority of which Canadian reservoir to draft first under Called Upon varied between the scenarios.

Further evaluations are needed to determine the allocation of flood control space between Canadian reservoirs that will cost-effectively meet flood control needs while also considering other project purposes.

5.2.1.4. Return of Canadian Projects to Planned Operation After Called Upon

After 2024, the U.S. will be required to reimburse Canada for any operating costs and economic losses incurred whenever Called Upon flood control operations are implemented. Therefore, a critical element of Called Upon implementation will be clearly defining when that action is initiated and when it has been concluded and the Canadian reservoirs have been returned to their planned operations. In the Phase 1 modeling, the Canadian reservoirs returned to their planned operation as soon as possible by releasing minimum flow. In real operations, this may or may not be desirable, depending on the project purposes at the time of the return. For future studies to develop implementation of Called Upon operations, it would be necessary to clearly define procedures for returning Canadian projects to planned operation after Called Upon and criteria for documenting when Called Upon operation is initiated and completed, as well as defining what is meant by economic loss in the Treaty.

5.2.1.5. Runoff Volume Forecast Changes in Called Upon Years

In some years, the runoff volume forecasts fluctuated from month to month above and below the runoff volumes that trigger Called Upon flood control operations. The resulting flow fluctuations may be undesirable for purposes other than flood control, such as fish operations. Refinements in how Called Upon is implemented for years when forecasts are close to the trigger runoff volume need to be developed to reduce highly fluctuating outflows. It may be possible to develop a sliding scale runoff volume trigger to be used such that the smaller the difference of the forecast runoff volume to the trigger runoff volume, the less the reservoirs will draft in January or wait until February to initiate drafting. However, this trigger could cause other problems, such as causing undesirable high flows at The Dalles if a winter flood event were to occur. Future studies could include a range of alternatives to be evaluated with an objective of reducing the flow fluctuations, and discuss tradeoffs between those alternative approaches.

5.2.1.6. Establish Strategies for Prioritizing Between Winter and Spring Flood Control

Modeling to control for winter flood events was not a primary objective for the Phase 1 studies; however, it was discovered that by regulating projects using the assumptions that were developed, Called Upon drafts increased flows to what might be considered undesirable high levels in the winter period. In future studies, strategies for Called Upon flood control operations could prioritize between 1) reducing winter flood flows caused by Called Upon drafts in addition to winter rain events and 2) operating to meet Called Upon draft requirements for spring flood risk management.

5.2.1.7. Canadian Local Flood Control

The daily Canadian Local Flood Control operations provided by BC Hydro for the Phase 1 studies do not take into account power and non-power requirements or necessarily reflect the project physical limitations. Future studies should likely improve the accuracy and reflect the operational capability of the projects.

5.2.1.8. Called Upon Operations and Flex Operations Impacts

In scenarios where the Treaty continues after 2024, Canada may flex operations between Arrow and Mica (shift storage of water between reservoirs) subject to maintaining the same border flow. A cursory evaluation of impacts of Called Upon and Flex operations on each other shows that physically it could be possible to transition from a Flex operation to a Called Upon operation. However, having Mica on minimum flow for up to three months in winter poses a high risk to BC Hydro power reliability and may impact non-power requirements. Further investigation is required on how much Flex operation can impact the Called Upon operation.

5.2.1.9. Knowledge and Assurance of Canadian Operations

If the Treaty is terminated, and without other agreements for coordination of the Columbia River operations, the U.S. will have greater uncertainties in planning for flood risk management operations. The greater the degree of assured future Canadian power drafts, the greater the

ability the U.S. will have to manage flood risk, especially the ability to reduce the risk of flooding even in moderate runoff volume years. For effective flood risk management, the U.S. needs a forecast throughout the year of the planned Canadian reservoir operations. In future studies, and under the assumption the Treaty is terminated after 2024, the U.S. will need to make estimates of various scenarios of likely Canadian operations and assess risks and consequences of various scenarios, developing operating criteria based on those assessments.

5.2.1.10. Drafting of all Effective Storage at Related U.S. Projects

Only the U.S. headwater projects (Libby, Dworshak, Hungry Horse) that currently have defined SRDs were operated to the effective use procedure. Grand Coulee and Brownlee reservoirs were drafted toward empty in a year when Called Upon was triggered. It is possible that other projects may also be able to provide some degree of flood protection, but this possibility should be investigated in the future.

5.2.1.11. Economic Loss and Canadian Operating Costs of Called Upon

The Phase 1 studies did not attempt to develop methods or procedures for calculating operating costs and economic loss associated with Called Upon operations after 2024 or to estimate those costs under the Phase 1 scenarios. In addition, no attempt was made beyond modeling assumptions to develop criteria for identifying when a formal Called Upon operation begins to affect Canadian reservoir operations and when those operations have returned to normal. Such criteria will be essential for accounting for the costs of Called Upon. Agreement between the Canadian and U.S. Entities as to acceptable methods, procedures, and criteria will be critical to evaluating the benefits and costs of future Called Upon alternatives and to finalizing implementation of Called Upon operations.

5.2.2. ONGOING CORPS OF ENGINEERS FLOOD RISK ASSESSMENT

As noted in previous sections, significant additional evaluation beyond the Phase 1 studies is required to fully understand the potential implications of post-2024 Treaty changes on flood control operations in the Columbia River Basin and to further develop procedures for implementing Called Upon flood control in a manner consistent with the Treaty. In support of the U.S. Entity, the Corps of Engineers has initiated a comprehensive Flood Risk Management study. Only the initial phase of that effort, called Flood Risk Assessment (FRA), has been scoped in any detail. The Corps initiated work on the FRA phase of studies in 2009 and plans to complete it in 2011. The objective of FRA is to collect and update data and develop models and other analytical tools needed to evaluate flood risk under existing and base conditions. It is expected that the updated information may be used to evaluate the flood risk associated with alternative approaches to future implementation of Called Upon; however, alternatives beyond those evaluated in Phase 1 have not been formulated at this time. FRA will include the collection of existing information to calculate damages currently prevented in floodplain areas of the Columbia River and tributaries influenced by Treaty storage. The ultimate objective of the FRA is to collect and manage data and information and develop the tools necessary to produce quantifiable estimates of flood control benefits and costs associated with alternative Treaty scenarios.

The Phase 1 studies followed deterministic approaches to evaluating future Called Upon flood control operations. In accordance with U.S. policies and guidance,³³ future flood risk management studies conducted by the Corps will attempt to follow more probabilistic, risk-based approaches to studying system flood management. The ultimate goal of this risk-based evaluation is to complete a comprehensive approach in which the values of all key variables, parameters, and components of flood damage reduction studies are subject to probabilistic analysis. The risk analysis should concentrate on the uncertainties of the variables having a significant impact on study conclusions. At a minimum, the following variables must be explicitly incorporated:

- The stage/damage function for economic studies, with special emphasis on first floor elevation, depth-percent damage relationships, and structure and content values for urban areas
- Discharge associated with exceedance frequency for hydrologic studies
- Structural and geotechnical performance of existing structures

Global climate change considerations are critical to development of the base condition and evaluation of alternatives. Regional expertise should be used to determine climate change conditions “most likely to occur,” which then will need to be incorporated into the base condition. Assumptions regarding potential variations in climate change could be tested in various alternatives. Other considerations that will be critical to accurately defining “base condition” for a flood risk management perspective include estimates of future population growth and development in the floodplain.

Based on the findings and conclusions of the Phase 1 studies and other related evaluations, a number of preliminary assumptions can be drawn regarding considerations that should be incorporated into formulation and evaluation of flood risk management scenarios for further study.

The Phase 1 studies looked at a narrow range of flood control strategies that focused on Canadian Storage. In order for the U.S. to determine the most cost-effective solutions for flood control in the U.S. after 2024, alternatives that compare and contrast Called Upon Canadian storage against other flood risk management measures must be evaluated. Other measures may include local flood control improvements (e.g., levee upgrades), changes to operation of U.S. storage facilities, additional U.S. storage, and others.

5.2.3. CAPACITY CREDIT LIMIT

The Treaty defines an Entitlement capacity maximum limit based on the difference in Firm Load Carrying Capability (FLCC)³⁴ of the Base System and thermal installations with and without

³³ Engineer Regulation (ER) 1105-2-101 (January 3, 2006); Risk Analysis for Flood Damage Reduction

³⁴ Firm load carrying capability (FLCC) is either the firm energy or firm peak load carrying capability (whichever is critical).

Treaty storage. Using current procedures, the limit is much greater than the forecast Entitlement capacity for 2024-25 and 2044-45 and therefore is not an issue in the Phase 1 studies. However, as loads grow and an increasing amount of renewable resources are added, the region is likely to transition from an energy-deficit to a capacity-deficit system. This will require changes to procedures for determining FLCC and reserves that may cause the CCL to apply. There will also be many questions on how the system should be operated during and after the transition to a capacity-constrained system and what the power objective should be.

5.2.4. ADDITIONAL POWER STUDIES

The Phase 1 studies did not look closely at optimizing the operating criteria through critical period studies, refill studies, or other analysis. Future studies could explore methods to optimize FLCC and secondary energy production. In addition, other areas that were not considered or analyzed in detail in the Phase 1 studies were alternative scenarios for loads and resources, ability to meet peak loads, system reliability, the value of power, and the tradeoffs between power and non-power objectives.

5.3. SCENARIOS

5.3.1. NON-POWER AND NON-FLOOD CONTROL USES

Analysis of the benefits and impacts associated with the alternative scenarios described in the Phase 1 studies was strictly limited to the two primary purposes authorized under the Treaty—power generation and flood control. No attempt was made to evaluate the future effects of the Phase 1 scenarios on other operating purposes and benefits of the Columbia River system, including but not limited to fisheries, wildlife habitat, recreation, irrigation, water supply, water quality, and navigation. The Canadian and U.S. Entities recognize that evaluation of the potential impacts of system operations on these other operating purposes will be a critical consideration for future phases of study conducted under the Columbia River Treaty Review. The U.S. and Canada will seek input from regional interests, stakeholders, and sovereigns to define these additional scenarios for analysis.

5.3.2. CLIMATE CHANGE – PHYSICAL IMPACTS

The potential effect of global climate change on river hydrology and the benefits and operations of the Columbia River system in Canada and the U.S. is an important regional consideration. Both nations have initiated joint and independent evaluations of the potential impacts of climate change on the timing and volume of precipitation in the Columbia River Basin. Evaluations of possible impacts on reservoir system operations have not been incorporated into the Phase 1 studies but could be considered in any future Columbia River Treaty Review studies.

5.3.3. CLIMATE CHANGE – GREEN ENERGY

Part of the climate change picture is the physical system changes (e.g., streamflows, temperature) discussed above; however, another important aspect of climate change is the role of hydropower in the resource portfolio of the region. Regional and national policy is emphasizing clean and renewable resources as part of the resource mix for the future. If minimizing the carbon impact of thermal generation is the primary objective, then maximizing hydropower energy production would require significant changes to Canadian and U.S. project operations. In addition, other renewable resources, such as wind, affect the calculation of the DDPB, the resulting Canadian Entitlement, and operation of the hydro system in the AOP. Examining the role of hydropower and the Treaty in the overall picture and approach to reducing carbon emissions for the future may be another facet of future modeling.

5.3.4. RANGES OF UNCERTAINTIES

Capturing the uncertainty surrounding all aspects of the future is perhaps the biggest challenge in understanding the post-2024 Treaty world. For example, the Phase 1 studies used one set of assumptions for loads and resources for all scenarios. Future work may include performing sensitivity studies assessing the impact of changes in the loads and resources mix in the AOP, which can affect Canadian storage operation and the Canadian Entitlement. Another example is looking at additional scenarios to assess border flows absent the Treaty. The Phase 1 studies looked at two scenarios with emphasis on power generation and flood control, which did not explore the entire range of possibilities. These are just a few examples of additional scenarios that could be looked at in future studies.

Columbia River Treaty

2014/2024 Review • Phase 1 Report

APPENDICES

July 2010



Canadian and United States Entities

This page intentionally left blank

Disclaimer

The scenarios included in this Phase 1 Report are identified for analysis purposes only and do not represent a determination, decision, or commitment of either the Canadian Entity or the U.S. Entity or their respective governments concerning any particular position, operation, or other course of action. Furthermore, notwithstanding anything contained in this Phase I Report, assumptions used in developing the Phase 1 Report scenarios do not represent the future expected position, interpretation, or perspective on any matter of either Entity or its respective government.

Nothing in this report (including the studies undertaken) sets a precedent or implies agreement by either Entity concerning interpretation of Treaty rights and obligations. In addition, nothing in this report, or actions taken by the Entities and their representatives in preparing this report, represents a past practice or procedure or constitutes a Treaty modification or interpretation that prejudices, changes, or waives in any way Treaty rights and obligations. In preparing this report, the Entities have agreed that:

- Participating in this report is not to be considered as an acknowledgment or admission by either Entity of facts, rights, or obligations that may be implied by preparing the report, any assumptions used in the report, or the results of the report.
- No operating response identified by an Entity as a possible or likely response to any condition is an admission of the required response or is to be considered to limit options that may be available to the Entity or to affect or limit the response of the Entity.
- No assumption used in this report shall be considered to be an acknowledgment or admission by either Entity of facts, rights, or obligations that may be implied by any such assumption used in the report, and each Entity reserves the future right to challenge any assumption, notwithstanding its use in this report.
- Neither Entity makes any representation or warranty concerning assumptions, inputs, or responses provided to the other Entity in conducting the Phase 1 studies.
- Failure of an Entity to object to an assumption or operating response in this report is not to be considered acceptance of that assumption or operating response.
- Report results are non-binding on the Entities and without prejudice.
- The absence of any scenario, alternative, curve, or similar output in this report is not to be considered an acknowledgment that such scenario, alternative, curve, or output is not valid or relevant to the 2014/2024 Columbia River Treaty Review.

The Treaty does not provide detailed procedures for Called Upon, and there are differences between the Entities with regard to interpretation of Called Upon rights and obligations, including flood control objectives (e.g. 600 kcfs or 450 kcfs). Thus, on a without prejudice basis, two different flow objectives were simulated to provide information regarding a potential range of future operations.

This page intentionally left blank

APPENDIX A

CURRENT METHODOLOGY

This page intentionally left blank

APPENDIX A. CURRENT METHODOLOGY

TABLE OF CONTENTS

A.1 Introduction 1
 A.1.1 Flood Control Operating Plan 1
 A.1.2 Power Operating Plans 2
 A.1.3 Real-time Operations 3
 A.2 System Flood Control..... 3
 A.2.1 Flood Control Objective..... 3
 A.2.2 Reservoir Categorization..... 5
 A.2.3 Overview of Seasonal Flood Control Operation 7
 A.2.4 Reservoir-Specific Flood Control Strategies Used in Development of Real-Time Flood Control Rule Curves..... 8
 A.2.5 Details of Refill Period 14
 A.2.6 On-Call Flood Control (Pre-2024) 16
 A.3 Assured Operating Plan and Downstream Power Benefit Computation 17
 A.3.1 Overview 17
 A.3.2 Step I, II, III Descriptions 20
 A.3.3 System Regulation Studies and Associated Rule Curves 22
 A.3.4 Input Data to the AOP Process..... 27
 A.3.5 Step I AOP Process 28
 A.3.6 Calculation of Downstream Power Benefits and Canadian Entitlement 31
 A.3.7 Capacity Credit Limit..... 32
 A.3.8 Simulation Model..... 32
 A.4 Detailed Operating Plan 33
 A.4.1 Overview..... 33
 A.4.2 DOP 70-Year Studies..... 34
 A.4.3 System Regulation Study 34
 A.4.4 Implementation of the Detailed Operating Plan..... 34

Tables

Table A.1. Characteristics of each hydroelectric study 1
 Table A.2. Flood Control Objectives in Canada (2003 FCOP) 4
 Table A.3. Flood Control Objectives in the United States (2003 FCOP) 5
 Table A.4. Reservoir Categories for Flood Control..... 6
 Table A.5. Reservoir Evacuation Requirements..... 7
 Table A. 6. Forecast of Unregulated April through August Runoff Volumes in Millions of Acre-feet at The Dalles 16
 Table A. 7. Summary of Assured Operating Plan and Downstream Power Benefit System Regulation Studies 19

Figures

Figure A.1. Example Libby Storage Reservation Diagram 9
 Figure A.2. Example Grand Coulee Storage Reservation Diagram..... 10
 Figure A.3. Process Diagram..... 20
 Figure A.4. Illustration of Critical Rule Curves 24
 Figure A.5. How each system regulation study is used in the Step I process 30

This page intentionally left blank

APPENDIX A. CURRENT METHODOLOGY

A.1 INTRODUCTION

Appendix A describes how planning studies and real-time operations for flood control and power generation are currently conducted under the existing Treaty. The purpose of this appendix is to provide a basis on which the study methodologies applied in Phase 1 can be compared and understood. In most of the Phase 1 scenarios, the modeling either paralleled or modified how the current planning and real-time implementation occur.

The overall purpose of Treaty planning and implementation studies is to provide for an assured operation to meet flood control requirements and optimize power production for the Columbia River basin across a range of historical or forecast streamflow conditions. The Treaty directs the Entities to develop a flood control operating plan and hydroelectric operating plans for Treaty storage provided by Canada at Mica, Arrow, and Duncan reservoirs (Canadian storage). The Treaty is specific that these plans must be designed to achieve optimum power generation in both the U.S. and Canada and reflect only the requirements included in the Treaty, its Annexes and Protocol, and subsequent Entity Agreements. Characteristics of each hydroelectric study, planning and real-time, are explained below and summarized briefly in Table A.1.

It is important to note that in both planning and real-time operations, flood control requirements are examined first and applied as a limit to power operations planning and real-time studies. Although priority is always given to achieving minimum flood control objectives, the two objectives of flood control and power are often complementary, as the evacuation and refill of reservoirs provides benefits for both.

Table A.1. Characteristics of each hydroelectric study

Study	Type	Modeling Horizon	Mode	Water Supply/ Streamflow Input
Assured Operating Plan (AOP)	Planning	6 years	Observed	Historical
Detailed Operating Plan (DOP)	Planning	1 year	Observed	Historical
Treaty Storage Regulation (TSR)	Real-time	Within Year	Forecast	Observed and In-Season Forecast

A.1.1 FLOOD CONTROL OPERATING PLAN

The purpose of Columbia River system flood control is to achieve the desired local and system flood control objectives in the United States and Canada. Design of the system flood control is focused on reducing flows at the Columbia System reference point at The Dalles, Oregon. In

general, meeting system flood control objectives at The Dalles will most likely result in adequate control at other flood damage areas in Canada and the United States.

The Canadian storage is an integral part of the overall Columbia River reservoir system, and it is used in coordination with the U.S. storage to achieve system flood control objectives. The Treaty Flood Control Operating Plan¹ (FCOP) prescribes criteria and procedures for operation of Mica, Duncan, and Arrow reservoirs to achieve the flood control objectives. Libby reservoir is included in the FCOP to meet the Treaty requirement to coordinate Libby's operation for flood control protection in Canada and for the system. The U.S. Corps of Engineers ensures that the principles and operating criteria within the FCOP for Treaty storage are consistent with the overall system flood control for the Columbia River. Operations for flood control at Grand Coulee and other U.S. reservoirs are described in their respective Water Control Manuals and are not explicitly described in the FCOP. Charts 2, 3, and 6 of the FCOP do, however, refer to Grand Coulee and other U.S. reservoirs.

The FCOP provides guidance for both real time operations and flood control planning studies. Flood control requirements used in power planning studies are derived from observed mode (see section A.1.2) system flood control regulation studies. These flood control constraints are then transferred to the power operating plans.

A.1.2 POWER OPERATING PLANS

An Assured Operating Plan (AOP) is prepared annually for the sixth succeeding operating year. The AOP provides a guaranteed default operation that enables orderly planning of the power systems in Canada and the U.S., which are dependent on and coordinated with the operation of Treaty storage. The AOP is prepared in conjunction with the Determination of Downstream Power Benefits (DDPB). The Canadian Entitlement to downstream U.S. power benefits is one-half of the computed DDPBs.

Immediately prior to each August through July operating year, a Detailed Operating Plan (DOP) is developed from the AOP for that operating year. The DOP may reflect any changes mutually agreed upon by the Ent and may be updated with more recent project operating criteria or information. The DOP, together with the FCOP, serves as a guide and provides criteria for actual operation of Canadian storage. The DOP development process does not change the Canadian Entitlement amounts agreed to in the AOP/DDPB, regardless of any changes in the operating criteria.

Both the AOP and DOP studies for Treaty operation are conducted in *observed mode*. In observed mode, reservoir regulation decisions are made with assumed perfect foresight of all future runoff volumes and inflows across the entire Columbia Basin. Modelers are able to draft reservoirs to the proper elevation to refill the system at the correct rate and time to maximize

¹ The initial development of the FCOP for Canadian storage began in 1965, with a draft completed in 1968. In 1971 the FCOP was updated and modified to reflect changed conditions since 1968 while preserving the essence of the original draft. The revised version was reviewed in 1972 by the Columbia River Treaty Operating Committee. Revisions to the 1972 FCOP occurred in 1999 and 2003.

power production, avoid spill, and limit the peak flow at The Dalles. Observed mode studies are a relatively simple and fast way to perform regulation studies; however, forecast uncertainty is not addressed in these studies.

A.1.3 REAL-TIME OPERATIONS

During the operating year, the Entities perform a Treaty Storage Regulation (TSR) study at least twice per month. The TSR studies are conducted in *forecast mode* using existing reservoir conditions and forecasts of monthly and seasonal inflows. The TSR uses these forecasts, in conjunction with the rules governing Canadian storage operation outlined in the DOP and FCOP, to determine the end-of-month storage levels for Canadian storage. This information is then used by the Entities to determine the coordinated weekly Treaty storage operation.

The flood control component of TSR studies is the only type of Treaty study that incorporates the risk and uncertainty associated with forecasting future water supply, streamflows, and resultant operations. In forecast mode, the modelers apply the historical forecast errors to determine the drawdown of the reservoirs for flood control, thus incorporating uncertainty and error into the modeling of the system.

A.2 SYSTEM FLOOD CONTROL

A.2.1 FLOOD CONTROL OBJECTIVE

The basic objective in the 1972 FCOP for flood regulation is to operate reservoirs to reduce the river stages, at all potential flood damage areas in Canada and the United States, to non-damaging levels insofar as possible. Larger floods that cannot be controlled to non-damaging levels are reduced to the lowest possible level that the available storage space allows.

In the 1972 FCOP, major flood damage levels were identified at different locations within the Columbia Basin in both Canada and the United States. Elevations where damage commences were also identified and are used as the flood control objectives in the FCOP. The terms “Major Damage” and “Damage Commences” are relative descriptors that do not have standard definitions. Development has occurred throughout the Columbia Basin so that damage now commences at elevations lower than those identified in the FCOP. For example, flood damages are reported to occur in the lower Columbia River downstream of Vancouver at flows as low as 200 kcfs as measured at The Dalles.² Damages in Nelson, B.C., occur when Kootenay Lake reaches 1750 feet, and significant damage occurs at 1755 feet.³ Flood damage levels will be confirmed as part of the Flood Risk Management Study.⁴

The flood control flows and stages of interest locations in the 2003 FCOP are provided in Tables A.2 and A.3 below. In the U.S., changes to a project’s authorized level of protection (as

² This result was reported in “Columbia River System Operation Review Final Environmental Impact Statement,” Appendix E, dated November 1995; however, this is a very low flow, and this reported damage level needs to be confirmed and re-evaluated.

³ “Kootenay Lake West Arm: Stage-Damage Relationship Development,” dated 28 November 2005.

⁴ See section 5.2.2 of the main report.

defined in the project’s congressional authorization) cannot be made without congressional approval and completion of a comprehensive study addressing the impacts to local and system flood control and necessary operational changes.

In the United States, the National Weather Service has the authority (given to it by the U.S. Congress) to issue all flood warnings in the United States and to set the river stages at which these warnings will be issued. Flood warning levels are often the same as or slightly below an elevation considered to be zero damage levels. Flood control zero damage stages are determined by the National Weather Service local forecast office after consultation with the interested local community, the project owner, and the project regulator. In general, a flood warning level may be lowered in response to deterioration in the condition of a levee or if stream channel hydraulic characteristics have changed such that a stream is no longer able to convey the same amount of flow for a certain stage. For example, at Bonners Ferry, two flood warning changes were requested and made—first down to a stage of 1766.5 feet from 1770 feet and later to 1764 feet.

Table A.2. Flood Control Objectives in Canada (2003 FCOP)

	Major Damage	Damage Commences
Revelstoke ^a	1,450 ft (200 kcfs with Arrow @ El 1446 ft)	
Castlegar ^b	1405 ft	1400 ft
Trail ^c	1,352 ft 280 kcfs	1,347 ft @ old highway bridge 225 kcfs @ Birchbank
Creston ^{a,d}	1,763 ft	
Nelson ^a	1759 ft	1755 ft

- a. Elevations based on Geodetic Survey of Canada (GSC) 1961 data.
- b. It is assumed that if flood control requirements at Trail are met, flood protection is also achieved at Castlegar.
- c. GSC 1951 data.
- d. It is assumed that if the stage at Bonners Ferry is controlled to 1770 feet, flood protection at Creston will be achieved.

Table A.3. Flood Control Objectives in the United States (2003 FCOP)

	Major Damage	Flood Stage as defined by the National Weather Service
Vancouver, Washington ^a	24 ft NGVD 22.2 ft, Columbia River Datum 600 kcfs @ The Dalles	17.8 feet NGVD 16 feet, Columbia River Datum 450 kcfs @ The Dalles
Bonnars Ferry, Idaho ^{b, c, d}	1774 feet NGVD	1764 ft NGVD (~50 kcfs when Kootenay Lake is at 1750 ft NGVD)
Hanford, ^e Washington (mid Columbia)		400 kcfs as measured at the Priest Rapids project

- a. 1959 USGS adjustment.
- b. The river stage at Bonners Ferry, Idaho, is influenced by the backwater effects of Kootenay Lake and the amount of flow in the Kootenai River.
- c. Originally, flood damage began at 1770 feet NVGD (approximately 75,000 cfs when Kootenay Lake is at 1750 feet NGVD), and the authorization of Libby and its associated water control plans were designed to this stage.
- d. In some years local inflow downstream from Libby Dam may cause the flood stage of 1764 feet to be exceeded so that control to this limit will not always be possible.
- e. The regulation required for The Dalles normally will also achieve the desired protection in the mid-Columbia area.

A.2.1.1. Local Flood Control Objectives

Storage in upstream reservoirs to meet system flood control objectives at The Dalles generally will result in adequate control at other flood damage areas in Canada and the United States. If this is not the case, reservoir releases may be adjusted for local requirements. Columbia Falls below Hungry Horse (South Fork Flathead River), Spaulding below Dworshak (Clearwater River), Bonners Ferry below Libby (Kootenai River), and the area just downstream of Duncan all are operated for both local and system flood control. Brownlee, Grand Coulee, and Mica, in contrast, do not have local flood control requirements immediately downstream of the dams.

If the rate of filling vacated storage at Arrow required to control the flow at Trail, B.C., exceeds the rate of filling requirement for control of the lower Columbia, the requirement for Trail will take precedence, and to the extent possible appropriate evacuation of storage will be made at other Category IV (see section A.2.2) projects to compensate for the fill into Arrow Reservoir.

A.2.2 RESERVOIR CATEGORIZATION

The FCOP states that the rules and diagrams required to accomplish the refill of storage space divide the reservoirs in the Columbia River system into five major categories. Projects in each category are listed in Table A.4. Categories I and IV provide the majority of system flood control operation.

CATEGORY I - Reservoirs operated under fixed releases primarily for flood control of the lower Columbia. Reservoirs in this category cannot be operated on a day-to-day basis for flood control of the lower Columbia due mainly to the relatively long time it takes for a change in the outflow at these reservoirs to have a significant effect upon streamflow at The Dalles.

CATEGORY II - Reservoirs operated for tributary flood protection with incidental flood regulation for the lower Columbia.

CATEGORY III - Major lakes with projects operated to control lake elevations during non-flood period. The regulation of these lakes during the high-flow period is such that the natural storage effect of the lakes is preserved to the extent possible. However, local conditions are limiting factors that must be considered.

CATEGORY IV - Reservoirs operated with variable releases primarily for flood control of the lower Columbia. Reservoirs in this category are those in which outflows have a relatively brief time of travel (two days or less) to the lower Columbia flood area, and have sufficient flexibility to permit variable releases on a day-to-day forecast basis. These reservoirs provide the final major flow regulation of the flood control system and are used primarily to maintain the desired controlled flow in the lower Columbia and provide local flood protection. Although John Day Dam is a Category IV project, it does not operate to Storage Reservation Diagrams (SRDs) like Grand Coulee and Arrow. The John Day flood control space is used only occasionally during large flood events.

CATEGORY V - Run-of-River Projects on the mainstem Columbia and major tributaries. The effect of the run-of-river projects on the total regulation of the Columbia River flood flows is minor, but the operating requirements for these projects provide for establishment of specific outflows individually on a day-to-day basis for Columbia River flood regulation.

Table A.4. Reservoir Categories for Flood Control

I Fixed minimum releases	II Tributary protection	III Major lakes	IV Variable releases	V Run-of-River Projects^a
Hungry Horse Dworshak Brownlee Libby Duncan Mica	River Basins: Upper Snake Boise River Payette River Yakima River	Kootenay Flathead Pend Oreille Spokane	John Day Grand Coulee Arrow	Revelstoke Chief Joseph Wells Rocky Reach Rock Island Wanapum Priest Rapids McNary The Dalles Bonneville

a. Only run-of river projects on the mainstem of the Columbia are listed.

A.2.3 OVERVIEW OF SEASONAL FLOOD CONTROL OPERATION

Flood control operation involves two seasonal periods—the storage reservoir evacuation period (normally the low-flow period from October through March), and the reservoir refill period (normally the high-flow period from May through July). Either evacuation or refill of reservoir storage may occur during April depending upon runoff conditions.

A.2.3.1. Flood Control Storage Evacuation Period

In the winter months, reservoirs are drafted in accordance with their Storage Reservation Diagrams to provide storage space for the spring runoff. Storage requirements are based on forecasts of spring/summer volume runoff. Early evacuation of reservoirs is required for the possibility of an early spring runoff that would preclude further reservoir draft. In order to ensure drawdown in an orderly manner with consideration of project operating limits, it is necessary to initiate evacuation of reservoirs by either December first or January first. The timing of required evacuation and the period used for forecasting varies by reservoir, as shown in Table A.5. Differences in timing are due to geographical location of watershed and contributing areas at different elevations in each watershed. Lower elevation watersheds, and those located farther south, typically have an earlier completion of spring runoff.

Table A.5. Reservoir Evacuation Requirements

Dam	Forecast used for Evacuation (Period, Location)	Date When Evacuation Is Required
Mica	Apr-Aug, The Dalles	March 31
Arrow	Apr-Aug, The Dalles	March 31
Duncan	Apr-Aug, Duncan	February 28
Libby	Apr-Aug, Libby	March 15
Grand Coulee	Apr-Aug, The Dalles	April 30
Hungry Horse	May-Sep, Hungry Horse	April 30
Dworshak	Apr-Jul, Dworshak	April 15
Brownlee	Apr-Aug, The Dalles Apr-Jul, Brownlee (regulated)	April 30

The end-of-evacuation date and/or forecast period are different from project to project for two main reasons: 1) to arrange orderly drawdown to avoid requiring all projects to release high outflows in the same short period, thereby potentially causing unintended regulated flood; and 2) to follow the natural runoff pattern; e.g., the highest-elevation project’s runoff starts later (note Hungry Horse).

A.2.3.2. Flood Control Refill Period

Refill is initiated to 1) meet the system flood control objective represented by the controlled flow target for the lower Columbia River as measured at The Dalles, Oregon, 2) meet assured refill criteria as determined by flood control refill curves, and 3) meet other operational objectives that are not related to hydropower or flood control.

Day-to-day regulation in the Refill Period is accomplished by first establishing a controlled flow objective at The Dalles using the methodologies described in the FCOP and adjusting reservoir releases to try not to exceed that controlled flow. Reservoirs are divided into five categories according to the operating rules for accomplishing refill, as described in section A.2.2.

The Flood Control Refill Period is defined as commencing 10 days prior to the date the unregulated mean daily discharge is forecast to first exceed the controlled flow objective at The Dalles. The end of the Flood Control Refill Period will be when no further flood potential exists at any of the damage areas. It should be noted that a realistic forecast window of unregulated streamflow does not extend beyond 10 days; and in an effort to maintain a good likelihood of refill, refill may begin in moderate to low runoff volume years well before unregulated flows are forecasted to exceed controlled flow objectives at The Dalles.


A.2.3.3. Fall and Winter Floods

Occasionally, heavy rains and rain-on-snow events can cause flood-level flows in the lower Columbia River and its tributaries during the fall and winter months. In the fall, from October through December, a small amount of storage space is required at Mica and Arrow to ensure that, to the extent possible, releases do not exceed natural streamflows if flooding is occurring in the lower Columbia River. No more than 0.71 Maf storage space in Arrow and 0.39 Maf storage in Mica are obligated for this operation. In the event of flooding in the Lower Columbia, the Mica and Arrow projects will be operated so that, insofar as possible, the outflow from Arrow will not exceed the natural streamflow.

A.2.4 RESERVOIR-SPECIFIC FLOOD CONTROL STRATEGIES USED IN DEVELOPMENT OF REAL-TIME FLOOD CONTROL RULE CURVES


Figures A.1 and A.2 provide sample Storage Reservation Diagrams for two representative Category I and IV reservoirs, Libby and Grand Coulee. Each reservoir in the system is operated slightly differently from other reservoirs. The following discussions are intended to clarify some of the operating nuances that are unique to each reservoir. These real-time operations are used as a basis to determine how to characterize the operations of the reservoirs in planning studies such as the AOPs and DOPs, or the Phase 1 studies.

Figure A.1. Example Libby Storage Reservation Diagram⁵



⁵ This diagram represents Libby Standard flood control operations used in Treaty studies. A different SRD for Libby VarQ is used in real-time operations.

Figure A.2. Example Grand Coulee Storage Reservation Diagram



A.2.4.1. Exchange of Storage between Mica and Arrow

As provided for under the Treaty, Canada may exchange flood control storage space between Mica and Arrow if the Entities agree that the exchange gives the same degree of flood protection at The Dalles. The original 8.45 Maf of primary storage space prescribed in the Treaty includes 7.1 Maf at Arrow, 0.08 Maf at Mica, and 1.27 Maf at Duncan. The 1972 FCOP adopted a 5.1/2.08 Maf Arrow/Mica allocation, which reflects an exchange of 2 Maf of flood control storage from Arrow to Mica.

The maximum limit of flood control space that can be exchanged from Arrow to Mica without adversely affecting flood control at The Dalles was confirmed in a Corps report⁶ as 3.5 Maf, provided that 0.5 Maf of additional storage is provided in Mica. The Canadian Entity agreed with the Corps’ assessment that a 3.6/4.08 and 5.1/2.08 Maf allocation of primary flood control space between Arrow and Mica provide an equivalent level of flood protection at The Dalles. During the operating year, but no later than November first, Canada may select a flood control storage space combination between Arrow and Mica consistent with the allocations described in

⁶ Summary Report, Proposed Reallocation of Flood Control Space, Mica and Arrow Reservoirs, March 31, 1995.

this section. The Treaty FCOP SRDs that are used to determine required flood control draft have been modified to accommodate any Arrow/Mica storage exchange.

A.2.4.2. Grand Coulee Storage Reservation Diagram

Grand Coulee Dam's (GCL) primary flood control purpose is to reduce system flows measured at The Dalles, Oregon, although it does offer some incidental flood protection in the Hanford Reach. GCL has an SRD but does not use a seasonal volume forecast exclusively to determine its required flood control space. Instead, GCL uses an Upstream Storage Correction, which is the aggregation of all anticipated space upstream of The Dalles regardless of whether drafted for power or flood control needs available by April 30 (except space at GCL). The parameter necessary to make use of GCL's SRD is the unregulated seasonal volume forecast at The Dalles minus the Upstream Space Adjustment. The procedure for determining this parameter for use in GCL's SRD is outlined in Chart 2 of the FCOP. In some cases, a project may have more space drafted than can possibly be refilled. This can occur if the reservoir is evacuated deeply for power generation or if the water supply forecast during the evacuation period caused the reservoir to draft deeply and the water supply forecast does not materialize. In such a situation, the amount of space allowed for that project's upstream storage correction is limited to the expected seasonal volume of runoff minus that project's minimum flow requirement during the refill period.

A.2.4.3. Standard and Variable Discharge Flood Control

The flood control operation described in the FCOP is referred to as "Standard Flood Control." Standard Flood Control is used in all Treaty regulation studies including the AOP, DOP, and TSR. In 2003, real-time Libby and Hungry Horse operations initiated a modified flood control strategy called VarQ. Variable Discharge Flood Control, or "VarQ,"⁷ is an alternative system flood control operation developed by the Corps for both Libby and Hungry Horse to improve the likelihood of refill and potentially provide more instream flow both during and after the refill season. Implementation of VarQ at Libby and Hungry Horse Dams permits lower volumes to be released (i.e., allows higher reservoir levels during the evacuation period) and increases the likelihood of providing more reliable spring flows for fish. Because Hungry Horse is not a Treaty project, subsequent VarQ discussion and description in this appendix will reference Libby only.

Since the flood control draft at Grand Coulee Dam is based, in part, on the available storage space upstream from The Dalles (see section A.2.4.2), VarQ flood control at Libby and Hungry Horse dams influences operations for system flood control at Grand Coulee Dam by causing Grand Coulee Dam to draft deeper to maintain system flood protection at The Dalles. In practice, Grand Coulee Dam drafts deeper for flood control only in years where the seasonal volume Water Supply Forecasts (WSF) prepared for Libby Dam in December through March are between 86 and 100 percent of average. The increase in flood control draft at Grand Coulee Dam is less than the net decrease in draft at Libby and Hungry Horse dams.

⁷ Q is engineering shorthand for flow.

Standard Flood Control and VarQ also differ during reservoir refill. For example, standard flood control at Libby dam allows releases to its authorized project minimum flow of 4 kcfs during the refill period from May through July. Minimum releases during the refill period from Libby under VarQ operation can be as high as 25 kcfs.

Libby operations for VarQ and flow augmentation to protect sturgeon, bull trout, and salmon are embedded in all recent Biological Opinions developed by the U.S. Fish and Wildlife Service and NOAA-Fisheries. The Corps prepared an Environmental Impact Statement (EIS) on permanent implementation of Libby VarQ flood control in April 2006 and issued a related Record of Decision in June 2008. Those documents indicated that VarQ flood control procedures for Libby Dam would be implemented on a permanent basis starting with the 2008-09 operating year.

A.2.4.4. Libby Variable End-of-December Draft

The Protocol states, with regard to Libby Dam, that the Entities shall cooperate on a continuing basis to coordinate the operation of that dam with the operation of hydroelectric plants on the Kootenay River and elsewhere in Canada. Libby Reservoir is included in the FCOP to meet the Treaty requirement to coordinate its operation for flood control protection in Canada and for the system.

When the Treaty FCOP was first put into practice, the Libby SRD required a fixed flood control draft of two million acre-feet by the end of December, because seasonal volume forecasts were not prepared until January. Two million acre-feet was chosen because if the first seasonal volume forecast at Libby was relatively high, then a “head start” on the draft was appropriate to increase the likelihood of achieving Libby’s full flood control draft by March 15th. During the flood control evacuation period, Libby’s outflow (and subsequent ability to evacuate water pursuant to its SRD) is constrained by the Kootenay Lake Order. The Kootenay Lake Order requires Libby to reduce outflows so as not to force Kootenay Lake above fixed winter elevations. In relatively low-volume runoff years, a Libby draft of two million acre-feet is excessive and jeopardizes refill. Recent advances in volume forecasting technology and skill allow a seasonal volume forecast of inflow to Libby to be prepared by December first. The December forecast now enables the end-of-December Libby flood control elevation to be variable and less than two million acre feet. The total allowable “relaxation” of Libby end-of-December flood control draft is 600,000 acre-feet, thereby potentially reducing the maximum draft to 1.4 Maf. The amount of relaxation is determined as follows:

If 1 Dec forecast for Libby Dam \geq 5900 kaf for the April through August period (94 percent of normal), no relaxation, and 2 Maf is evacuated by the end of December.

If 1 Dec forecast for Libby Dam \leq 5500 kaf for the April through August period (88 percent of normal), relax draft by 600 kaf, and 1.4 Maf is evacuated by the end of December.

For 5500 kaf < 1 Dec forecast < 5900 kaf, relax draft by interpolating between 600 and 0 kaf.

The variable end of December draft procedure has been used in real-time operations since the 2005 Water Year.⁸ This process is not used in Treaty studies such as the AOP, DOP, or TSR.

A.2.4.5. Other Projects

Duncan

Duncan is a Category I Treaty project. Its flood control effect is dedicated primarily to the system; however, there is an incidental local flood control benefit to the river reach starting immediately below the project and extending to Kootenay Lake. Duncan has 1.27 Maf of authorized primary flood control space. A detailed description of Duncan's flood control operation is found in Chapter VIII of the Treaty Flood Control Operating Plan.

Hungry Horse

Hungry Horse is not a Treaty project and is a Category I project. As a headwater project, its outflow can be reduced to project minimum to minimize downstream flooding, or to enhance refill probability. Hungry Horse has approximately 3 Maf of authorized flood control space. Hungry Horse provides a flood control benefit for the system and at the Columbia Falls, Montana, local control point on the South Fork Flathead River, a few river miles below Hungry Horse Dam. It has flow augmentation requirements and a VarQ flood control scheme. As with Libby, the effect of VarQ is to potentially facilitate a more-reliable supply of spring and summer flows for fish while simultaneously better ensuring higher reservoir elevations in the summer. Flow augmentation occurs in the summer months for salmon and year-round, in the form of a minimum flows, for bull trout.

Dworshak

Dworshak is not a Treaty project and is a Category I project. Dworshak is a headwater project, and its outflow is reduced to its project minimum at the start of the refill season. Dworshak has approximately 2 Maf of authorized flood control space. Dworshak provides a flood control benefit for the system and at the Spalding, Idaho, local control point on the Clearwater River, just upstream of the confluence of the Snake and Clearwater Rivers.

Brownlee

Brownlee Dam is not a Treaty project and is a Category I project. As a headwater project, its outflow is reduced to its project minimum at the start of the refill season. Brownlee is owned and operated by Idaho Power Company and is the only project on the Snake River with system flood control space dedicated for use in a coordinated fashion for system flood control. The 1 Maf of system flood control space authorized by Brownlee's FERC license is drafted for flood control according to its Storage Reservation Diagram, directed by the Corps.

⁸ *Summary Report, 31 December Variable Flood Control Draft For Libby Reservoir*, Columbia Basin Water Management Division, US Army Corps of Engineers, January 2004

Kootenay Lake

On November 11, 1938, the International Joint Commission (IJC) granted an Order of Approval to the West Kootenay Power and Light Company to operate Corra Linn dam at Granite, B.C., to store six feet of water in Kootenay Lake and also to excavate the outlet of the lake at Grohman Narrows. The Order stipulated that the works be operated subject to a number of conditions and established the International Kootenay Lake Board of Control (KLBC) to oversee the operation of the works. The Board consists of four members, one each from the U.S. Army Corps of Engineers, U.S. Geological Survey, Environment Canada, and B.C. Ministry of the Environment. An annual report is submitted to the IJC in April of each year.

The 1938 Order requires an orderly drawdown of Kootenay Lake in preparation for the spring runoff such that the elevation does not exceed 1739.32 feet on or about April first as measured by the lake elevation gauge at Queens Bay. During the high summer water, the allowable lake elevation is calculated using a lowering formula from the natural lake elevation that would have occurred under original outlet conditions existing before the excavation of Grohman Narrows. At the end of the summer, for agricultural interests, the 1938 Order also specifies that once the lake elevation falls below 1743.32 feet, as measured at the Nelson gauge, it should be held below this elevation until August 31. Between September 1 and January 7, the maximum elevation is 1745.32 feet. The Treaty requires that the operation of Libby be consistent with the Kootenay Lake IJC Order. The current FCOP contains statements indicating that both Duncan and Libby must operate so as to avoid violating the IJC Order.

A.2.5 DETAILS OF REFILL PERIOD

A.2.5.1. Flood Control Refill Curves

Flood Control Refill Curves help guide the refill of reservoirs during the spring refill period and ensure that the flood control regulation does not adversely affect refill insofar as possible. Individual project refill can commence before regulation to meet the Initial Controlled Flow (ICF; see section A.2.5.3) at The Dalles if the reservoir is at or below its Flood Control Refill Curve. The refill curves define the upper reservoir elevation at any point during the refill period. Their derivation is based on the “95 percent confidence volume runoff forecast,” reduced by the amount of water to be filled into reservoirs upstream and project outflows that are anticipated to occur during the remaining refill period.

The 95 percent forecast is computed by reducing the expected seasonal runoff volume by approximately 1.65 times the standard error of the forecast. The purpose of the reduction is to account for a situation where the volume is over forecast and refill cannot be achieved because the anticipated volume did not materialize, thus creating a refill volume shortage.

The refill curves are updated daily, if necessary, using the residual volume inflow forecast and hydrologic simulations of forecasted stream flows to as much as 10 days into the future during the refill period to determine when the ICF will be reached and refill can begin. Daily inflows into the reservoirs are accounted for, and deducted from, the 95 percent confidence volume runoff forecast to determine the residual volume inflow forecast. It is important to note that the

95 percent confidence volume runoff forecast is not probability-based. If actual seasonal runoff is more than the expected value, then the excess water is passed through the project throughout the entire refill period such that a “fill and spill” condition is avoided.

A.2.5.2. Arrow/Grand Coulee Coordinated Refill

During the refill period, Arrow and Grand Coulee reservoirs refill at proportional rates to control flow at The Dalles to the required ICF (see section A.2.5.3). The rate of refill of the reservoirs is computed based on how full each reservoir is on the date of the ICF. The proportional fill of each reservoir is guided by use of Charts 3 and 6 in the FCOP. The proportional fill quantities for each reservoir are revisited throughout the refill season and adjusted as each reservoir fills.

FCOP Chart 3 is used to determine the flow to be met at The Dalles during the refill period. The flow is a function of the ICF and the combined space available to fill at Arrow plus Grand Coulee. The space available at Arrow plus Grand Coulee is defined as the percent of space available on the date of ICF. This available space, combined with the expected volume of runoff yet to come on the date of the ICF, less the volume of other upstream storage to be filled, gives the user a flow objective at The Dalles.

FCOP Chart 6 is used to determine how to proportionally fill the reservoirs. Chart 6 uses the ratio of storage space available in Grand Coulee compared to Arrow and prorates the amount of storage to be filled at Grand Coulee. Chart 6 is used as guidance and can be revisited throughout the refill season.

A.2.5.3. Controlled Flow at The Dalles

During the refill period, the upstream reservoirs operate as a system to meet the controlled flow at The Dalles, Oregon. The controlled flow is the target flow for lower Columbia River flood control as measured at The Dalles. The controlled flow is a function of the projected volume of the Columbia River spring runoff as measured at The Dalles and the amount of upstream storage space that has been evacuated for system flood control. Refill of upstream reservoir storage is regulated in a manner that provides the desired controlled flow at The Dalles. While a discharge of 450 kcfs, as measured at The Dalles, may be considered a bank-full level, higher controlled flows will be used for high-magnitude floods, resulting in damaging flows in the lower Columbia, to prevent storage space from filling too soon.

The expected controlled flow for the runoff season, and the one-day annual peak flow objective at The Dalles, is called the Initial Controlled Flow. The ICF is used in conjunction with unregulated streamflow forecasts to guide the determination of when to begin refill of reservoirs. The ICF is fundamentally a water balance calculated using the available system storage volume on 30 April and the forecasted seasonal runoff volume. The resultant volume is then converted to a flow rate and labeled the ICF. The simplistic interpretation of ICF is that all unregulated flow above the ICF during the runoff season at The Dalles can be stored in upstream reservoirs, thereby refilling reservoirs. Therefore, when the calculated unregulated flow at The Dalles reaches the ICF, the system can begin refill and operate to a regulated flow that is equal to the ICF. The ICF thus is the trigger to initiate system refill. The ICF is used to ensure that the

projects refill while minimizing the peak runoff at The Dalles. Charts in the FCOP are used to establish the ICF. In FCOP Chart 1, the ICFs at The Dalles are shown as low as 200 kcfs.

As stated earlier, the one-day annual peak flow objective and the refill season flow objective at The Dalles are the ICF, and every effort is made to control flows down to the ICF by the regulation of upstream reservoirs until the end of the flood control period or until revised forecasts indicate the necessity for the controlled flow to be changed. Change in the controlled flow at The Dalles will be made based primarily upon day-to-day forecasts of streamflow and reservoir regulation by computer simulations, together with the latest volume forecasts of runoff.

A.2.6 ON-CALL FLOOD CONTROL (PRE-2024)

The Columbia River Treaty refers to two types of flood control storage space that is provided by Canadian storage. Storage space that is available on an annual basis is defined as Primary Storage. Under the Columbia River Treaty, the United States paid U.S. \$64.4 million for use of 8.45 Maf⁹ of Primary Storage through September 2024. The Treaty also requires Canada to operate any storage in addition to the Primary Storage in the Columbia River Basin in Canada as required to meet flood control needs in the United States that cannot adequately be met by flood control facilities in the United States and Primary Storage. The Protocol further defines this need as arising only in the case of potential floods that would result in a peak discharge in excess of 600,000 cfs at The Dalles after the use of all related United States storage capacity existing and under construction in January 1961, Libby storage, and the Primary Storage. This additional Canadian space beyond Primary Storage is labeled “On-Call” storage.

A request for On-Call storage space must be processed in accordance with the Treaty. A large part of this On-Call storage would normally be evacuated during the winter, but this is not assured. Under the Treaty, a delay of 20 days may be encountered before the request for On-Call storage use is honored. With consideration of the discharge limitations at each project, the time required to prepare forecasts, and the time to process a request, it will be necessary for consultations on the use of On-Call storage to commence early in order to be assured that the storage space at each project can be made available by April first.

When the forecast of unregulated April through August runoff for the Columbia River at The Dalles exceeds the values shown in Table A.6, the United States Entity may, at its discretion, initiate formal consultation with the Canadian Entity on the need for On-Call storage:

Table A. 6. Forecast of Unregulated April through August Runoff Volumes in Millions of Acre-feet at The Dalles

Date of Forecast	Millions of Acre-feet at The Dalles
1 January	105
1 February	108
1 March	110
1 April	111

⁹ This amount of space was augmented in 1995 to 8.95 MAF as part of the flood control storage reallocation between Mica and Arrow reservoirs (see section A.2.4.1)

The Treaty requires that the United States pay Canada \$1,875,000 for each of the first four calls for On-Call Storage. In addition, the United States will deliver electric power equal to the power lost by Canada as a result of operating the storage to meet the flood control need for which the call was made. To date, the U.S. has not requested On-Call storage in Canada.

A.3 ASSURED OPERATING PLAN AND DOWNSTREAM POWER BENEFIT COMPUTATION

A.3.1 OVERVIEW

The Treaty requires that the Entities prepare annually an Assured Operating Plan for Canadian Storage and calculate the resulting Determination of Downstream Power Benefits. These studies are prepared for the sixth succeeding operating year. The AOPs are designed to achieve an optimum power operation in both Canada and the U.S. The DDPB calculates the Canadian Entitlement of the improved and optimized generation from downstream U.S. projects due to a coordinated and optimized Canadian Treaty storage operation. It also determines the year-to-year limit of allowable decrease in Entitlement due to the operation of Canadian storage for optimum power in both Canada and the U.S.

The AOP operating criteria include a series of rule curves that guide reservoir operation for flood control, optimum power generation, and reservoir refill in average and better water years. Similarly, critical rule curves guide reservoir operation for firm power in low flow conditions. Also included are operating criteria for Mica and Arrow that optimize Canadian power generation. This includes minimum and maximum flows, procedures for target flows, storage contents at Mica, and storage upper limits for Arrow.

The objective of the DDPB studies is to compute the Canadian Entitlement associated with the AOP operation. To the extent possible, the same operating criteria and procedures have to be applied to both AOP and the DDPB. Therefore, the development of AOP and the computations of Downstream Power Benefits are interdependent and have to be accomplished concurrently. The Canadian Entitlement is one-half of the DDPB.

AOP studies and the DDPB are prepared in accordance with the Treaty, the Protocol,¹⁰ and the following Entity Agreements:

- Principles for the Preparation of the AOP and DDPB Studies (28 July 1988)
- Changes to Procedures for the Preparation of the AOP and DDPB Studies (12 August 1988)
- Columbia River Treaty Entity Agreement on Resolving the Dispute on Critical Period Determination, the Capacity Entitlement, for the 1998-99, 1999-00, and 2000-01 AOP/DDPBs, and Operating Procedures for the 2001-02 and Future AOPs (29 August 1996)

¹⁰ Protocol - Annex to Exchange of Notes, Dated January 22, 1964 Between the Governments of Canada and the United States Regarding the Columbia River Treaty (Protocol).

- Principles and Procedures for Preparation and use of Hydroelectric Operating Plans for Canadian Treaty Storage (October 2003)¹¹

Any procedure changes from these agreements are noted in the annual AOP and DDPB report.

Five studies are generally performed to complete the AOP and DDPB studies. The basic assumptions for these studies and their general purpose are shown in Table A.7, and a process diagram is provided in Figure A.3. Steps I, II, and III U.S. optimum studies are completed first. In the Step I and II U.S. optimum studies, Canadian storage is operated to provide optimum power generation in the United States. The Step III study excludes Canadian storage and operates for optimum power in the U.S.

Once the three U.S. optimum studies are complete, the next stage in the process is to complete the “Canadian Re-operation,” which involves developing project-specific operating criteria for Canadian storage projects to optimize generation in both countries. These criteria are then included in the Joint Optimum Step I and Step II systems. The Step I Joint Optimum study becomes the basis for the AOP. The Step II Joint Optimum study is then used for comparison with the Step III study to compute the Joint Optimum Downstream Power Benefits.

Within each of the five studies described above (U.S. Optimum Steps I, II, III and Joint Optimum Steps I and II) there are three different system regulation studies that may be simulated:

- Critical Period System Regulation Studies
- Power Refill studies
- System Regulation Studies

The system regulation studies are used to develop the rule curves, operating rules, and project operating criteria that, in conjunction with the FCOP, are used to guide operations.

Due to the interdependence of the AOP (Step I) and the DDPB (Steps II and III), and with the three types of system regulation studies, it is difficult to describe a linear process for conducting the AOP/DDPB studies. The various studies’ components and approaches are organized in the following sections:

- A.3.2 Step I, II, III Descriptions
- A.3.3 System Regulation Studies and Associated Rule Curves
- A.3.4 Input Data to the AOP Process


Descriptions and definitions of these system regulation studies, and their associated rule curves, are provided in the subsequent sections.

¹¹ This Entities’ Agreement is referred to as POP. Appendices have been added and updated since 2003, including Appendix 6 - Streamline Procedures (2004), Appendix 7 - Table of Median Streamflows (2004), and Appendix 8 - Water Supply Forecasts (2007).

Table A. 7. Summary of Assured Operating Plan and Downstream Power Benefit System Regulation Studies

Study Name Annex B Step #	System Configuration	Study Purpose / Description
<u>US Optimum</u>		
Step I	15.5 Maf Canadian storage All U.S. Columbia Basin hydro projects Coordinated Cdn projects	1) Establishes the power installations required and U.S. Optimum generation that must be met or exceeded by the Joint Optimum Step I generation.
Step II	15.5 Maf Canadian storage 13.0 Maf Base System PNWA Load Shape Step I Thermal Installations	1) Compared to Step III study [no Canadian storage] to establish U.S. optimum Downstream Power Benefits. 2) Compared to Joint Optimum Step II study to determine reduction, if any, in Downstream Power Benefits caused by Canadian re-operation.
Step III	No Canadian storage 13.0 Maf Base System PNWA Load Shape Step I Thermal Installations	Base case for all Downstream Power Benefit computations. [Use of Base system, defined in Annex B, provides Canada with the next-added benefits agreed to in Article VII(2)(b) of the Treaty.]
<u>Joint Optimum (Re-regulation of U.S. Optimum Step I and II studies to include Canadian Generation)</u>		
Step I	15.5 Maf Canadian storage All U.S. Columbia Basin hydro projects Step I Load Shape Step I Thermal Installations Coordinated Cdn projects	Establishes operating plan for Canadian storage, including Mica Operating Criteria, based on Joint Optimum generation, which must exceed U.S. Optimum Step I generation.
Step II	15.5 Maf Canadian storage 13.0 Maf Base System Step I Load Shape Step I Thermal Installations	1) Compared to Step III U.S. Optimum to establish final Downstream Power Benefits, based on Joint Optimum with Canadian storage next-added to 13.0 Maf Base System Storage. 2) Compared to Step II U.S. Optimum to determine reduction, if any, in Downstream Power Benefits caused by Canadian re-regulation. Downstream Power Benefit reduction must not exceed limits specified in the Treaty (see section A.3.6.1.)
Notes:		
1) 13 Maf (16.035 km ³) Base System defined in Annex B, includes 0.673 Maf (0.829 km ³) of usable storage at Kootenay Lake. 2) Two AOP studies used to limit the reduction in Downstream Power Benefits that may result from re-operation of Canadian storage are not included in this table.		

Figure A.3. Process Diagram



A.3.2 STEP I, II, III DESCRIPTIONS

In accordance with Annex B, paragraph 7, of the Treaty, the increase in dependable hydroelectric capacity and the increase in average annual hydroelectric energy are determined from critical period and 30-year system regulation studies of the following systems:

Step I: The Step I study is used for two purposes:

1. To develop the Assured Operating Plan for Canadian storage to fulfill Treaty obligations. The study determines whether the proposed operating rules are optimum in both countries. The final “joint optimum” study forms the basis of the Assured Operating Plan. The Joint Optimum AOP Step I Study is the default required operation of Canadian Treaty Storage, unless otherwise agreed upon in the DOP.
2. To set the agreed-upon planning processes, joint optimum operating criteria, and thermal and hydropower installations that are used for the Step II and III studies.

Step II: These studies determine the critical period energy capability and the average annual usable hydro energy capability of a system that includes the same thermal installation as the

Step I studies, only the Base System projects with the same installed capacity as Step I, and the Canadian Treaty Storage.

Step III: These studies are the same as Step II studies except Canadian Treaty Storage is not included.

Information developed in the Step I studies that is carried over to and utilized in the Step II and Step III studies includes, but is not limited to, the following:

- Load shape of the Pacific Northwest Area (PNWA)
- Installed capacity of the Base System
- Project Operating Criteria
- Thermal Installations
- Flood Control rule curves
- Minimum generation of each Thermal Installation
- System Sales
- PNWA monthly load factors during the Step I critical period

The Step II and Step III studies are used to determine Downstream Power Benefits and are not based on real power systems. Analysis of these hypothetical systems is required because the Treaty provides that Canadian storage shall be considered as “next added” to the 13.0 Maf of usable storage in the Base System. Next-added refers to the concept that the first increments of storage will provide greater benefits than increments built later.

System configurations for the Step I, II and II studies are listed below.

Step I: Represents the actual physical system, including:

- 15.5 Maf Canadian storage
- All U.S. Columbia Basin hydro projects
- Coordinated Canadian projects¹²
- Thermal Installations operated in coordination with the PNWA
- PNWA firm loads, plus estimated imports, exports, and all other PNWA generation

Step II: Represents the “base system”¹³ with the Canadian storage:

- 15.5 Maf Canadian storage
- 13.0 Maf “base system” (essentially the 1961 storage reservoirs upstream of Bonneville dam, as modeled in the 1961 Modified Flow Report,¹⁴ plus all mainstem run-of-river projects)

¹² Recent AOPs have included projects on the Kootenay and Pend Oreille.

¹³ The “base system” plants are defined in the Treaty.

- Step I Thermal Installations
- System power loads equal to critical period resources, but shaped the same as Step I PNWA load

Step III: Same as Step II except Canadian storage is not included.

A.3.3 SYSTEM REGULATION STUDIES AND ASSOCIATED RULE CURVES

There are three different system regulation studies that may be simulated in each of the Step I, II, and III studies.

1. **Critical Period Studies.** Determine the critical period,¹⁵ the U.S. system firm energy load carrying capability (FELCC),¹⁶ and Critical Rule Curves used to guide operations during low streamflow operations.
2. **Power Refill Studies.** Establish operating criteria for middle and high water years by looking at 30 water years to preserve the future FELCC (that is, not overdraft the reservoir while serving the secondary market).
3. **System Regulation Studies.** Simulate a continuous operation over 70 years (30 years for Steps II/III) with the operating criteria established from critical period and refill studies.

Further details on these system regulation studies and their associated rule curves are provided in the following sections. A description of how each system regulation study is used in the Step I process can be found in section A.3.5.

A.3.3.1. Flood Control Upper Rule Curves

The flood control Upper Rule Curve (URC) defines the maximum allowable end of month reservoir levels at each project during the evacuation and refill periods. The Upper Rule Curves used in the AOP are determined from observed mode flood control regulation studies conducted by the U.S. Entity. During the evacuation period (the low flow period from October to March), the URCs are based on Storage Reservation Diagram contained in the FCOP. The URC for the refill period is derived from a daily analysis of system flood control simulations to control flows at the lower Columbia River as measured at The Dalles, Oregon. URCs are used as a constraint in the AOP hydroregulation studies. More information on flood control is provided in section A.2.

¹⁴ The Modified Flow report is referred to in Protocol VIII. It includes a large amount of regulation at projects not modeled, and irrigation depletion, especially the Upper Snake, Priest Lake, Upper Deschutes, and Yakima, which otherwise would not appear to be part of the Base System.

¹⁵ The critical period is defined as the period, beginning with the initial release of stored water from full reservoir conditions and ending with the reservoirs empty, when the water available from reservoir releases plus the natural streamflow is capable of producing the least amount of hydroelectric power in meeting system load requirements.

¹⁶ The system generation during the critical period is the firm energy load carrying capability.

A.3.3.2. Critical Period Studies and Rule Curves


The purpose of the critical period study is to determine the FELCC of the hydroelectric system and the operating criteria that guide each project's operation during the critical period. FELCC is the maximum amount of annual firm energy (shaped load) that the system can continuously support while drafting the active storage of the system from full to empty under the most adverse sequence of streamflows occurring within the adopted historical record (the critical period). In critical period studies, the system is regulated to maximize critical period energy, shaped to the load of the Pacific Northwest Area, within the operating constraints applied to the study. The study is conducted in observed mode, which assumes complete foreknowledge of all stream flows during the critical period.

Critical Rule Curves (CRC) are developed for each storage reservoir by the Critical Period Study. The end-of-month storages are the CRC. This study also determines the length of the critical period. A CRC provides a monthly guide to reservoir storage drafts and fills to provide an optimum power operation to meet system FELCC during periods of low inflows.

In multiple-year critical periods, there will be a CRC for each year of the critical period. The first Critical Rule Curve (CRC1) is used in the development of the Operating Rule Curve. Any additional rule curves define proportional drafting¹⁷ points below the Operating Rule Curve, which guide reservoir operation while generating system FELCC during low water conditions. Figure A.4 below provides an illustration of the Critical Rule Curves for Canadian Treaty Storage.

¹⁷ Proportional draft equitably distributes draft of storage among the reservoirs in the system during poor water years to ensure that FELCC will be met when reservoirs must be drafted below Energy Content Curves. See section A.3.3.7.

Figure A.4. Illustration of Critical Rule Curves



A.3.3.3. Power Refill Studies and Associated Curves

The refill studies develop guidelines for generation to produce secondary energy while protecting future FELCC and ensuring a high probability of refill. A reservoir shall not be drafted below its refill curve (ARC; see next paragraph) to serve any secondary energy loads, unless required by established operating procedures at the project.

Two refill curves are developed to guide reservoir operations. The Variable Refill Curve (VRC) is based on a 95 percent refill probability. The Assured Refill Curve (ARC) is developed using the second-lowest January to July volume inflow of historical stream flows (1931). In essence, the ARC provides a check on the VRC and allows a deeper draft if the VRC is found to be overly conservative.

ARCs are developed for all reservoirs. VRCs are developed only for reservoirs with multi-year storage (i.e., reservoirs that do not normally draft from full to minimum levels every year, e.g., Mica, Arrow, Duncan, Libby, and Grand Coulee).

Power refill studies are used to develop the ARCs and VRCs. The studies incorporate the CRCs and FELCC developed in the Critical Period System Regulation Study.

Monthly Power Discharge Requirements are parameters used in computing the ARCs and VRCs. They define the “amount of water to hold back for filling the reservoir.” The Power Discharge

Requirements vary as a function of the unregulated January through July runoff volume at The Dalles, Oregon, and are defined for forecast volumes of 80 Maf, 95 Maf, and 110 Maf. Between these runoff volumes, the Power Discharge Requirements are linearly interpolated. In years when the runoff volume is less than 80 Maf or greater than 110 Maf, the Power Discharge Requirement at 80 and 110 Maf, respectively, is used.

A.3.3.4. Operating Rule Curve Lower Limit

The Operating Rule Curve Lower Limit (ORCLL) defines the minimum month-end storage content that provides a high probability that the system will be capable of meeting its FELCC during the period 1 January through 30 April in the event that the VRCs permit storage to be emptied prior to the start of the freshet. For multi-year critical periods, the ORCLLs are determined from special 1937 hydroregulation studies. If the critical period is one year or less, the ORCLL and the first-year CRC are identical during the period 1 January through 30 April.

A.3.3.5. Operating Rule Curves

The Operating Rule Curve (ORC) for each reservoir is a synthesis of all of the preceding curves, as follows:

1 Aug - 31 Dec:	ORC = Higher of CRC1 and ARC
1 Jan - 31 Jul:	ORC = Lower of VRC and Higher of CRC1 and ARC
1 Jan - 15 Apr:	ORC is limited to no lower than ORCLL
At all times:	ORC is limited to no higher than the URC

The Operating Rule Curve allows, but limits, reservoir operation for the purpose of producing secondary energy. Reservoirs are drafted below Operating Rule Curves only if required to maintain the FELCC of the system or meet non-power requirements.

A.3.3.6. Non-Power Requirements

In Treaty studies, project operations¹⁸ are subject to agreed (established) non-power requirements at each of the hydro projects, such as the following:

1. Maximum rate of storage draft and refill
2. Maximum and minimum flows
3. Maximum ramping rates
4. Maximum and minimum reservoir elevations
5. Flood control criteria
6. Other agreed at-site non-power requirements

¹⁸ Actual operations may be subject to additional non-power requirements that are not included in Treaty studies.

Non-power requirements for AOP and DDPB studies for Base System projects and Canadian storage are established in the 29 August 1996 Entity Agreement. Non-power requirements for Libby are established in the Libby Coordination Agreement. The non-power requirements at Base system and Canadian storage projects can be changed only by mutual agreement.

A.3.3.7. Additional Operating Criteria

In general, the whole of Canadian storage is operated to follow the Operating Rule Curve. However, there are situations where this does not occur.

Operating Above the Operating Rule Curve. Draft to the Operating Rule Curve is typically limited at Mica and all U.S. storage reservoirs to maximum powerhouse discharge (i.e., projects do not need to spill water to meet ORC draft levels). Operating above the Operating Rule Curve also can occur if the U.S. project secondary energy generation amounts exceed the secondary market limit.

Proportional Draft Below the Operating Rule Curve. Under low water conditions, proportional draft below the Operating Rule Curves is required to produce the hydro FELCC of the U.S. system. When proportional draft conditions are met, the whole of the Canadian storage and all reservoirs in the U.S. system are initially drafted proportionally between their respective Operating Rule Curves and their first Critical Rule Curves. If it is necessary to draft additional storage after system reservoirs reach their first Critical Rule Curves, the proportional draft shall be made between their first and second Critical Rule Curves, their second and third Critical Rule Curves, and so on.

Proportional draft is limited by 1) maximum powerhouse discharge at Mica and all U.S. reservoirs, 2) Mica/Arrow operating criteria, and 3) non-power requirements and project operating criteria.

Composite Operation of Canadian Storage. While the operating plans and rule curves are developed for each Canadian reservoir, the obligation of Canada to provide storage regulation is measured by the composite storage in all three Treaty reservoirs. To accomplish this, Canadian storage operation is guided by the composite Operating Rule Curve and composite Critical Rule Curves for the whole of Canadian storage. A composite rule curve for the whole of Canadian storage is the summation, by month, of the storage corresponding to the rule curves for Mica, Arrow, and Duncan. In addition, the individual operation of Mica and Arrow is guided by Upper Rule Curves and project operating criteria, which may cause a deviation from the rule curves.

In actual operation, the Canadian Entity may vary the individual project operation in any manner consistent with the composite operation for Canadian storage in the hydroelectric operating plan and the individual Upper Rule Curves at each project.

A.3.3.8. System Regulation Studies

These studies cycle through each of the historical streamflow conditions sequentially to test the system operating criteria developed in the critical period and refill studies over a wide range of

inflows. For joint optimum studies, operating criteria for Mica and Arrow are also included. The studies are used to determine the average annual usable energy and dependable peaking capacity produced by the Canadian and U.S. systems.

A.3.4 INPUT DATA TO THE AOP PROCESS

Input data must be gathered prior to conducting the system regulation studies. Required information includes loads and resources, streamflows, flood control criteria, and non-power requirements.

A.3.4.1. Loads and Resources

Load and resource forecasts provide basic but critical information required to simulate the operation of the PNWA coordinated hydroelectric system and, as a result, affect the design of reservoir operating criteria and the calculation of the Canadian Entitlement to downstream power benefits.

Loads are quantified by three main forecasts:

1. PNWA Firm Loads
2. Flow of power at points of interconnection (i.e., imports and exports)
3. Miscellaneous resources including some small hydro and other renewables (Step I firm load is reduced by these resources)

Resources are quantified by known and forecast:

1. Base System Hydro
2. Other Step I Coordinated Hydro
3. Thermal installations operated in coordination with the Base System
4. Maintenance, transmission loss, and reserves

The assumptions behind load and resource forecasts significantly influence the outcomes of the Phase 1 studies.

A.3.4.2. Streamflow Record

All system regulation studies are currently based on the 2000-level Modified Flow study data set (August 1928 through July 1998). Modified flow data includes updates for current best estimates of 2000 level irrigation depletions, return flows, and evaporation, and adjustments for errors and omitted projects.

In accordance with Protocol VIII, the AOP Step I, II, and III system regulation studies are based on only the 30-year streamflow period from 1928 through 1958. However, the Step I studies do use the total streamflow period (currently 70 years) from the 2000-level Modified Streamflows (1928-1978) to develop and test the AOP operating rules and rule curves to provide an indication

of actual Treaty operation over a wider range of streamflow conditions. The additional 40 years (currently) are not included in the determination of optimum power or the calculation of downstream power benefits.

The Entities have agreed to use a 1 August through 31 July operating year with 14 periods (August and April are split into two periods).

A.3.5 STEP I AOP PROCESS

Figure A.3 describes how each system regulation, described in section A.3.3, is used in the Step I studies. Links with the Step II and III studies are also shown in the figure.

A.3.5.1. Step I U.S. Optimum Study

The first study conducted is the Critical Period Study. An iterative process is required so that the Firm Load Carrying Capability (FLCC) determined from the Critical Period Study matches the Residual Hydro Load defined by the loads and resources. The critical rule curves defined in the Critical Period Study are then used in the power refill study, which develops the variable and assured refill curves and the power discharge requirements. Finally the system regulation studies are conducted to test operation criteria under a range of conditions and calculate the power produced.

A.3.5.2. Canadian Re-operation and Joint Optimum Study

After the U.S. Entity has completed the U.S. Optimum study, the information is provided to the Canadian Entity to adjust operation of Canadian Storage to optimize generation in both countries. The objective is to:

1. Increase the firm energy, secondary energy, and/or dependable capacity of Mica and the Canadian downstream projects
2. Improve the monthly distribution of energy production on the Canadian system
3. Maintain sufficient outflow to allow peaking during all periods

The Canadian re-operation can modify the rule curves that were developed in the U.S. Optimum studies and develop operating criteria for Mica and Arrow projects.

Under the Mica Project Operating Criteria, the Mica operation in each period is to a target flow or content as determined by Arrow's storage content at the end of the previous period. In the event that Mica's operation results in more or less than Mica's share of draft from the Operating Rule Curve or proportional draft point, compensating changes will be made from Arrow to the extent possible. In general, Arrow reservoir is operated to provide the balance of the required total Canadian Treaty Storage to compensate for Mica operation, subject to physical and


operating requirements.¹⁹ The operation of Mica to specific project operating criteria, together with compensating changes to Arrow's operation, is commonly called "Mica/Arrow Balancing."

Other Canadian projects such as Revelstoke, Upper Bonnington, Lower Bonnington, South Slokan, Brilliant, Seven Mile, and Waneta are included in the study as run-of-river projects. Corra Linn and Kootenay Canal are included and operated in accordance with criteria that closely approximate an optimum power operation as limited by International Joint Commission requirements for Kootenay Lake.

The Canadian Treaty operating criteria are applied to both Step I and II joint optimum studies. As a result, the Canadian re-operation is conducted in parallel to the Step I and II joint optimum studies.

¹⁹ Requirements include but are not limited to the flood control upper rule curve, rate-of-draft and minimum flow limits, and the Arrow Project Operating Criteria.

Figure A.5. How each system regulation study is used in the Step I process
Detailed Process Flow - Step I Studies



A.3.5.3. Optimum Power Generation

The Treaty requires that the AOP be based on joint optimum power generation in Canada and the U.S. To evaluate the power gains and losses to the United States and Canada in the Step I U.S. Optimum and Step I Joint Optimum studies and ensure the joint optimum power operation, the Entities have agreed to a common measure, which is the weighted sum of each system’s firm energy capability, dependable peaking capacity, and average annual usable secondary energy capability. The relative weights assigned to each quantity are provided in the table below:

<u>Quantity</u>	<u>Relative Value</u>
Annual firm energy capability (average megawatts (aMW))	3
Dependable peaking capacity (MW)	1
Average annual usable secondary energy (aMW)	2

A.3.6 CALCULATION OF DOWNSTREAM POWER BENEFITS AND CANADIAN ENTITLEMENT

The Canadian Entitlement to Downstream Power Benefits for any operating year is one-half of the estimated increase in dependable hydroelectric capacity and one-half of the estimated increase in average annual usable hydroelectric energy.

Dependable Hydroelectric Capacity Benefit. Subject to the Capacity Credit Limit (section A.3.7), the capacity benefit from Canadian storage is the difference between the Step II and Step III systems’ average rates of U.S. hydro generation during the critical periods, divided by the average of the monthly load factors during the critical period of the Pacific Northwest Area, as determined from the Step I study.

Average Annual Usable Hydroelectric Energy Benefits. The energy benefit from Canadian storage is the difference in the average annual usable energy of the Step II and Step III systems. Usable energy includes firm hydro energy plus a portion of secondary energy.

Usable energy has been defined as the sum of these three factors:

- The annual firm hydro energy determined from critical period studies
- The secondary hydro energy (generation in excess of firm energy) that can be used for thermal displacement
- The estimated amount of the remaining secondary generation that is agreed by the Entities to be usable, provided this amount does not exceed 40 percent of the remainder (in practice, the Entities have agreed that the 40 percent limit was applicable to all Downstream Power Benefit determinations to date)

A.3.6.1. Minimum Permitted Downstream Power Benefits

The Treaty provides certain restrictions on the reduction in Downstream Power Benefits resulting from re-operation of Canadian storage for optimal operation in both countries. As a

result of these limitations, the actual Downstream Power Benefits must be not less than the higher of the two following values:

The Downstream Power Benefits associated with 12.5 million acre-feet (15.5 cubic kilometers) of Canadian storage

The Downstream Power Benefits associated with the preceding year's benefits reduced by the effect of withdrawing 0.5 million acre-feet (0.6 cubic kilometers) of Canadian storage

This procedure has not limited the Canadian Entitlement for many years and so was not investigated as part of the Phase 1 technical studies. Therefore, the methodology for limiting the reduction in Downstream Power Benefits is not included in this appendix.

A.3.7 CAPACITY CREDIT LIMIT

The Treaty specifies that the Dependable Hydroelectric Capacity Benefit shall not exceed the difference between the capability of the base system without Canadian storage and the maximum feasible capability of the base system with Canadian storage to supply firm load during the critical streamflow periods.

The following example demonstrates how the capacity credit limit is computed for the Determination of Downstream Power Benefits. The information for this example is taken from AOP06.

The firm load carrying capacity of Step II is the lesser of:

Step II capacity load	28,608 MW
Step II resources minus reserves	32,323 MW

Similarly, the firm load carrying capacity of Step III is the lesser of:

Step III capacity load	23,394 MW
Step III resources minus reserves	32,174 MW

Therefore, the capacity credit limit is 28,608 minus 23,394, or 5,214 MW.

The actual dependable capacity gain for this year (from AOP06) was 2,436 MW, well within the Capacity Credit Limit. The Capacity Credit Limit has not limited capacity entitlements in any DDPB carried out to date.

A.3.8 SIMULATION MODEL

HYDSIM is the hydroregulation model that is used in AOP, DOP, and TSR studies. It simulates the month-to-month operation of the Pacific Northwest hydropower system in accordance with operating criteria and constraints based on the Columbia River Treaty. HYDSIM is used to determine the hydro system generation and resulting project outflows and ending storage contents under varying inputs of inflows, power loads, operating procedures and constraints, and physical plant data.

HYDSIM is not an optimizer; instead, it is a deterministic model that uses rule curves and flow or storage constraints to achieve operating objectives for power, flood control, and various constraints or requirements on the system. HYDSIM simulates one period at a time without looking forward. Each period is equivalent to one month, except for April and August, which are split into two periods each due to significant natural flow variation in those months, resulting in a 14-period operating year. HYDSIM is typically run using historical water year sequences—the 30-year or 70-year record of Modified Streamflows (1929-1998), or critical period studies looking at 1929-1932, 1937, or 1944-1945.

HYDSIM is run in either a continuous mode or a non-continuous (refill) mode. In continuous mode, the projects' storage contents start each year where the previous year ended. In non-continuous mode, the projects' initial storage contents are set to the same storage content in each operating year. Typically, mid-term studies (6 to 18 months out) are run in refill mode, and long-term studies (greater than 18 months out) are run in continuous mode.

Projects modeled in HYDSIM include both storage and run-of-river projects. Storage projects regulate inflows to adjust the river's natural flow patterns and reshape water on a seasonal basis (i.e., month to month) to conform more closely to desired water uses. For the PNWA, most storage projects capture the spring runoff for release during summer, fall, and winter, when natural streamflows are low. Run-of-river projects have limited storage capability and pass inflow on either a daily or weekly basis. Treaty studies typically include 29 storage projects (6 without generation) and 45 run-of-river projects, for a total of 74 projects. Most projects are upstream of Bonneville Dam, including 10 in British Columbia. There are 22 projects west of the Cascades that are coordinated with the Columbia system and are included in HYDSIM. The Federal Willamette projects, Yakima projects, and projects upstream of Brownlee are not included in HYDSIM and are treated as hydro independents.

For each period, HYDSIM reads input files containing forecasts of the residual power load to be met by the modeled hydro system, Modified Streamflows, flood control curves, energy content curves, critical rule curves, and other project-specific operating requirements.

A.4 DETAILED OPERATING PLAN

A.4.1 OVERVIEW

A Detailed Operating Plan is developed prior to each operating year and includes changes to the AOP that would be mutually advantageous to the Entities. The DOP is developed from the AOP previously agreed to for that operating year and provides information needed to operate Treaty storage within the operating year. Such information includes operating rule curves for the composite Canadian Storage and constraints and operating criteria that may apply to individual reservoirs. This information defines operations in the Treaty Storage Regulation Study, which is used to implement DOP operations throughout the operation year.

The process for development of the DOP has evolved over time and is designed to identify and evaluate proposed changes to the AOP that would be mutually advantageous to the Entities. This

process provides the opportunity to address non-power issues that are not included in the AOP. The DOP usually allows for further refinement of the operating plan throughout the operating year as more information becomes available about the current streamflow and water supply conditions.

A.4.2 DOP 70-YEAR STUDIES

A number of system regulation studies are used to test the default operating criteria in the AOP and to develop potential new operating criteria. The process is outlined below.

1. Start with the AOP Step I Joint Optimum 70-year study.
2. Update Flood Control rule curves for historical water years.
3. Update forecast information, typically including:
 - Forecast errors, distribution factors, and streamflow forecast procedures
 - Streamflow record increases corresponding to Coulee pumping and other irrigation depletions, if available
 - Estimate of hydro independents
4. Consider plant and reservoir updates that do not significantly affect operation of Canadian Storage, including:
 - Plant data
 - Operating criteria and non-power constraints for non-Base System projects
5. Explore modifications to Canadian operating criteria for mutual benefit.
6. Compare study results to AOP Step I Joint Optimum 70-year study.

A.4.3 SYSTEM REGULATION STUDY

A System Regulation Study is the primary tool used to evaluate current and proposed operating criteria. By agreement, additional water years from the 2000-level Modified Flow data set may be included. The studies can include the full 70 years of historical data. These studies cycle through all years in continuous mode, where the ending elevations for each historical year become the starting elevations for the next water year. Several other studies may also be required to test and evaluate proposed changes to the operating criteria. Any changes from the original AOP study must be agreed to by the Entities.

A.4.4 IMPLEMENTATION OF THE DETAILED OPERATING PLAN

Treaty Storage Regulation studies are prepared within the operating year to implement the DOP. The HYDSIM hydroregulation model (see section A.3.8) simulates the Columbia River system operation for power, flood control, and agreed non-power purposes. End-of-month storage contents for Canadian Treaty Storage are determined from the results of the model simulation for the current operating year. Input data to the TSR is either pre-defined in the AOP/DOP or variable based on conditions in the given operating year. Pre-defined inputs to the TSR are:

- Firm and secondary loads
- Thermal and miscellaneous resources
- Agreed non-power requirements
- Other plant and operating data
- Assured Refill Curves
- Critical Rule Curves
- Operating Rule Curve Lower Limits
- Upper Rule Curves (July through November)

Inputs that may vary each year based on hydrological conditions include:

- Unregulated observed and forecast streamflow
- Variable Refill Curves
- Upper Rule Curves (December through June)
- Hydro-independent generation

The TSR provides the Entities with the required composite operation of Canadian Treaty Storage for the current end of month and information on the subsequent two months. This information is used to plan the near-term operation of the Composite Treaty Storage, which is implemented through weekly agreements. Unless otherwise agreed, the weekly agreements are based on operating Canadian Treaty Storage to the end-of-month elevations determined in the current Treaty Storage Regulation study as modified by any Supplemental Operating Agreement. The one exception to this process is during the refill period, when the reservoirs are actively being managed for flood control requirements.

This page intentionally left blank

APPENDIX B

COLUMBIA RIVER TREATY AND PROTOCOL

This page intentionally left blank

APPENDIX B. COLUMBIA RIVER TREATY AND PROTOCOL

The Columbia Treaty

Treaty between Canada and the United States of America relating to Cooperative Development of the Water Resources of The Columbia River Basin

The Governments of Canada and the United States of America

Recognizing that their peoples have, for many generations, lived together and cooperated with one another in many aspects of their national enterprises, for the greater wealth and happiness of their respective nations, and

Recognizing that the Columbia River Basin, as a part of the territory of both countries, contains water resources that are capable of contributing greatly to the economic growth and strength and to the general welfare of the two nations, and

Being desirous of achieving the development of those resources in a manner that will make the largest contribution to the economic progress of both countries and to the welfare of their peoples of which those resources are capable, and

Recognizing that the greatest benefit to each country can be secured by cooperative measures for hydroelectric power generation and flood control, which will make possible other benefits as well.

Have agreed as follows:

ARTICLE I ***Interpretation***

1. In the Treaty, the expression

(a) “average critical period load factor” means the average of the monthly load factors during the critical stream flow period;

(b) “base system” means the plants, works and facilities listed in the table in Annex B as enlarged from time to time by the installation of additional generating facilities, together with any plants, works or facilities which may be constructed on the main stem of the Columbia River in the United States of America;

(c) “Canadian storage” means the storage provided by Canada under Article II;

(d) “critical stream flow period” means the period, beginning with the initial release of stored water from full reservoir conditions and ending with the reservoirs empty, when the water available from reservoir releases plus the natural stream flow is capable of producing the least amount of hydroelectric power in meeting system load requirements;

(e) “consumptive use” means use of water for domestic, municipal, stock-water, irrigation, mining or industrial purposes but does not include use for the generation of hydroelectric power;

(f) “dam” means a structure to impound water, including facilities for controlling the release of the impounded water;

(g) “entity” means an entity designated by either Canada or the United States of America under Article XIV and includes its lawful successor;

(h) “International Joint Commission” means the Commission established under Article VII of the Boundary Waters Treaty, 1909, or any body designated by the United States of America and Canada to succeed to the functions of the Commission under this Treaty;

(i) “maintenance curtailment” means an interruption or curtailment which the entity responsible therefor considers necessary for purposes of repairs, replacements, installations of equipment, performance of other maintenance work, investigations and inspections;

(j) “monthly load factor” means the ratio of the average load for a month to the integrated maximum load over one hour during that month;

(k) “normal full pool elevation” means the elevation to which water is stored in a reservoir by deliberate impoundment every year, subject to the availability of sufficient flow;

(l) “ratification date” means the day on which the instruments of ratification of the Treaty are exchanged;

(m) “storage” means the space in a reservoir which is usable for impounding water for flood control or for regulating stream flows for hydroelectric power generation;

(n) “Treaty” means this Treaty and its Annexes A and B;

(o) “useful life” means the time between the date of commencement of operation of a dam or facility and the date of its permanent retirement from service by reason of obsolescence or wear and tear which occurs notwithstanding good maintenance practices.

2. The exercise of any power, or the performance of any duty, under the Treaty does not preclude a subsequent exercise of performance of the power or duty.

ARTICLE II ***Development by Canada***

1. Canada shall provide in the Columbia River basin in Canada 15,500,000 acre-feet of storage usable for improving the flow of the Columbia River.

2. In order to provide this storage, which in the Treaty is referred to as the Canadian storage, Canada shall construct dams:

(a) on the Columbia River near Mica Creek, British Columbia, with approximately 7,000,000 acre-feet of storage;

(b) near the outlet of Arrow Lakes, British Columbia, with approximately 7,100,000 acre-feet of storage; and

(c) on one or more tributaries of the Kootenay River in British Columbia downstream from the Canada-United States of America boundary with storage equivalent in effect to approximately 1,400,000 acre-feet of storage near Duncan Lake, British Columbia.

3. Canada shall commence construction of the dams as soon as possible after the ratification date.

ARTICLE III

Development by the United States of America Respecting Power

1. The United States of America shall maintain and operate the hydro electric facilities included in the base system and any additional hydroelectric facilities constructed on the main stem of the Columbia River in the United States of America in a manner that makes the most effective use of the improvement in stream flow resulting from operation of the Canadian storage for hydro-electric power generation in the United States of America power system.

2. The obligation in paragraph (1) is discharged by reflecting in the determination of downstream power benefits to which Canada is entitled the assumption that the facilities referred to in paragraph (1) were maintained and operated in accordance therewith.

ARTICLE IV

Operation by Canada

1. For the purpose of increasing hydroelectric power generation in Canada and in the United States of America, Canada shall operate the Canadian storage in accordance with Annex A and pursuant to hydroelectric operating plans made thereunder. For the purpose of this obligation an operating plan if it is either the first operating plan or if in the view of either Canada or the United States of America it departs substantially from the immediately preceding operating plan must, in order to be effective, be confirmed by an exchange of notes between Canada and the United States of America.

2. For the purpose of flood control until the expiration of sixty years from the ratification date, Canada shall

(a) operate in accordance with Annex A and pursuant to flood control operating plans made thereunder

- (i) 80,000 acre-feet of the Canadian storage described in Article II(2)(a),
- (ii) 7,100,000 acre-feet of the Canadian storage described in Article II(2)(b),
- (iii) 1,270,000 acre-feet of the Canadian storage described in Article II(2)(c),

provided that the Canadian entity may exchange flood control storage under subparagraph (ii) for flood control storage additional to that under subparagraph (I), at the location described in Article II(2)(a), if the entities agree that the exchange would provide the same effectiveness for control of floods on the Columbia River at the Dalles, Oregon;

(b) operate any additional storage in the Columbia River basin in Canada, when called upon by an entity designated by the United States of America for that purpose, within the limits of existing facilities and as the entity requires to meet flood control needs for the duration of the flood period for which the call is made.

3. For the purpose of flood control after the expiration of sixty years from the ratification date, and for so long as the flows in the Columbia River in Canada continue to contribute to potential flood hazard in the United States of America, Canada shall, when called upon by an entity designated by the United States of America for that purpose, operate within the limits of existing facilities any storage in the Columbia River basin in Canada as the entity requires to meet flood control needs for the duration of the flood control period for which the call is made.

4. The return to Canada for hydroelectric operation and the compensation to Canada for flood control operation shall be as set out in Articles V and VI.

5. Any water resource development, in addition to the Canadian storage, constructed in Canada after the ratification date shall not be operated in a way that adversely affect the stream flow control in the Columbia River within Canada so as to reduce the flood control and hydroelectric power benefits which the operation of the Canadian storage in accordance with the operating plans in force from time to time would otherwise produce.

6. As soon as any Canadian storage becomes operable Canada shall commence operation thereof in accordance with this Article and in any event shall commence full operation of the Canadian storage described in Article II(2)(b) and Article II(2)(c) within five years of the ratification date and shall commence full operation of the balance of the Canadian storage within nine years of the ratification date.

ARTICLE V

Entitlement to Downstream Power Benefits

1. Canada is entitled to one half the downstream power benefits determined under Article VII.

2. The United States of America shall deliver to Canada at a point on the Canada-United States of America boundary near Oliver, British Columbia, or such other place as the entities may agree upon, the downstream power benefits to which Canada is entitled, less

- (a) transmission loss,
- (b) the portion of the entitlement disposed of under Article VIII(1), and
- (c) the energy component described in Article VIII(4).

3. The entitlement of Canada to downstream power benefits begins for any portion of Canadian storage upon commencement of its operation in accordance with Annex A and pursuant to a hydroelectric operating plan made thereunder.

ARTICLE VI

Payment for Flood Control

1. For the flood control provided by Canada under Article IV(2)(a) the United States of America shall pay Canada in United States funds:

- (a) 1,200,000 dollars upon the commencement of operation of the storage referred to in subparagraph (a)(i) thereof,
- (b) 52,100,000 dollars upon the commencement of operation of the storage referred to in subparagraph (a)(ii) thereof, and
- (c) 11,100,000 dollars upon the commencement of operation of the storage referred to in subparagraph (a)(iii) thereof.

2. If full operation of any storage is not commenced within the time specified in Article IV, the amount set forth in paragraph (1) of this Article with respect to that storage shall be reduced as follows:

- (a) under paragraph (1)(a), 4,500 dollars for each month beyond the required time,
- (b) under paragraph (1)(b), 192, 100 dollars for each month beyond the required time, and
- (c) under paragraph (1)(c), 40,800 dollars for each month beyond the required time.

3. For the flood control provided by Canada under Article IV(2)(b) the United States of America shall pay Canada in United States funds in respect only of each of the first four flood periods for which a call is made 1,875,000 dollars and shall deliver to Canada in respect of each and every call made, electric power equal to the hydroelectric power lost by Canada as a result of operating the storage to meet the flood control need for which the call was made, delivery to be made when the loss of hydroelectric power occurs.

4. For each flood period for which flood control is provided by Canada under Article IV(3), the United States of America shall pay Canada in United States funds:

- (a) the operating cost incurred by Canada in providing the flood control, and
- (b) compensation for the economic loss to Canada arising directly from Canada foregoing alternative uses of the storage used to provide the flood control.

5. Canada may elect to receive in electric power, the whole or any portion of the compensation under paragraph 4(b) representing loss of hydroelectric power to Canada.

ARTICLE VII

Determination of Downstream Power Benefits

1. The downstream power benefits shall be the difference in the hydroelectric power capable of being generated in the United States of America with and without the use of Canadian storage, determined in advance, and is referred to in the Treaty as the downstream power benefits.

2. For the purpose of determining the downstream power benefits:

- (a) the principles and procedures set out in Annex B shall be used and followed;
- (b) the Canadian storage shall be considered as next added to 13,000,000 acre-feet of the usable storage listed in Column 4 of the table in Annex B;
- (c) the hydroelectric facilities included in the base system shall be considered as being operated to make the most effective use for hydroelectric power generation of the improvement in stream flow resulting from operation of the Canadian storage.

3. The downstream power benefits to which Canada is entitled shall be delivered as follows:

- (a) dependable hydroelectric capacity as scheduled by the Canadian entity, and
- (b) average annual usable hydroelectric energy in equal amounts each month, or in accordance with a modification agreed upon under paragraph (4).

4. Modification of the obligation in paragraph (3)(b) may be agreed upon by the entities.

ARTICLE VIII

Disposal of Entitlement to Downstream Power Benefits

1. With the authorization of Canada and the United States of America evidenced by exchange of notes, portions of the downstream power benefits to which Canada is entitled may be disposed of within the United States of America. The respective general conditions and limits within which the entities may arrange initial disposals shall be set out in an exchange of notes to be made as soon as possible after the ratification date.

2. The entities may arrange and carry out exchanges of dependable hydroelectric capacity and average annual usable hydroelectric energy to which Canada is entitled for average annual usable hydroelectric energy and dependable hydroelectric capacity respectively.

3. Energy to which Canada is entitled may not be used in the United States of America except in accordance with paragraphs (1) and (2).

4. The bypassing at dams on the main stem of the Columbia River in the United States of America of an amount of water which could produce usable energy equal to the energy component of the downstream power benefits to which Canada is entitled but not delivered to Canada under Article V or disposed of in accordance with paragraphs (1) and (2) at the time the energy component was not so delivered or disposed of, is conclusive evidence that such energy component was not used in the United States of America and that the entitlement of Canada to such energy component is satisfied.

ARTICLE IX

Variation of Entitlement to Downstream Power Benefits

1. If the United States of America considers with respect to any hydroelectric power project planned on the main stem of the Columbia River between Priest Rapids Dam and McNary Dam that the increase in entitlement of Canada to downstream power benefits resulting from the operation of the project would produce a result which would not justify the United States of America in incurring the costs of construction and operation of the project, Canada and the United States of America at the request of the United States of America shall consider modification of the increase in entitlement.

2. An agreement reached for the purposes of this Article shall be evidenced by an exchange of notes.

ARTICLE X

East-West Standby Transmission

1. The United States of America shall provide in accordance with good engineering practice east-west standby transmission service adequate to safeguard the transmission from Oliver, British Columbia, to Vancouver, British Columbia, of the downstream power benefits to which Canada is entitled and to improve system stability of the east-west circuits in British Columbia.

2. In consideration of the standby transmission service, Canada shall pay the United States of America in Canadian funds the equivalent of 1.50 United States dollars a year for each kilowatt of dependable hydroelectric capacity included in the downstream power benefits to which Canada is entitled.

3. When a mutually satisfactory electric coordination arrangement is entered into between the entities and confirmed by an exchange of notes between Canada and the United States of America the obligation of Canada in paragraph (2) ceases.

ARTICLE XI

Use of Improved Stream Flow

1. Improvement in stream flow in one country brought about by operation of storage constructed under the Treaty in the other country shall not be used directly or indirectly for hydroelectric power purposes except:

(a) in the case of use within the United States of America with the prior approval of the United States entity, and

(b) in the case of use within Canada with the prior approval of the authority in Canada having jurisdiction.

2. The approval required by this Article shall not be given except upon such conditions, consistent with the Treaty, as the entity or authority considers appropriate.

ARTICLE XII
Kootenai River Development

1. The United States of America for a period of five years from the ratification date, has the option to commence construction of a dam on the Kootenai River near Libby, Montana, to provide storage to meet flood control and other purposes in the United States of America. The storage reservoir of the dam shall not raise the level of the Kootenai River at the Canada-United States of America boundary above an elevation consistent with a normal full pool elevation at the dam of 2,459 feet, United States Coast and Geodetic Survey datum, 1929 General Adjustment, 1947 International Supplemental Adjustment.

2. All benefits which occur in either country from the construction and operation of the storage accrue to the country in which the benefits occur.

3. The United States of America shall exercise its option by written notice to Canada and shall submit with the notice a schedule of construction which shall include provision for commencement of construction, whether by way of railroad relocation work or otherwise, within five years of the ratification date.

4. If the United States of America exercises its option, Canada in consideration of the benefits accruing to it under paragraph (2) shall prepare and make available for flooding the land in Canada necessary for the storage reservoir of the dam within a period consistent with the construction schedule.

5. If a variation in the operation of the storage is considered by Canada to be of advantage to it the United States of America shall, upon request, consult with Canada. If the United States of America determines that the variation would not be to its disadvantage it shall vary the operation accordingly.

6. The operation of the storage by the United States of America shall be consistent with any order of approval which may be in force from time to time relating to the levels of Kootenay Lake made by the International Joint Commission under the Boundary Waters Treaty, 1909.

7. Any obligation of Canada under this Article ceases if the United States of America, having exercised the option, does not commence construction of the dam in accordance with the construction schedule.

8. If the United States of America exercises the option it shall commence full operation of the storage within seven years of the date fixed in the construction schedule for commencement of construction.

9. If Canada considers that any portion of the land referred to in paragraph (4) is no longer needed for the purpose of this Article Canada and the United States of America, at the request of Canada, shall consider modification of the obligation of Canada in paragraph (4).

10. If the Treaty is terminated before the end of the useful life of the dam Canada shall for the remainder of the useful life of the dam continue to make available for the storage reservoir of the dam any portion of the land made available under paragraph (4) that is not required by Canada for purposes of diversion of the Kootenay River under Article XIII.

ARTICLE XIII
Diversions

1. Except as provided in this Article neither Canada nor the United States of America shall, without the consent of the other evidenced by an exchange of notes, divert for any use, other than consumptive use, any water from its natural channel in a way that alters the flow of any water as it crosses the Canada-United States of America boundary within the Columbia River Basin.

2. Canada has the right, after the expiration of twenty years from the ratification date, to divert not more than 1,500,000 acre-feet of water a year from the Kootenay River in the vicinity of Canal Flats, British Columbia, to the headwaters of the Columbia River, provided that the diversion does not reduce the flow of the Kootenay River immediately downstream from the point of diversion below the lesser of 200 cubic feet per second or the natural flow.

3. Canada has the right, exercisable at any time during the period commencing sixty years after the ratification date and expiring one hundred years after the ratification date, to divert to the head-waters of the Columbia River any water which, in its natural channel, would flow in the Kootenay River across the Canada-United States of America boundary, provided that the diversion does not reduce the flow of the Kootenay River at the Canada-United States of America boundary near Newgate, British Columbia, below the lesser of 2500 cubic feet per second or the natural flow.

4. During the last twenty years of the period within which Canada may exercise the right to divert described in paragraph (3) the limitation on diversion is the lesser of 1000 cubic feet per second or the natural flow.

5. Canada has the right:

(a) if the United States of America does not exercise the option in Article XII(1), or

(b) if it is determined that the United States of America, having exercised the option, did not commence construction of the dam referred to in Article XII in accordance therewith or that the United States of America is in breach of the obligation in that Article to commence full operation of the storage,

to divert to the headwaters of the Columbia River any water which, in its natural channel, would flow in the Kootenay River across the Canada-United States of America boundary, provided that the diversion does not reduce the flow of the Kootenay River at the Canada-United States of America boundary near Newgate, British Columbia, below the lesser of 1000 cubic feet per second or the natural flow.

6. If a variation in the use of the water diverted under paragraph (2) is considered by the United States of America to be of advantage to it Canada shall, upon request, consult with the United States of America. If Canada determines that the variation would not be to its disadvantage it shall vary the use accordingly.

ARTICLE XIV ***Arrangements for Implementation***

1. Canada and the United States of America shall each, as soon as possible after the ratification date, designate entities and when so designated the entities are empowered and charged with the duty to formulate and carry out the operating arrangements necessary to implement the Treaty. Either Canada or the United States of America may designate one or more entities. If more than one is designated the powers and duties conferred upon the entities by the Treaty shall be allocated among them in the designation.

2. In addition to the powers and duties dealt with specifically elsewhere in the Treaty the powers and duties of the entities include:

(a) coordination of plans and exchange of information relating to facilities to be used in producing and obtaining the benefits contemplated by the Treaty,

(b) calculation of and arrangements for delivery of hydroelectric power to which Canada is entitled for providing flood control,

- (c) calculation of the amounts payable to the United States of America for standby transmission services,
- (d) consultation on requests for variations made pursuant to Articles XII(5) and XIII(6),
- (e) the establishment and operation of a hydrometeorological system as required by Annex A,
- (f) assisting and cooperating with the Permanent Engineering Board in the discharge of its functions,
- (g) periodic calculation of accounts,
- (h) preparation of the hydroelectric operating plans and the flood control operating plans for the Canadian storage together with determination of the downstream power benefits to which Canada is entitled,
- (i) preparation of proposals to implement Article VIII and carrying out any disposal authorized or exchange provided for therein,
- (j) making appropriate arrangements for delivery to Canada of the downstream power benefits to which Canada is entitled including such matters as load factors for delivery, times and points of delivery, and calculation of transmission loss,
- (k) preparation and implementation of detailed operating plans that may produce results more advantageous to both countries than those that would arise from operation under the plans referred to in Annexes A and B.

3. The entities are authorized to make maintenance curtailments. Except in case of emergency, the entity responsible for a maintenance curtailment shall give notice to the corresponding Canadian or United States entity of the curtailment, including the reason therefor and the probable duration thereof and shall both schedule the curtailment with a view to minimizing its impact and exercise due diligence to resume full operations.

4. Canada and the United States of America may by an exchange of notes empower or charge the entities with any other matter coming within the scope of the Treaty.

ARTICLE XV ***Permanent Engineering Board***

1. A permanent Engineering Board is established consisting of four members, two to be appointed by Canada and two by the United States of America. The initial appointments shall be made within three months of the ratification date.

2. The Permanent Engineering Board shall:

- (a) assemble records of the flows of the Columbia River and the Kootenay River at the Canada-United States of America boundary;
- (b) report to Canada and the United States of America whenever there is substantial deviation from the hydroelectric and flood control operating plans and if appropriate include in the report recommendations for remedial action and compensatory adjustments;
- (c) assist in reconciling differences concerning technical or operational matters that may arise between the entities;

(d) make periodic inspections and require reports as necessary from the entities with a view to ensuring that the objectives of the Treaty are being met;

(e) make reports to Canada and the United States of America at least once a year of the results being achieved under the Treaty and make special reports concerning any matter which it considers should be brought to their attention;

(f) investigate and report with respect to any other matter coming within the scope of the Treaty at the request of either Canada or the United States of America.

3. Reports of the Permanent Engineering Board made in the course of the performance of its functions under this Article shall be prima facie evidence of the facts therein contained and shall be accepted unless rebutted by other evidence.

4. The Permanent Engineering Board shall comply with directions, relating to its administration and procedures, agreed upon by Canada and the United States of America as evidenced by an exchange of notes.

ARTICLE XVI *Settlement of Differences*

1. Differences arising under the Treaty which Canada and the United States of America cannot resolve may be referred by either to the International Joint Commission for decision.

2. If the International Joint Commission does not render a decision within three months of the referral or within such other period as may be agreed upon by Canada and the United States of America, either may then submit the difference to arbitration by written notice to the other.

3. Arbitration shall be a tribunal composed of a member appointed by Canada, a member appointed by the United States of America and a member appointed jointly by Canada and the United States of America who shall be Chairman. If within six weeks of the delivery of a notice under paragraph (2) either Canada or the United States of America has failed to appoint its member, or they are unable to agree upon the member who is to be Chairman, either Canada or the United States of America may request the President of the International Court of Justice to appoint the member or members. The decision of a majority of the members of an arbitration tribunal shall be the decision of the tribunal.

4. Canada and the United States of America shall accept as definitive and binding and shall carry out any decision of the International Joint Commission or an arbitration tribunal.

5. Provision for the administrative support of a tribunal and for remuneration and expenses of its members shall be as agreed in an exchange of notes between Canada and the United States of America.

6. Canada and the United States of America may agree by an exchange of notes on alternative procedures for settling differences arising under the Treaty, including reference of any difference to the International Court of Justice for decision.

ARTICLE XVII *Restoration of Pre-Treaty Legal Status*

1. Nothing in this Treaty and no action taken or foregone pursuant to its provisions shall be deemed, after its termination or expiration, to have abrogated or modified any of the rights or obligations of Canada or the United States of America under then existing international law, with respect to the uses of the water resources of the Columbia River basin.

2. Upon termination of this Treaty, the Boundary Waters Treaty, 1909, shall, if it has not been terminated, apply to the Columbia River basin, except insofar as the provisions of that Treaty may be inconsistent with any provision of this Treaty which continues in effect.

3. Upon termination of this Treaty, if the Boundary Waters Treaty, 1909, has been terminated in accordance with Article XIV of that Treaty, the provisions of Article II of that Treaty shall continue to apply to the waters of the Columbia River basin.

4. If upon the termination of this Treaty Article II of the Boundary Waters Treaty, 1909, continues in force by virtue of paragraph (2) of this Article the effect of Article II of that Treaty with respect to the Columbia River basin may be terminated by either Canada or the United States of America delivering to the other one year's written notice to that effect; provided however that the notice may be given only after the termination of this Treaty.

5. If, prior to the termination of this Treaty, Canada undertakes works usable for and relating to a diversion of water from the Columbia River basin, other than works authorized by or under-taken for the purpose of exercising a right under Article XIII or any other provision of this Treaty, paragraph (3) of this Article shall cease to apply one year after delivery by either Canada or the United States of America to the other of written notice to that effect.

ARTICLE XVIII ***Liability for Damage***

1. Canada and the United States of America shall be liable to the other and shall make appropriate compensation to the other in respect of any act, failure to act, omission or delay amounting to a breach of the Treaty or any of its provisions other than an act, failure to act, omission or delay occurring by reason of war, strike, major calamity, act of God, uncontrollable force or maintenance curtailment.

2. Except as provided in paragraph (1) neither Canada nor the United States of America shall be liable to the other or to any person in respect of any injury, damage or loss occurring in the territory of the other caused by any act, failure to act, omission or delay under the Treaty whether the injury, damage or loss results from negligence or otherwise.

3. Canada and the United States of America, each to the extent possible within its territory, shall exercise due diligence to remove the cause of and to mitigate the effect of any injury, damage or loss occurring in the territory of the other as a result of any act, failure to act, omission or delay under the Treaty.

4. Failure to commence operation as required by Articles IV and XII is not a breach of the Treaty and does not result in the loss of rights under the Treaty if the failure results from a delay that is not wilful or reasonably avoidable.

5. The compensation payable under paragraph (1):

(a) in respect of a breach by Canada of the obligation to commence full operation of a storage, shall be forfeiture of entitlement to downstream power benefits resulting from the operation of that storage, after operation commences, for a period equal to the period between the day of commencement of operation and the day when commencement should have occurred;

(b) in respect of any other breach by either Canada or the United States of America, causing loss of power benefits, shall not exceed the actual loss in revenue from the sale of hydroelectric power.

ARTICLE XIX ***Period of Treaty***

1. The Treaty shall come into force on the ratification date.
2. Either Canada or the United States of America may terminate the Treaty other than Article XIII (Except paragraph (1) thereof), Article XVII and this Article at any time after the Treaty has been in force for sixty years if it has delivered at least ten years written notice to the other of its intention to terminate the Treaty.
3. If the Treaty is terminated before the end of the useful life of a dam built under Article XII then, notwithstanding termination, Article XII remains in force until the end of the useful life of the dam.
4. If the Treaty is terminated before the end of the useful life of the facilities providing the storage described in Article IV(3) and if the conditions described therein exist then, notwithstanding termination, Articles IV(3) and VI(4) and (5) remain in force until either the end of the useful life of those facilities or until those conditions cease to exist, whichever is the first to occur.

ARTICLE XX
Ratification

The instruments of ratification of the Treaty shall be exchanged by Canada and the United States of America at Ottawa, Canada.

ARTICLE XXI
Registration with the United Nations

In conformity with Article 102 of the Charter of the United Nations, the Treaty shall be registered by Canada with the Secretariat of the United Nations.

This Treaty has been done in duplicate copies in the English language.

IN WITNESS WHEREOF the undersigned, duly authorized by their respective Governments, have signed this Treaty at Washington, District of Columbia, United States of America, this seventeenth day of January, 1961.

For Canada

John G. Diefenbaker
Prime Minister of Canada
E.D. Fulton
Minister of Justice
A.D.P. Heeney
*Ambassador Extraordinary and Plenipotentiary of
Canada to the United States of America*

For the United States of America

Dwight D. Eisenhower
President of the United States of America
Christian A. Herter
Secretary of State
Elmer F. Bennett
Under Secretary of the Interior

ANNEX A *Principles of Operation*

General:

1. The Canadian storage provided under Article II will be operated in accordance with the procedures described herein.
2. A hydrometeorological system, including snow courses, precipitation stations and stream flow gauges will be established and operated, as mutually agreed by the entities and in consultation with the Permanent Engineering Board, for use in establishing data for detailed programming of flood control and power operations. Hydrometeorological information will be made available to the entities in both countries for immediate and continuing use in flood control and power operations.
3. Sufficient discharge capacity at each dam to afford the desired regulation for power and flood control will be provided through outlet works and turbine installations as mutually agreed by the entities. The discharge capacity provided for flood control operations will be large enough to pass inflow plus sufficient storage releases during the evacuation period to provide the storage space required. The discharge capacity will be evaluated on the basis of full use of any conduits provide for that purpose plus one half the hydraulic capacity of the turbine installation at the time of commencement of the operation of storage under the Treaty.
4. The outflows will be in accordance with storage reservation diagrams and associated criteria established for flood control purposes and with reservoir-balance relationships established for power operations. Unless otherwise agreed by the entities the average weekly outflows shall not be less than 3000 cubic feet per second at the dam described in Article II(2)(a), not less than 5000 cubic feet per second at the dam described in Article II(2)(b), and not less than 1000 cubic feet per second at the dam described in Article II(2)(c). These minimum average weekly releases may be scheduled by the Canadian entity as required for power or other purposes.

Flood Control:

5. For flood control operation, the United States entity will submit flood control operating plans which may consist of or include flood control storage reservation diagrams and associated criteria for each of the dams. The Canadian entity will operate in accordance with these diagrams or any variation which the entities agree will not derogate from the desired aim of the flood control plan. The use of these diagrams will be based on data obtained in accordance with paragraph 2. The diagrams will consist of relationships specifying the flood control storage reservations required at indicated times of the year for volumes of forecast runoff. After consultation with the Canadian entity the United States entity may from time to time as conditions warrant adjust these storage reservation diagrams within the general limitations of flood control operation. Evacuation of the storages listed hereunder will be guided by the flood control storage reservation diagrams and refill will be as requested by the United States entity after consultation with the Canadian entity. The general limitations of flood control operation are as follows:
 - (a) The Dam described in Article II(2)(a) - The reservoir will be evacuated to provide up to 80,000 acre-feet of storage, if required, for flood control use by May 1 of each year.
 - (b) The Dam described in Article II(2)(b) - The reservoir will be evacuated to provide up to 7,100,000 acre-feet of storage, if required, for flood control use by May 1 of each year.
 - (c) The Dam described in Article II(2)(c) - The reservoir will be evacuated to provide up to 700,000 acre-feet of storage, if required, for flood control use by April 1 of each year and up to 1,270,000 acre-feet of storage, if required, for flood control use by May 1 of each year.

(d) The Canadian entity may exchange flood control storage provided in the reservoir referred to in subparagraph (b) for additional storage provided in the reservoir referred to in sub-paragraph (a) if the entities agree that the exchange would provide the same effectiveness for control of floods on the Columbia River at The Dalles, Oregon.

Power:

6. For power generating purposes the 15,500,000 acre-feet of Canadian storage will be operated in accordance with operating plans designed to achieve optimum power generation downstream in the United States of America until such time as power generating facilities are installed at the site referred to in paragraph 5(a) or at sites in Canada downstream therefrom.

7. After at-site power is developed at the site referred to in paragraph 5(a) or power generating facilities are placed in operation in Canada downstream from that site, the storage operation will be changed so as to be operated in accordance with operating plans designed to achieve optimum power generation at-site in Canada and downstream in Canada and the United States of America, including consideration of any agreed electrical coordination between the two countries. Any reduction in the downstream power benefits in the United States of America resulting from that change in operation of the Canadian storage shall not exceed in any one year the reduction in downstream power benefits in the United States of America which would result from reducing by 500,000 acre-feet the Canadian storage operated to achieve optimum power generation in the United States of America and shall not exceed at any time during the period of the Treaty the reduction in downstream power benefits in the United States of America which would result from similarly reducing the Canadian storage by 3,000,000 acre-feet.

8. After at-site power is developed at the site referred to in paragraph 5(a) or power generating facilities are placed in operation in Canada downstream from that site, storage may be operated to achieve optimum generation of power in the United States of America alone if mutually agreed by the entities in which event the United States of America shall supply power to Canada to offset any reduction in Canadian generation which would be created as a result of such operation as compared to operation to achieve optimum power generation at-site in Canada and downstream in Canada and the United States of America. Similarly, the storage may be operated to achieve optimum generation of power in Canada alone if mutually agreed by the entities in which event Canada shall supply power to the United States of America to offset any reduction in United States generation which would be created as a result of such operation as compared to operation to achieve optimum power generation at-site in Canada and downstream in Canada and the United States of America.

9. Before the first storage becomes operative, the entities will agree on operating plans and the resulting downstream power benefits for each year until the total of 15,500,000 acre-feet of storage in Canada becomes operative. In addition, commencing five years before the total of 15,500,000 acre-feet of storage is expected to become operative, the entities will agree annually on operating plans and the resulting downstream power benefits for the sixth succeeding year of operation thereafter. This procedure will continue during the life of the Treaty, providing to both the entities, in advance, an assured plan of operation of the Canadian storage and a determination of the resulting downstream power benefits for the next succeeding five years.

ANNEX B
Determination of Downstream Power Benefits

1. The downstream power benefits in the United States of America attributable to operation in accordance with Annex A of the storage provided by Canada under Article II will be determined in advance and will be the estimated increase in dependable hydroelectric capacity in kilowatts for agreed critical stream flow periods and the increase in average annual usable hydroelectric energy output in kilowatt hours on the basis of an agreed period of stream flow record.

2. The dependable hydroelectric capacity to be credited to Canadian storage will be the difference between the average rates of generation in kilowatts during the appropriate critical stream flow periods for the United States of America base system, consisting of the projects listed in the table, with and without the addition of the Canadian storage, divided by the estimated average critical period load factor. The capacity credit shall not exceed the difference between the capability of the base system without Canadian storage and the maximum feasible capability of the base system with Canadian storage, to supply firm load during the critical stream flow periods.

3. The increase in the average annual usable hydroelectric energy will be determined by first computing the difference between the available hydroelectric energy at the United States base system with and without Canadian storage. The entities will then agree upon the part of available energy which is usable with and without Canadian storage, and the difference thus agreed will be the increase in average annual usable hydroelectric energy. Determination of the part of the energy which is usable will include consideration of existing and scheduled transmission facilities and the existence of markets capable of using the energy on a contractual basis similar to the then existing contracts. The part of the available energy which is considered usable shall be the sum of:

(a) the firm energy,

(b) the energy which can be used for thermal power displacement in the Pacific Northwest Area as defined in Paragraph 7, and

(c) the amount of the remaining portion of the available energy which is agreed by the entities to be usable and which shall not exceed in any event 40% of that remainder.

4. An initial determination of the estimated downstream power benefits in the United States of America from Canadian storage added to the United States base system will be made before any of the Canadian storage becomes operative. This determination will include estimates of the downstream power benefits for each year until the total of 15,500,000 acre-feet of Canadian storage becomes operative.

5. Commencing five years before the total of 15,500,000 acre-feet of storage is expected to become operative, estimates of downstream power benefits will be calculated annually for the sixth succeeding year on the basis of the assured plan of operation for that year.

6. The critical stream flow period and the details of the assured plan of operation will be agreed upon by the entities at each determination. Unless otherwise agreed upon by the entities, the determination of the downstream power benefits shall be based upon stream flows for the twenty year period beginning with July 1928 as contained in the report entitled Modified Flows at Selected Power Sites - Columbia River Basin, dated June 1957. No retroactive adjustment in downstream power benefits will be made at any time during the period of the Treaty. No reduction in the downstream power benefits credited to Canadian storage will be made as a result of the load estimate in the United States of America, for the year for which the determination is made, being less than the load estimate for the preceding year.

7. In computing the increase in dependable hydroelectric capacity and the increase in average annual hydroelectric energy, the procedure shall be in accordance with the three steps described below and shall encompass the loads of the Pacific Northwest Area. The Pacific Northwest Area for purposes of these determinations shall be Oregon, Washington, Idaho, and Montana west of the Continental Divide but shall exclude areas served on the ratification date by the California Oregon Power Company and the Utah Power and Light Company.

Step I - The system for the period covered by the estimate will consist of the Canadian storage, the United States base system, any thermal installation operated in coordination with the base system, and additional hydroelectric projects which will provide storage releases usable by the base system or which will use storage releases that are usable by the base system. The installations included in this system will be those required, with allowance for adequate reserves, to meet the forecast power load to be served by this system in the United States of America, including the estimated flow of power at points of inter-connection with adjacent areas, subject to paragraph 3, plus the portion of the entitlement of Canada that is expected to be used in Canada. The capability of this system to supply this load will be determined on the basis that the system will be operated in accordance with the established operating procedures of each of the projects involved.

Step II - A determination of the energy capability will be made using the same thermal installation as in Step I, the United States base system with the same installed capacity as in Step I and Canadian storage.

Step III - A similar determination of the energy capability will be made using the same thermal installation as in Step I and the United States base system with the same installed capacity as in Step I.

8. The downstream power benefits to be credited to Canadian storage will be the differences between the determinations in Step II and Step III in dependable hydroelectric capacity and in average annual usable hydroelectric energy, made in accordance with paragraphs 2 and 3.

ANNEX B - TABLE - BASE SYSTEM

Project	Stream	Stream		Normal Pool Feet	Elev. Tailwater Feet	Gross Head Feet	Initial Install. # of Units	Initial Install. Plant Kilowatts (Nameplate)	Estimated Ultimate Install.	
		Mile Above Mouth	Usable Storage Acre-Feet						# of Units	Plant Kilowatts (Nameplate)
Hungry Horse	SFk Flathead	5	3,161,000 ⁽⁴⁾	3560	3083	477	4	285,000	4	285,000
Kerr	Flathead	73	1,219,000	2893	2706	187	3	168,000	3	168,000
Thompson Falls	Clark Fork	279	Pondage	2396	2336	60	6	30,000	8	65,000
Noxon Rapids	Clark Fork	170	Pondage	2331	2179	152	4	336,000	5	420,000
Cabinet Gorge	Clark Fork	150	Pondage	2175	2078	97	4	200,000	6	300,000
Albeni Falls	Pend Oreille	90	1,155,000	2062	2034	28	3	42,600	3	42,600
Box Canyon	Pend Oreille	34	Pondage	2031	1989	42	4	60,000	4	60,000
Grand Coulee	Columbia	597	5,232,000 ⁽⁴⁾	1290 ^(3,4)	947	343	18	1,944,000	34	3,672,000
Chief Joseph	Columbia	546	Pondage	946	775	171	16	1,024,000	27	1,728,000
Wells (1)	Columbia	516	Pondage	775	707	68	6	400,000	10	666,700
Rocky Reach	Columbia	474	Pondage	707	614	93	7	711,550	11	1,118,150
Rock Island	Columbia	453	Pondage	608	570	38	10	212,100	10	212,100
Wanapum	Columbia	415	Pondage	570	486	84	10	831,250	16	1,330,000
Priest Rapids	Columbia	397	Pondage	486	406	80	10	788,500	16	1,261,600
Brownlee	Snake	285	974,000	2077	1805	272	4	360,400	6	540,600
Oxbow	Snake	273	Pondage	1805	1683	122	4	190,000	5	237,500
Ice Harbor	Snake	10	Pondage	440	343	97	3	270,000	6	540,000
McNary	Columbia	292	Pondage	340	265	75	14	980,000	20	1,400,000
John Day	Columbia	216	Pondage	265	161	104	8	1,080,000	20	2,700,000
The Dalles	Columbia	192	Pondage	160	74	86	16 ⁽²⁾	1,119,000	24 ⁽²⁾	1,743,000
Bonneville	Columbia	145	Pondage	74	15	59	10	518,400	16	890,400
Kootenay Lk	Kootenay	16	673,000	1745	--	--	--	--	--	--
Chelan	Chelan	0	676,000	1100	707	393	2	48,000	4	96,600
Couer d'Alene L.	Couer d'Alene	102	223,000	2128	--	--	--	--	--	--
TOTAL 24 PROJECTS			13,313,000⁽⁴⁾				3128	11,598,800	258	19,476,600

- (1) The Wells project is not presently under construction; when this project or any other project on the main stem of the Columbia River is completed, they will be integral components of the base system.
- (2) Includes two 13,500 kilowatt units for fish attraction water.
- (3) With flashboards.
- (4) In determining the base system capabilities with and without Canadian storage the Hungry Horse reservoir storage will be limited to 3,008,000 acre-feet (normal full pool elevation of 3560 feet) and the Grand Coulee project will not include the effect of adding flashboards, limiting the storage to 5,072 acre-feet (normal full pool elevation of 1288 feet). The total usable storage of the base system as so adjusted will be 13,000,000 acre-feet.

Protocol

ANNEX TO EXCHANGE OF NOTES

*Dated January 22, 1964 Between the Governments of Canada
And The United States Regarding the Columbia River Treaty*

I. If the United States entity should call upon Canada to operate storage in the Columbia River Basin to meet flood control needs of the United States of America pursuant to Article IV(2)(b) or Article IV(3) of the Treaty, such call shall be made only to the extent necessary to meet forecast flood control needs in the territory of the United States of America that cannot adequately be met by flood control facilities in the United States of America in accordance with the following conditions:

(1) Unless otherwise agreed by the Permanent Engineering Board, the need to use Canadian flood control facilities under Article IV(2)(b) of the Treaty shall be considered to have arisen only in the case of potential floods which could result in a peak discharge in excess of 600,000 cubic feet per second at The Dalles, Oregon, assuming the use of all related storage in the United States of America existing and under construction in January 1961, storage provided by any dam constructed pursuant to Article XII of the Treaty and the Canadian storage described in Article IV(2)(a) of the Treaty.

(2) The United States entity will call upon Canada to operate storage under Article IV(3) of the Treaty only to control potential floods in the United States of America that could not be adequately controlled by all the related storage facilities in the United States of America existing at the expiration of 60 years from the ratification date but in no event shall Canada be required to provide any greater degree of flood control under Article IV(3) of the Treaty than that provided for under Article IV(2) of the Treaty.

(3) A call shall be made only if the Canadian entity has been consulted whether the need for flood control is, or is likely to be, such that it cannot be met by the use of flood control facilities in the United States of America in accordance with subparagraphs (1) or (2) of this paragraph. Within ten days of receipt of a call, the Canadian entity will communicate its acceptance, or its rejection or proposals for modification of the call, together with supporting considerations. When the communication indicates rejection or modification of the call the United States entity will review the situation in the light of the communication and subsequent developments and will then withdraw or modify the call if practicable. In the absence of agreement on the call or its terms the United States entity will submit the matter to the Permanent Engineering Board provided for under Article XV of the Treaty for assistance as contemplated in Article XV(2)(c) of the Treaty. The entities will be guided by any instructions issued by the Permanent Engineering Board. If the Permanent Engineering Board does not issue instructions within ten days of receipt of a submission the United States entity may renew the call for any part or all of the storage covered in the original call and the Canadian entity shall forthwith honor the request.

II. In preparing the flood control operating plans in accordance with paragraph 5 of Annex A of the Treaty, and in making calls to operate for flood control pursuant to Articles IV(2)(b) and IV(3) of the Treaty, every effort will be made to minimize flood damage in both Canada and the United States of America.

III. The exchange of Notes provided for in Article VIII(1) of the Treaty shall take place contemporaneously with the exchange of the Instruments of Ratification of the Treaty provided for in Article XX of the Treaty.

IV. (1) During the period and to the extent that the sale of Canada's entitlement to downstream power benefits within the United States of America as a result of an exchange of Notes pursuant to Article

VIII(1) of the Treaty relieves the United States of America of its obligation to provide east-west standby transmission service as called for by Article X(1) of the Treaty, Canada is not required to make payment for the east-west standby transmission service with regard to Canada's entitlement to downstream power benefits sold in the United States of America.

(2) The United States of America is not entitled to any payments of the character set out in subparagraph (1) of this paragraph in respect of that portion of Canada's entitlement to down-stream power benefits delivered by the United States of America to Canada at any point on the Canada-United States of America boundary other than at a point near Oliver, British Columbia, and the United States of America is not required to provide the east-west standby transmission service referred to in subparagraph (1) of this paragraph in respect of the portion of Canada's entitlement to downstream power benefits which is so delivered.

V. Inasmuch as control of historic streamflows of the Kootenay River by the dam provided for in Article XII(1) of the Treaty would result in more than 200,000 kilowatt years per annum of energy benefit downstream in Canada, as well as important flood control protection to Canada, and the operation of that dam is therefore of concern to Canada, the entities shall, pursuant to Article XIV(2)(a) of the Treaty, cooperate on a continuing basis to coordinate the operation of that dam with the operation of hydroelectric plants on the Kootenay River and elsewhere in Canada in accordance with the provisions of Article XII(5) and Article XII(6) of the Treaty.

VI. (1) Canada and the United States of America are in agreement that Article XIII(1) of the Treaty provides to each of them a right to divert water for a consumptive use.

(2) Any diversion of water from the Kootenay River when once instituted under the provisions of Article XIII of the Treaty is not subject to any limitation as to time.

VII. As contemplated by Article IV(1) of the Treaty, Canada shall operate the Canadian storage in accordance with Annex A and hydroelectric operating plans made thereunder. Also, as contemplated by Annexes A and B of the Treaty and Article XIV(2)(k) of the Treaty, these operating plans before they are agreed to by the entities will be conditioned as follows:

(1) As the downstream power benefits credited to Canadian storage decrease with time, the storage required to be operated by Canada pursuant to paragraphs 6 and 9 of Annex A of the Treaty, will be that required to produce those benefits.

(2) The hydroelectric operating plans, which will be based on Step I of the studies referred to in paragraph 7 of Annex B of the Treaty, will provide a reservoir-balance relationship for each month of the whole of the Canadian storage committed rather than a separate relationship for each of the three Canadian storages. Subject to compliance with any detailed operating plan agreed to by the entities as permitted by Article XIV(2)(k) of the Treaty, the manner of operation which will achieve the specific storage or release of storage called for in a hydroelectric operating plan consistent with optimum storage use will be at the discretion of the Canadian entity.

(3) Optimum power generation at-site in Canada and downstream in Canada and the United States of America referred to in paragraph 7 of Annex A of the Treaty will include power generation at-site and downstream in Canada of the Canadian storages referred to in Article II(2) of the Treaty, power generation in Canada which is coordinated therewith, downstream power benefits from the Canadian storage which are produced in the United States of America and measured under the terms of Annex B of the Treaty, power generation in the Pacific Northwest Area of the United States of America and power generation coordinated therewith.

VIII. The determination of downstream power benefits pursuant to Annex B of the Treaty, in respect of each year until the expiration of thirty years from the commencement of full operation in accordance with Article IV of the Treaty of that portion of the Canadian storage described in Article II of the Treaty which is last placed in full operation, and thereafter until otherwise agreed upon by the entities, shall be based upon stream flows for the thirty-year period beginning July 1928 as contained in the report "Extension of Modified Flows Through 1958 - Columbia River Basin" and dated June 29, 1961, by the Water Management Subcommittee of the Columbia Basin Inter-Agency Committee.

IX. (1) Each load used in making the determinations required by Steps II and III of paragraph 7 of Annex B of the Treaty shall have the same shape as the load of the Pacific Northwest area as that area is defined in that paragraph.

(2) The capacity credit of Canadian storage shall not exceed the difference between the firm load carrying capabilities of the projects and installations included in Step II of paragraph 7 of Annex B of the Treaty and the projects and installations included in Step III of paragraph 7 of Annex B of the Treaty.

X. In making all determinations required by Annex B of the Treaty the loads used shall include the power required for pumping water for consumptive use into the Banks Equalizing Reservoir of the Columbia Basin Federal Reclamation Project but mention of this particular load is not intended in any way to exclude from those loads any use of power that would normally be part of such loads.

XI. In the event operation of any of the Canadian storages is commenced at a time which would result in the United States of America receiving flood protection for periods longer than those on which the amounts of flood control payments to Canada set forth in Article VI(1) of the Treaty are based, the United States of America and Canada shall consult as to the adjustments, if any, in the flood control payments that may be equitable in the light of all relevant factors. Any adjustment would be calculated over the longer period or periods on the same basis and in the same manner as the calculation of the amounts set forth in Article VI(1) of the Treaty. The consultations shall begin promptly upon the determination of definite dates for the commencement of operation of the Canadian storages.

XII. Canada and the United States of America are in agreement that the Treaty does not establish any general principle or precedent applicable to waters other than those of the Columbia River Basin and does not detract from the application of the Boundary Waters Treaty, 1909, to other waters.

This page intentionally left blank

This page intentionally left blank

APPENDIX C

**LIST OF ACRONYMS
AND GLOSSARY OF TERMS**

This page intentionally left blank

**APPENDIX C. LIST OF ACRONYMS
AND GLOSSARY OF TERMS**

**LIST OF ACRONYMS/ABBREVIATIONS
AND GLOSSARY OF TERMS
RELATING TO THE COLUMBIA RIVER TREATY 2014/2024 PHASE 1
STUDIES AND REPORT**

[Based in part on the list of acronyms and glossary prepared by the Permanent Engineering Board Engineering Committee for the Columbia River Treaty Permanent Engineering Board, Treaty and Treaty-associated documents, and the BPA Dictionary]

ACRONYMS AND ABBREVIATIONS

aMW – Average MW

AOP - Assured Operating Plan

ARC - Assured Refill Curve

BC Hydro - British Columbia Hydro and Power Authority

BECC – Base Energy Content Curve

BPA - Bonneville Power Administration

CCL - Capacity Credit Limit

CE - Canadian Entitlement

cfs - cubic feet per second

CND - Canada

Corps - U.S. Army Corps of Engineers

CP - Critical Period

CRC - Critical Rule Curve

CRC1 - First Year Critical Rule Curve

CRT - Columbia River Treaty

CRTOC - Columbia River Treaty Operating Committee

CU - Called Upon

DDPB - Determination of Downstream Power Benefits

DOP - Detailed Operating Plan

EL - elevation

FCOP - Flood Control Operating Plan

FELCC - firm energy load carrying capability

FERC - Federal Energy Regulatory Commission

FLCC - firm load carrying capability

Flex – flexibility energy, Canada’s flexibility under the Treaty to operate individual projects for maximum Canadian benefits

FPLCC - firm peak load carrying capability

FRA – Flood Risk Assessment

GCL - Grand Coulee

HYDSIM - BPA’s Hydrologic Simulator Model

ICF - Initial Control Flow

IJC - International Joint Commission

Kaf - thousand acre-feet

KCFS - thousand cubic feet per second

KLBC – Kootenay Lake Board of Control

LCA – Libby Coordination Agreement

KSFD - thousand second-foot-days

Maf - million acre-feet

MW - megawatt

NGVD - National Geodetic Vertical Datum

ORC - Operating Rule Curve

ORCLL - Operating Rule Curve Lower Limit

PDR - Power Discharge Requirement

PEB - Permanent Engineering Board

PNWA - Pacific Northwest Area

PNCA - Pacific Northwest Coordination Agreement

PNW - Pacific Northwest

RPS - Renewable Portfolio Standards

SOA - Supplemental Operating Agreement

SRD - Storage Reservation Diagram

TDM - Thermal Displacement Market

TSR - Treaty Storage Regulation

URC - Upper Rule Curve

U.S. - United States of America

VarQ - Variable Discharge Flood Control

VRC - Variable Refill Curve

GLOSSARY

Acre-foot - The volume of water that will cover a one-acre [43, 560 square feet] area to a depth of one foot; one acre-foot equals 1233 cubic meters (325,000 gallons) of water.

Active Storage - That portion of the live storage capacity in which water will normally be stored or withdrawn for beneficial purposes, in compliance with operating agreements or restrictions.

Annexes A and B - Appendices to the Columbia River Treaty. Annex A deals with the principles of operation and Annex B with the determination of downstream power benefits. Annexes A and B are an integral part of the Treaty. (Treaty Article I)

Annual Firm Energy Capability – Annual FELCC: the firm energy load that the Pacific Northwest coordinated system is able to supply in a year from the firm resources of the coordinated system after deducting the required energy reserve and forced outage reserve.

Assured Operating Plan - One of the two reservoir system operating plans prepared each year to implement the Columbia River Treaty. The Assured Operating Plan is prepared six years in advance of the actual year of operation and defines the rule curves and other operating parameters to guide the operation of the system in a manner that realizes the benefits anticipated by the Treaty. This series of annual operating plans assures both Entities of the manner of operation of Canadian storage in advance for the next five years. The AOP establishes the generation potential of both systems, prescribes operating criteria and procedures to ensure that the potential will be realized, and serves as the basis for the Detailed Operating Plan in the actual year of operation. The downstream power benefits studies are conducted in conjunction with the AOP. (Treaty Article XIV-2h and Annex A Paragraph 9, Protocol VII)

Assured Refill Curve - The Assured Refill Curve indicates the end-of-month storage content required to ensure refill of the reservoir while releasing power discharge requirement outflows. The ARC is based on 1931 historical volume of inflow during the refill period. The year 1931 represents the second lowest historical January through July volume inflow for the Columbia River for the period 1928 to 1958 measured near The Dalles, Oregon.

Average Annual Energy or Average Annual Generation - The average yearly energy production of a hydroelectric project or system as determined from a long-term streamflow record. For purposes of Treaty downstream power benefit determinations, the average output of hydroelectric projects is based on regulation studies using the 30 years of historical streamflows experienced during the period 1928-58, as modified by appropriate irrigation depletions. (Protocol Section VIII)

Average Annual Usable Energy - That portion of the average annual energy production of the United States base system that is usable as defined by Annex B to the Treaty—specifically, firm energy, plus thermal displacement energy, plus up to 40 percent of remaining energy. This is one of the two components of the downstream power benefits. (Annex B Paragraph 3)

Average Annual Usable Secondary Energy - A hydro system's average annual generation less its firm energy capability. This is one of the three parameters used in Step I to evaluate generation optimality.

Average Critical Period Load Factor - The average of the monthly load factors during the critical streamflow period. (Treaty Article I)

Average Megawatt - A unit of average energy output over a specified time period (total energy in megawatt-hours divided by the number of hours in the time period). Used in the Pacific Northwest for comparing a plant or system's energy output (average power output) to its capacity.

Base System (or U.S. Base System) - The plants, works, and facilities listed in the table in Annex B of the Treaty, as enlarged from time to time by the installation of additional generating facilities, together with any projects that may be constructed on the mainstem Columbia River in the United States. The table in Annex B is in essence the 1961 Columbia River hydropower system. (Treaty Article I and Annex B)

B.C. Hydro System - The transmission facilities located within the Province of British Columbia and owned by B.C. Hydro. (Entity Agreement for Delivery and Disposition of the Canadian Entitlement, page 3)

Called Upon - Storage the U.S. can call upon beginning in the year 2024 for flood control. See also On-Call.

Canadian Entitlement - Under the Columbia River Treaty, Canada's 50-percent share of the increase in usable energy and capacity downstream ["Downstream Power Benefits"] from and based on the filling of the three reservoirs at Duncan, Keenleyside, and Mica storage dams in Canada and the reservoir behind Libby Dam in Montana.

Canadian Entitlement Capacity - Dependable hydroelectric capacity forming part of the Canadian Entitlement, expressed in megawatts. (Entity Agreement for Delivery and Disposition of the Canadian Entitlement, page 4, and Canadian Entitlement Capacity Reduction Agreement, page 3)

Canadian Entitlement Energy - Average usable hydroelectric energy forming part of the Canadian Entitlement, expressed in megawatts. (Entity Agreement for Delivery and Disposition of the Canadian Entitlement, page 4)

Canadian Entity - The agency that implements the Columbia River Treaty for Canada. The Canadian Entity for the purposes of the Treaty's Article XIV is B.C. Hydro, which is a Crown Corporation of British Columbia. For the purpose of disposing of the Canadian Entitlement to downstream power benefits directly in the United States, the Canadian Entity is the government of British Columbia.

Canadian Re-operation - Five studies are generally performed to complete the AOP and DDPB studies. Once the three U.S. optimum studies are complete, the next stage in the process is to complete the “Canadian Re-operation.” This stage involves developing project-specific operating criteria for Canadian storage projects that optimize generation in both countries.

Canadian Treaty Storage - The 15.5 Maf of storage provided by Canada under Article II of the Treaty at the Mica Creek, Arrow Lakes, and Duncan Lake projects. Also called Treaty Storage. (Treaty Article I)

Canadian System - The Canadian projects included in the AOP and DOP studies. In the most recent AOPs, the Canadian System has been defined as Duncan, Arrow (Keenleyside), Mica, Revelstoke, Kootenay Canal, Corra Lynn, Upper Bonnington, Lower Bonnington, South Slokan, Brilliant, Seven Mile, and Waneta.

Capability - The maximum load that a generator, turbine, power plant, transmission circuit, or power system can supply under specified conditions for a given time interval without exceeding approved limits.

Capacity - The load for which a generator, transmission circuit, power plant, or system is rated. May be used synonymously with capability.

Capacity Credit - The dependable hydroelectric capacity to be credited to Canadian storage in accordance with Annex B of the Treaty and paragraphs IX and X of the Protocol to the Treaty. (Entity Agreement for Delivery and Disposition of the Canadian Entitlement, page 4, and Canadian Entitlement Capacity Reduction Agreement, page 3)

Capacity Credit Limit - The Treaty specifies that the dependable hydroelectric capacity benefit shall not exceed the difference between the capability of the base system without Canadian storage and the maximum feasible capability of the base system with Canadian storage to supply firm load during the critical streamflow periods.

Columbia River Treaty - The 1961 Treaty, ratified in 1964, between the United States and Canada relating to cooperative development of the water resources of the Columbia River Basin, and Annexes A and B to that Treaty.

Coordinated Hydro Load - [also Residual Hydro Load] The treatment within the PNWA of all hydro-served loads and portions of load of a service control area proportionate to that area’s hydro generation as though it were all a single load of a single control area; the total load minus all resources that are not coordinated hydro.

Coordinated System - Contractually, the system of hydroelectric projects located on the U.S. portion of the Columbia River and major tributaries that are operated together on a coordinated basis under the terms of the Pacific Northwest Coordination Agreement. The term is sometimes used in a more general sense to include also those projects that are operated by utilities not participating in the Coordination Agreement.

Critical Period - The historical streamflow period when the water available from reservoir releases plus the natural streamflow is capable of producing the least amount of hydroelectric power in meeting system load requirements. Normally the critical period begins with the initial release of stored water from full reservoir conditions and ends with the reservoirs empty. (Treaty Article I) Also defined as the streamflow sequence during the historical record when water available from storage operated optimally to maximize power within all non-power constraints is capable of producing the least amount of FELCC shaped the same as the hydro firm load (i.e., uniform surplus/deficit).

Critical Period System Regulation Study - The regulation that develops critical rule curves for each reservoir and determines the length of the critical period and the firm energy load carrying capability of the system.

Critical Rule Curves - Critical rule curves, developed for each reservoir by the Critical Period System Regulation Study, are the end-of-month storage contents attained by the storage reservoirs. A critical rule curve provides a monthly guide to reservoir storage drafts and fills to provide an optimum power operation to meet system FELCC during periods of low inflows. In multiple-year critical periods, there will be a critical rule curve for each corresponding year of the critical period.

Dependable Capacity - For purposes of Treaty computations, dependable hydroelectric capacity to be credited to Canadian storage is defined as (a) the difference in the average rates of generation during the critical period with and without Canadian storage, divided by (b) the average of the monthly load factors during the critical period of the Pacific Northwest area, as determined from the Step I study. (Annex B Paragraph 2)

Dependable Peaking Capability - The reliably expected maximum output of a generating plant or plants during a specified peak-load period.

Detailed Operating Plan - The Detailed Operating Plan is similar to the Assured Operating Plan except that it is prepared immediately prior to each operating year. The DOP is developed from the AOP for that year and reflects the latest load, resource, flood control, and other pertinent data as mutually agreed to by the Entities. The Detailed Operating Plan serves as a guide and provides criteria for actual operation of the Canadian storage during the immediately ensuing operating year. (Treaty Article XIV-2(k))

Determination of Downstream Power Benefits - The calculation of downstream power benefits, both energy and capacity, in the United States resulting from Canadian Treaty Storage. This calculation is made annually in conjunction with the Assured Operating Plan.

Determination of Thermal Displacement Market - Calculation of the portion of generation in Columbia Basin from U.S. Step I thermal plants that can potentially be displaced with hydroelectric secondary energy minus System Sales, with System Sales being uniformly distributed over all months in the year. This computation is required by the Columbia River Treaty.

Discharge - Volume of water released from or through a project at a given time, usually expressed in cubic feet per second.

Downstream Power Benefit - The difference in the average annual usable energy and dependable capacity capable of being generated in the United States with and without the use of Canadian Treaty storage. (Treaty Article VII and Annex B)

Drawdown - The distance that the water surface of a reservoir is lowered from a given elevation as the result of the withdrawal of water due to discharge requirements exceeding inflows. This term is also used to refer to the maximum drawdown for power operation, from normal full pool to minimum power pool. Although drawdown is usually expressed in feet of elevation, it is sometimes expressed in terms of millions of acre-feet of storage withdrawn.

Drawdown Period (Evacuation Period) - That portion of the annual reservoir operation cycle when reservoirs are drafted to provide space for flood control and to maximize energy production; on the Columbia River system, this period typically extends from September 1 through April 15. PNCA defines the drawdown period more specifically in terms of energy in storage (PNCA Section 2k).

End-of-Month Contents - Volume of storage contained in a reservoir at the end of a given month, usually expressed in millions of acre-feet.

Energy Content Curve - As defined by the PNCA, the ECC is a guide to the use of storage water from each reservoir in the coordinated system that is used to define certain rights, entitlements, obligations, and limitations. ECCs are designed to provide sufficient storage at all times so that the coordinated system will be able to generate its firm energy load carrying capability under a recurrence of any historical streamflow sequence. As a practical matter, the ECC defines the level of drawdown below which no secondary energy loads will be carried. The ECC (sometimes called the Base Energy Content Curve) defines the reservoir levels that must be maintained to ensure that reservoirs will refill under 1931 (the third worst) water conditions. It is the higher of two curves—the Critical Rule Curve and the Assured Refill Curve—and its upper limit is the Flood Control Rule Curve.

Energy Entitlement - One-half of the difference between the Step II usable energy and the Step III usable energy (downstream benefits).

Entities - The entities designated by Canada and the United States under Article XIV of the Treaty to formulate and carry out the operating arrangements necessary to implement the Treaty. (Treaty Articles I and XIV) See United States Entity and Canadian Entity.

Firm Energy - Electric energy that is considered to have assured availability to the customer to meet all or any agreed-upon portion of the customer's firm load requirements.

Firm Energy Load Carrying Capability - As defined in the PNCA, FELCC is the firm energy load that the Pacific Northwest coordinated system is able to supply in any period from the firm

resources of the coordinated system after deducting the required energy reserve and forced outage reserve. Also called Firm Energy Capability.

Firm Hydro Energy - The firm energy capability of the hydro system, based on certain specified probability considerations. Firm hydro energy is determined for Treaty studies using the 1928-1958 historical water sequence and calculating the maximum amount of energy load that can be served in the worst water sequence and utilizing all available storage.

Firm Load - That part of the system load that must be met with firm power.

Firm Load Carrying Capability - The maximum amount of annual firm energy (shaped load) that the system can continuously support while drafting the active storage of the system from full to empty under the most adverse sequence of streamflows occurring within the adopted historical record (the Critical Period); collectively, Firm Energy Load Carrying Capability and Firm Peak Load Carrying Capability.

Firm Power - Power that is considered to have assured availability to the customer to meet all or any agreed-upon portion of a customer's load requirements. It is firm energy supported by sufficient capacity to fit the load pattern. The availability of firm power is based on the same probability considerations as is firm energy.

Flex operation - Canada's operation of individual projects for maximum Canadian benefits, so long as the flow at the border is the same as that specified in the operating plan.

Flood Control Curve - 1) Mandated and coordinated by the Corps of Engineers, a graph or table representation showing the reservoir drawdown necessary to control floods; 2) Specification of flood control storage space maintained to meet local and system flood control requirements, then used as an input to HYDSIM as monthly storage upper limits.

Flood Control Operating Plan - An operating plan that prescribes criteria and procedures by which the Mica, Duncan, Arrow, and Libby reservoirs are to be operated to achieve the flood control objectives of the Treaty. The Flood Control Operating Plan is prepared by the Entities and consists of flood control storage reservation diagrams and associated criteria for each of the reservoirs. (Annex A Paragraph 5 and FCOP Section 1-2)

Flood Control Refill Curves - Curves used to provide a 95 percent confidence level of refill. Flood Control Refill Curves help guide the refill of reservoirs during the spring refill period and ensure that the flood control regulation does not adversely affect refill insofar as possible. The refill curves define the upper reservoir elevation at any point during the refill period.

Flood Control Refill Period - Commences 10 days prior to the date the unregulated mean daily discharge is forecast to first exceed the controlled flow objective at The Dalles. The end of the Flood Control Refill Period will be when no further flood potential exists at any of the damage areas.

Flood Control Rule Curve - Flood Control Rule Curves, also called Upper Rule Curves or Mandatory Rule Curves, specify the amount of flood control storage space that must be maintained to meet local and system flood control requirements. These curves define the maximum reservoir elevation that must not be exceeded except during flood regulation. Flood Control Rule Curves are made up of two components: a fixed component guides drawdown during the fall to ensure that minimum flood control requirements can be met, and a variable component during winter and spring is based on forecast runoff. For Treaty projects, the Flood Control Rule Curves are based on the Flood Control Storage Diagram/Reservation Curves.

Flood Control Storage (Treaty) - A total of 15.5 Maf of storage is available in the three Canadian Treaty reservoirs for control of floods. Of this total, 8.45 Maf of storage is classified as Primary Storage and is available on a year-to-year basis. The remaining 7 Maf is classified as On-Call storage and is available only for control of large floods. (Treaty Articles V and VI and FCOP Section III)

Flow - Streamflow; the rate at which water passes a given point in a stream, usually expressed in cubic feet per second.

Reservoir Elevation - The water surface elevation immediately above a dam or hydroelectric plant intake structure.

Forecast Mode - A study mode that assumes limited foreknowledge of basin hydrology.

Freshet - A substantial rise in streamflow caused by rain or snowmelt. In the Columbia River system, the freshet normally refers to the snowmelt runoff occurring in the late spring and early summer.

Generation - The act or process of producing electric energy from other forms of energy; also the amount of electric energy so produced.

Gigawatt - One million kilowatts.

Head - The measure of potential energy due to the difference in water surface elevation between two points. In hydropower regulation studies, head is the difference in elevation between the forebay elevation and the tailwater.

Headwater Projects - Reservoirs located on upper tributaries of the Columbia River. They generally have large storage capabilities relative to their inflow and are operated to provide flood control and power benefits at downstream hydro plants. They cannot be operated on a day-to-day basis for flood control of the lower Columbia due to the relatively long time it takes for a change in outflow at these reservoirs to have a significant effect upon streamflow in the lower Columbia River. Headwater Projects are those classified as Category I reservoirs in the Flood Control Operating Plan. (FCOP Section 2-4)

Hydro Independents - The hydroelectric projects of the region that are not regulated in reservoir simulation models of the coordinated Columbia River system. The output of these

projects is accounted for by reducing system loads rather than simulating the operation of the projects. These projects are small and have little or no hydraulic effect on the operation of the coordinated system. Hydro independents modeled in HYDSIM include the Federal Willamette projects, Yakima projects, and projects upstream of Brownlee.

Hydroregulation Studies - Studies that simulate operation of the reservoir system.

Hydraulic Capacity - The maximum flow that a hydroelectric plant can utilize for power generation.

HYDSIM - HYDSIM is the hydro regulation model that is used in AOP studies. It simulates the month-to-month operation of the Pacific Northwest hydropower system in accordance with operating criteria and constraints based on the Columbia River Treaty. HYDSIM is used to determine the hydro system generation and resulting project outflows, ending storage contents, and so on under varying inputs of inflows, power loads, operating procedures and constraints, and physical plant data. HYDSIM is a deterministic model that uses rule curves and flow/storage constraints to achieve operating objectives, especially for power, flood control, fish flows and spill, and recreation.

Independent Power Producer - A non-utility producer of electricity that operates one or more generation plants under the 1978 Public Utility Regulatory Policies Act (PURPA). Many independent power producers are cogenerators who produce power for their own use and sell the extra power to their local utilities.

Initial Control Flow - The annual flow target at The Dalles. The ICF is fundamentally a water balance calculated using the available system storage volume on April 30 and the forecasted seasonal runoff volume. The resultant volume is then converted to a flow rate and labeled the ICF. The simplistic interpretation of this ICF is that all unregulated flow above the ICF during the runoff season at The Dalles can be stored, thereby refilling reservoirs. The ICF is thus the trigger to initiate system refill. The ICF is used to ensure that the projects refill while minimizing the peak runoff at The Dalles. The procedure for determining the ICF is presented in the Treaty FCOP.

Installed Capacity - Same as nameplate capacity unless otherwise specified.

International Joint Commission - The IJC was created under the Boundary Waters Treaty of 1909 between the United States and Canada to render decisions on the use of boundary waters, investigate important problems arising along the common frontiers not necessarily connected with waterways, and make recommendations on any question referred to it by either government. Differences arising under the Treaty that the Entities and PEB cannot resolve may be referred by either country to the IJC for decision. (Treaty Article XVI, and Annual Report Section II)

Intertie - Transmission circuit used to tie or interconnect two load areas or two utility systems.

Irrigation Depletions - Adjustments to streamflow data to account for projected irrigation withdrawals.

Kilowatt - The electrical unit of power that equals 1,000 Watts or 1.341 horsepower.

Kilowatt-hour - The basic unit of electrical energy. It equals one kilowatt of power applied for one hour.

KSFD - thousand second-foot-days; a unit of reservoir volume equal to 86,400,000 ft³, or ~1989 Kaf, and equivalent to a flow of 1000 ft³/second for one day.

Libby Coordination Agreement - The Columbia River Treaty Entity Agreement Coordinating the Operation of the Libby Project With the Operation of Hydroelectric Plants on the Kootenay River and Elsewhere in Canada, signed in the year 2000.

Load - The amount of electric energy delivered or required at any specified point or points on a system.

Load Factor - The ratio of the average load over a designated period to the peak load occurring in that period.

Load Shape/Pattern - The characteristic variation in the magnitude of the power load with respect to time, such as a daily, weekly, or annual period.

Local Flood Control – Small basin or sub-basin measures taken to control flooding within a relatively limited area, usually without consequences for a larger-area flood control regime.

Long-Term Planning Studies – Hydro regulation studies that simulate longer-term system conditions; usually in a six-year AOP horizon.

Transmission Losses - The general term applied to energy (kilowatthours) and power (kilowatts) lost when operating an electric system, occurring mainly as energy turns to waste heat in electrical conductors and apparatus. System losses consist of transmission, transformation, and distribution losses and unaccounted-for energy losses between sources of supply and points of delivery.

Maximum Outflows - Maximum discharge levels that have been established either for flood control or to ensure that as much of the project discharge as possible is used for power generation.

Megawatt - One thousand kilowatts.

Megawatt-hour - One thousand kilowatt-hours.

Mica/Arrow Balancing - The operation of Mica to specific Project Operating Criteria, together with compensating changes to Arrow's operation (in the event that Mica's operation results in more or less than Mica's share of draft, compensating changes will be made from Arrow to the extent possible).

Minimum Outflows - Minimum discharge levels that must be maintained either for power or for non-power river uses such as fish and wildlife, navigation, or irrigation; in some cases minimum generation requirements establish minimum discharge levels.

Modified Flows/Streamflows - Observed or historical flows that have been adjusted to a common level of development by correcting for the effects of irrigation and other diversion demands, return flows, and changes in storage of upstream reservoirs and lakes that are not included in the reservoir simulation model. Modified flows are used for all Treaty regulation studies.

Modified Regulation - The Modified Regulation fine-tunes the Preliminary Regulation to ensure that the hydro system is used to its fullest potential. Part of this process includes determining interchange energy obligations and shifting and shaping FELCC. (PNCA Sections 6c and 6d)

Monthly Load Factor - The ratio of the average load over a month to the peak load occurring in that month.

NGVD - National Geodetic Vertical Datum; a measure of land elevation essentially the same as Mean Sea Level (MSL); a fixed surface reference established by the U.S. Coast and Geodetic Survey in 1929 as the datum to which relief features and elevation data are referenced.

Non-firm Energy - Same as Secondary Energy.

Non-Power Operating Requirements - Operating requirements at hydroelectric projects that pertain to navigation, flood control, recreation, irrigation, fish and wildlife mitigation, and other non-power uses of the river.

Non-Treaty Storage - Reservoir storage in Canadian reservoirs on the Columbia River in excess of that which is regulated under the Treaty.

Non-Triggered Years - Years for which Called Upon was not triggered based on forecast flow volume.

Minimum Pool - The minimum forebay water surface elevation within the reservoir's normal operating range.

Observed Mode - A mode of conducting a study in which perfect foreknowledge of the basin hydrology is assumed.

Operating Criteria – All the rule curves of all kinds, APOC, Mica operating limits, draft limits, maximum and minimum flows that apply to and guide reservoir operations.

Operating Limits - Operating rules that set limits on the operation of projects for hydropower. Examples are flood control rule curves, minimum discharge requirements for fisheries and navigation, and maximum and minimum reservoir elevations/content.

Operating Procedures - Specific steps or tasks that should be taken by one or more specific operating positions to achieve specific operating goal(s). **OR** Documents that identify specific steps or tasks that should be taken by one or more specific operating positions to achieve specific operating goal(s). The steps in an operating procedure should be followed in the order in which they are presented, and should be performed by the position(s) identified; a document that lists the specific steps for a system operator to take in removing a specific transmission line from service is an example of an operating procedure.

Operating Rule Curve - The Operating Rule Curve for each reservoir is a synthesis of other curves, as follows:

- Aug 1 – Dec 31: ORC = Higher of CRC1 and ARC
- Jan 1 - Jul 31: ORC = Lower of VRC and Higher of CRC1 and ARC
- Jan 1 - Apr 15: ORC is limited to no lower than ORCLL
- At all times: ORC is limited to no higher than the URC

The Operating Rule Curve allows, but limits, reservoir operation for the purpose of producing secondary energy. Reservoirs are drafted below Operating Rule Curves only if required to maintain the FELCC of the system.

Operating Rule Curve Lower Limit - The minimum month-end storage contents that provide a high probability that the system will be capable of meeting its FELCC during the period January 1 through April 30 in the event that the Variable Refill Curves permit storage to be emptied prior to the start of the freshet. The ORCLL is developed from 1936-37 water conditions, which represent the lowest January 1 through April 30 run-off volume for the system as a whole.

Operating Year - The period upon which the system's reservoir seasonal operating cycle is based. It begins on August 1, which is when the reservoir system is generally at its highest level, and extends through July 31 of the following year.

Outflow - The total flow released from a reservoir project, including water passed through the powerhouse, spillway, regulating outlets, fish passage facilities, and navigation facilities.

Pacific Northwest Area - As defined in Section 7 of Treaty Annex A, the area comprised of Oregon, Washington, Idaho, and Montana west of the continental divide, but excluding areas served on the Treaty ratification date by the California-Oregon Power Company and the Utah Power & Light Company (now the service area of Pacific Power & Light Company and still excluded from the Pacific Northwest Area loads).

Peak Load - Literally, the maximum load in a stated period of time. Sometimes the term is used in a general sense to describe that portion of the load above the base load.

Peaking - Power plant operation to meet the variable portion of the daily load.

Peaking Capability - The maximum peak load that can be supplied by a generating unit, station, or system in a stated time period. For a hydro project, the peaking capability would be equal to the maximum plant capability only under optimum head and flow conditions; often the peaking capability may be less due to reservoir drawdown or tailwater encroachment. Also called Peaking Capacity.

Peak Reserve - Extra generating capacity available to meet unanticipated demands for power

Permanent Engineering Board - An independent board established under provisions of the Treaty to periodically review and report to the governments of Canada and the United States on operation of the Treaty projects and to investigate and report on any other matter coming within the scope of the Treaty at the request of either Canada or the United State. (Treaty Article XV)

Plant Factor - The ratio of (a) the average load on the generating plant for the period of time considered to (b) the capacity rating of the plant. Unless otherwise identified, capacity factor is computed on an annual basis.

Power Discharge Requirements - The project discharges used to compute VECCs and determined from the Refill Studies. These flows are based on FELCC needs and ensure a reasonable probability of refill under better than critical water conditions. The PDRs, which are established for the months of January through July for each year in the study period, set a limit on the amount of secondary energy that can be produced under various runoff conditions. In planning, PDRs are determined for three forecast runoff levels. When the runoff forecast becomes available in January, new PDRs are determined by interpolation.

Power Draft – Release of water from a reservoir(s) through a generator(s) for the purpose of producing electric power.

Power Refill studies - These studies develop guidelines for generation to produce secondary energy while protecting future FELCC and ensuring a high probability of refill.

Primary Storage - The 8.45 Maf of flood control storage that is available in each year in the three Canadian Treaty reservoirs for control of floods. (Treaty Article VI and FCOP Section 3-1)

Principles and Procedures (POP) - A document prepared by the Columbia River Treaty Operating Committee to serve as a guide for the preparation and use of hydroelectric operating plans for Canadian storage. It is updated periodically to incorporate changes that reflect current operating practices.

Project Operating Criteria – Constraints on operations (e.g., flow targets, minimum and maximum discharge) at a particular generating project to reflect characteristics and uses of the environment at and near the project.

Project Operating Procedures - Specific steps or tasks that should be taken by one or more specific operating positions to achieve specific operating goal(s) for one specific project/dam/reservoir.

Proportional Draft – A procedure for equitably distributing draft of storage among the reservoirs in the system during poor water years to ensure that FELCC will be met when reservoirs must be drafted below Energy Content Curves.

Proportional Draft Point - Points for each reservoir established to distribute proportional draft among reservoirs when low water conditions occur.

Protocol - A document accompanying an exchange of notes dated January 22, 1964 that clarifies certain particulars of the Treaty. The Protocol has the same force as the Treaty itself.

Refill Curve - A guide to operation of a reservoir that optimizes the production of usable energy consistent with an agreed probability that reservoir refill will not be jeopardized by secondary energy production. A reservoir shall not be drafted below its Refill Curve to serve any secondary energy loads, unless required by established operating procedures at the project. Two Refill Curves are developed to guide reservoir operations. The Variable Refill Curve is based on a 95 percent refill probability, and the Assured Refill Curve is developed using the second lowest January-July volume inflow of historical streamflows (1931). In essence, the ARC provides a check on the VRC and allows a deeper draft if the VRC is found to be overly conservative.

Refill Period - That portion of the annual reservoir operation cycle when reservoirs are allowed to refill; on the Columbia River system, this period typically extends from the middle of April through the end of July. The PNCA defines the refill-hold period as that period beginning at the end of the Drawdown Period and ending at the beginning of the next subsequent Drawdown Period. (PNCA Section 2dd)

Refill Study - Refill studies develop PDRs used to compute the ARC and VRC. The studies incorporate the CRCs and FELCC developed in the Critical Period System Regulation Study. The AOP refill studies use a 30-year historical streamflow record, and the PNCA refill studies use a 50-year historical streamflow record. The Refill Studies are intended to determine if energy content curves based on the AOP or Final Regulation will permit meeting FELCC under historical streamflow conditions and will meet a refill objective of 95 percent confidence of refill before production of secondary energy. (PNCA Section 7)

Regulated Flow - The controlled rate of flow at a given point during a specified period resulting from actual reservoir operation or a simulated reservoir operation.

Hydroregulation Study - A study of simulated operation of a reservoir system.

Renewable Portfolio Standards - Policy of various states, including Oregon, Washington, Montana, and California, that requires electricity providers to obtain a minimum percentage of their power from renewable energy resources by a certain date.

Reoperation – The review and recalculation of the U.S. Optimum Long-Term Study by Canada to produce optimal benefits of power and flood control for both nations.

Reserves - Generating capability that must be provided by a power system in excess of that required to meet forecasted peak loads. This “extra” generation is required to meet unanticipated demands for power or to generate power in the event of loss of generation resulting from scheduled or unscheduled outages of regularly used generating capacity.

Residual Hydro Load - The net result of PNWA loads, thermal installations, and other resources; a residual load for the coordinated hydropower system to meet.

Resources - Means of producing or saving energy that can be used to meet demand for energy (loads).

Return Flow - The portion of a water diversion demand that is returned to the stream system and is available for use downstream.

Rule Curves - Rule curves specify the end of month storage content for the reservoirs. In doing so, they delineate a schedule of reservoir drafts and fills that are designed to utilize storage and natural flow in such a manner as to produce the optimum amount of FELCC, usable secondary energy, and reservoir refill probability under any pattern of streamflow. Flood control rule curves also provide guidance to ensure adequate flood control on the Columbia River and its tributaries. The rule curves are derived from system-wide power regulation studies and hydrologic analyses of flood control needs in the basin designed specifically to develop and test the criteria.

Run-of-River Plant - A hydroelectric plant that depends for generation chiefly on the flow of a stream as it occurs, as opposed to a storage project that has sufficient storage capacity to carry water from one season to another. Some run-of-river projects have a limited storage capacity (pondage) that permits them to regulate streamflow on a daily or weekly basis.

Secondary Energy - All hydroelectric energy generated in excess of the firm energy capability. This additional generation results from streamflows greater than those in the critical period studies that determine the hydro firm energy capability.

Shaped Load - Energy demand whose variance over time has been revised mathematically to dispose of surplus energy and balance loads and resources.

Short-Term Market - Purchases and sales of firm and non-firm power ranging from the next hour, for an hour, up to five years.

Spill - Water passed over a spillway without going through turbines to produce electricity. Spill can be forced, when there is no storage capability and flows exceed turbine capacity; can be due to lack of market; or can be planned. An example of planned spill is when water is spilled to enhance juvenile fish passage.

Standard Flood Control - Standard Flood Control is used in all Treaty regulation studies including the AOP, DOP, and TSR and is defined in the Columbia River Treaty Flood Control Operating Plan. See also VarQ, Libby variable outflow flood control.

Step I/II/III Studies - Thirty-year system regulation studies made annually to determine the increase in dependable hydroelectric capacity and the increase in average annual hydroelectric energy resulting from operation of the Treaty projects. These studies are a part of the process to develop the AOP and the downstream power benefits. These studies are prepared each year for the sixth succeeding year in accordance with Treaty Annex B. (Annex B Paragraph 7)

Step I Study - The Step I system, defined in Annex B, includes the planned total US hydro and thermal system, including projected and existing resources used to meet Step I loads, with 15.5 Maf of Canadian Treaty storage. The Step I loads are the Pacific Northwest Area loads, including Grand Coulee pumping, adjusted for power flows into and out of the Pacific Northwest in accordance with the 1988 Entity agreements. The thermal installations, hydro plant data, and operating procedures, to the extent they apply to the respective critical periods, are carried over from Step I to the Step II and III studies. The Step I studies also determine the operating criteria for Treaty projects to be used in the DOP unless otherwise agreed by the Entities.

Step II and III Studies - The Step II system is the Base system as defined in Annex B (essentially the 1961 hydro system) with the addition of 15.5 Maf of Treaty storage. The Step III hydro system is the Base system only and does not include Treaty storage. The thermal installations, hydro plant data, and operating procedures, to the extent they apply to the respective critical periods, are carried over from Step I to the Step II and III studies. Step II and III loads are shaped to the PNWA load shape, including Grand Coulee pumping. The downstream power benefits are calculated from the results of system capability studies for the Step II and III systems.

Storage - Space in a reservoir that is usable for impounding water. The Treaty deals only with storage regulation for flood control and hydroelectric power generation, but many of the reservoirs in the system are regulated for other purposes as well. (Treaty Article I)

Storage Content - Volume of water in a reservoir at any particular point in time.

Storage Project - A project with a reservoir of sufficient size to store water in the high-flow season for release in the low-flow season, thus providing a firm flow substantially greater than the minimum natural flow. A storage project may have its own power plant or may be used only for increasing generation at downstream plants.

Storage Reservation Diagram - A graph of a family of curves of Required Storage Space by month. Each curve on the SRD corresponds to a given seasonal volume—the volume of flow to pass a certain point over a period of months.

Streamline Procedures – Reference to a way to complete AOP studies by utilizing either 1) numbers and calculations from previous years or 2) agreed-upon numbers and values in place of extensive studies and modeling.

System Regulation Study - Each operating plan specifies System Operating Criteria, which are developed from a series of System Regulation Studies designed specifically to develop and test the criteria:

- Critical Period System Regulation Studies establish U.S. system FLCC and low streamflow operating criteria, based on the worst water years.
- Refill Studies establish operating criteria for middle and high water years by analyzing 70 water years (30 for Steps II/III), with all reservoirs reinitialized to as full as possible at the start of each operating year.
- System Regulation Studies simulate a continuous operation over 70 years (30 for Steps II/III) with the operating criteria established above and, if applicable, Mica/Arrow operating criteria that optimize generation in both countries.

System Sales - Flows of firm power out of the Pacific Northwest Area, excluding:

- flows of power from exchanges of firm power that neither increase nor decrease the net flow of power between the PNWA and other regions
- plant sales
- flow-through transfers of power from outside the PNWA to outside the PNWA
- delivery of Canadian Entitlement out of the PNWA

Thermal Displacement Market - That portion of the generation from the U.S. Step I thermal plants that can potentially be displaced with hydro secondary energy minus System Sales, with System Sales being uniformly distributed over all months in the year. (Annex B Paragraph 3)

Transmission Interconnection (Intertie) - Transmission circuit used to tie or interconnect two load areas or two utility systems.

Treaty - The Treaty between Canada and the United States of America relating to the Co-operative Development of the Water Resources of the Columbia River Basin, including its Annexes A and B, ratified on September 16, 1964.

Treaty Obligation - All of the series of obligations, tasks, duties and responsibilities from Canada to the U.S., and the U.S. to Canada, spelled out in the Treaty.

Treaty Storage - Usually refers to the storage provided by Canada under Article II of the Treaty at the Mica Creek, Arrow Lakes, and Duncan Lake projects. All storage authorized by the Treaty, including Libby, is sometimes loosely referred to as Treaty storage.

Treaty Storage Regulation - A hydroregulation study based on the DOP operating criteria and current operating data, including streamflows, operating rule curves, and flood control rule curves. A TSR study is completed at least twice per month to compute the DOP storage obligation for Canadian storage. Loads and non-power constraints are not updated for current conditions.

U.S. Entity - One of the two parties designated to operate the Columbia River Treaty; made up of the Administrator of the Bonneville Power Administration (chairman) and the Division Engineer, North Pacific Division, U.S. Army Corps of Engineers (member).

Unregulated Flow - Observed streamflow adjusted to eliminate the effects of reservoir regulation but reflecting the effects of natural storage in lakes and river channels.

Upper Rule Curve - The month-end reservoir levels at each project during the evacuation and refill periods. Upper Rule Curves define the maximum allowable storage content of each reservoir and are determined from flood control regulations, in accordance with the Treaty FCOP. Also see Flood Control Rule Curve.

Usable Energy - All hydroelectric energy that can be used in meeting system firm and secondary loads. It is possible that there may not be a market for all of the secondary energy that could be generated in years of abundant water supply, and some of the water may have to be diverted over project spillways and the energy wasted.

U.S. Optimum Study - The U.S. AOP-like study that determines what the power output and flood control protection should be for the maximum benefit in the U.S.

Variable Refill Curve - The VRC indicates the end-of-month storage content required during the refill period to refill with 95 percent confidence each cyclic reservoir consistent with (1) at-site volume inflow forecasts, (2) Power Discharge Requirements, and (3) upstream reservoir refill requirements.

VarQ - VarQ means variable Q, or variable flow, as it pertains to flood control limits. It is an adaptive management technique that, rather than requiring fixed and rigid releases of water as levels in a reservoir approach a fixed flood control rule curve, allows managers to retain more water during the flood control season.

Year - A 12-month period for a particular purpose.

Operating Year - The August 1 through July 31 period, used for regulation studies for both the Treaty and PNCA.

Reporting Year (Entity and PEB) - The period covered by the Annual Report of the Columbia River Treaty, Canadian and United States Entities, and the Permanent Engineering Board's Annual Report to the Governments of The United States and Canada, specifically, October 1 through September 30. The reporting period is tied primarily to the need to report flow data, which is published by the responsible agencies on a Water Year basis. (Treaty Article XV)

Streamflow Year (Treaty) - The Water Year used in developing the streamflow data upon which Treaty regulation studies are performed: specifically, July 1 through June 30. (Protocol Section VIII)

Water Year - Established by Canadian and United States water resources agencies for purposes of uniformly reporting hydrologic records. The Water Year extends from

October 1 through September 30, but the streamflows used for all reservoir regulation studies of the Columbia River system are based on the period August 1 through July 31.

This page intentionally left blank